



Planning Commission

Larry Fox, Chairperson Summer L. McMullen, Trustee
Michael Mitchell, Vice-Chairperson Keith Voight, Secretary
Michelle LaRose, Commissioner Sue Grissim, Commissioner
Tom Murphy, Commissioner

Planning Commission Meeting Agenda
Hartland Township Hall
Thursday, June 10, 2021
7:00 PM

1. Call to Order
2. Pledge of Allegiance
3. Roll Call
4. Approval of the Agenda
5. Approval of Meeting Minutes
 - a. Planning Commission Minutes of April 8, 2021
6. Call to Public
7. Livingston County Planning Commission Visit
8. Public Hearing
 - a. Site Plan/PD Application #20-012 Newberry Place Planned Development – Preliminary Site Plan (Pattern Book submitted on April 15, 2021)
9. Call to Public
10. Planner's Report
11. Committee Reports
12. Adjournment

HARTLAND TOWNSHIP PLANNING COMMISSION **DRAFT** REGULAR MEETING MINUTES

April 8, 2021 – 7:00 p.m.

1. **Call to Order:** Chair Fox called the meeting to order at approximately 7:00 p.m.
2. **Pledge of Allegiance:**
3. **Roll Call and Recognition of Visitors:**
Present – Commissioners Fox, Grissim, LaRose, McMullen, Mitchell, Voight
Absent – Commissioner Murphy
4. **Approval of the Agenda:**
A Motion to approve the April 8, 2021 Planning Commission Regular Meeting Agenda was made by Commissioner Mitchell and seconded by Commissioner Voight. Motion carried unanimously.
5. **Approval of Minutes**
 - a. **Planning Commission Minutes of March 11, 2021**
A Motion to approve the March 11, 2021 Planning Commission Regular Meeting Minutes was made by Commissioner Grissim and seconded by Commissioner LaRose. Motion carried unanimously.
6. **Call to Public:**
None
7. **Public Hearing:**
 - a. **Site Plan with Special Land Use Application #21-003 (Hungry Howie's)** a request to construct a multi-tenant building approximately 4,550 square feet in size, with retail/office space and two (2) carry out restaurants, each having drive-through/pick-up service.

Chair Fox explained the Public Hearing process.

Chair Fox opened the Public Hearing at 7:03 PM stating all noticing requirements have been met.

Director Langer summarized the request, location and process stating the following:

- Site is in front of Bella Vita.
- Road name will be Bella Vita Court
- Not a traditional drive-through but drive-up window
 - No menu boards
 - No stacking lanes
 - No indoor dining
 - Orders placed by phone or online
 - Pick-up window only
- Planning Commission will approve the Site Plan and make a recommendation for the Special Use Permit to the Township Board. The Township Board has final approval.

The Applicant, Steve Peterson, had nothing to add.

Call to Public

None

Chair Fox closed the Public Hearing at 7:09 PM

Chair Fox asked the Planning Commission to review the **Special Land Use Review – General Standards** found in Section 6.6, Special Uses, of the Hartland Township Zoning Ordinance and listed in the staff memorandum.

The Planning Commission had no concerns.

Chair Fox continued with the **Special Land Use Review – Applicable Site Standards**. Section 4.28

Location of driveways. Ingress and egress points shall be located at least sixty (60) feet from the intersection of any two (2) streets (measured from the nearest right-of-way line). The use of secondary access drives in accordance with Section 5.10.2 is required.

Director Langer stated the most southern of the two (2) commercial driveways into the site is located approximately 47 feet from the right-of way line of Highland Road and does not comply with this standard. However, when Bella Vita was being developed, MDOT did not seem to have any negative concerns with the road, so we are moving ahead with it as shown.

Stacking space and lanes shall be provided as specified in Section 5.8, Off-Street Parking Requirements. Additionally, the site design must allow for unimpeded circulation around the building outside of the drive-through lanes.

Director Langer stated the following:

- The two (2) proposed restaurants provide carry out service/pick up service and each restaurant has its own drive-through window.
- Per Section 5.8.4.H., the restaurant category for carry-out or delicatessen, with less than six (6) tables or booths, does not require stacking spaces.
- Pick-up window only. No menu board or ordering stations or stacking spaces.

The Applicant added following the order, the customer will be given a time to pick up their items, so they do not anticipate cars stacking. Most payments will be handled online but someone could pay at the window if they chose.

Director Langer continued there is no known tenant for the second business so they have asked the Applicant to provide a letter indicating their understanding that there are limitations; this site cannot accommodate a standard fast-food restaurant with a drive-through. It is for pick up only. Chair Fox asked if that is how it would be conveyed to a potential future tenant, that this site was developed from day one with this in mind. Director Langer confirmed and stated the Applicant has provided that letter. The Applicant confirmed. The Planning Commission briefly discussed the wording in the Motion addressing this issue.

SITE PLAN REVIEW – Applicable Site Standards

Chair Fox referred to the staff letter dated April 1, 2021.

Site Requirements

Off-Street Parking

Director Langer explained there are two ways to calculate parking here: based on building square footage which generates a number of spaces required that serves for all allowed uses present and future; or by use, which generates a specific number for that use but must be recalculated for each new use. This complies with either one. The Planning Department would like direction going forward for what types of restaurant uses could be permitted on this site, given the potential parking and stacking limitations.

Commissioner LaRose asked what the parking requirement is for the current location of Hungry Howie's. The Applicant estimated there are fewer than 25 parking spots.

There was a brief discussion on parking at the current site and future options including off-site parking.

Commissioner Mitchell expressed concern about setting a precedent and does not understand why there are two ways of calculating parking standards.

Director Langer replied with the following:

- The Zoning Ordinance has many different ways of calculating parking based on the different uses.
- If it were solely a Hungry Howie's Restaurant, they would use the restaurant calculation process determined by the number of seats and the square footage of the building available to the public.
- If the use changed and it became an office, it would be recalculated using the office standards.
- For any use, parking calculations must be checked.
- For multi-tenant buildings, with many different uses, a general retail parking standard is applied.
- This building is unusual as it is multi-tenant, has a restaurant with no indoor seating, is carry-out only, and is only 4000 square feet.
- Normally a building of this size would be only one tenant, but Hungry Howie's wants to recoup some of their investment by renting out the additional space.
- Planning is looking for direction on how to calculate parking for this unusual situation.

Commissioner Mitchell asked if the property were sold, and the new owner wanted to remodel and make it a restaurant with indoor seating, would the parking requirements previously approved be able to be revised.

Director Langer stated if it were a complete change in use, yes, the parking could be recalculated; however, if parking is calculated using the general retail standards, any business allowed in the GC district could go into one of those spaces without recalculating the parking, assuming it remains a multi-tenant building.

The Planning Commission directed staff to use the calculations using general retail/office formula for GFA (Gross Floor Area) of building (4,550 sq. ft.).

Landscaping and Screening

Foundation Landscaping

Commissioner Grissim expressed some concern over the Foundation Landscaping on the south side, the width, and the type of plants being used.

The Planning Commission discussed the following Foundation Landscaping items:

- Which plants are being counted as part of the Foundation Landscaping requirement.
- Redundancy.
- Size of planters.
- Location of planters.
- Width of sidewalk.
- ADA ramp regulations.
- Location of building and the option to move it back on the site.
- Reducing the size of the Loading area to allow for more space.
- Cannot only be flowers as there needs to be something there during the winter months.
- Planters acting as bollards to protect the building.

The Planning Commission indicated they are willing to work with the Applicant to make it look as nice as possible with the size and space limitations.

Parking Lot Landscaping

Commissioner Grissim asked that the westernmost endcap, the most exposed, be widened to 10 feet which would allow the easternmost endcap to be narrower, place the Landscaping in areas where it can have the greatest impact and lessen it in other areas.

Commissioner Voight commented he would like to avoid the same issue they had with Culver's who came back after the fact stating the required trees were impeding the visibility of their sign.

Perimeter Landscaping

Commissioner Grissim stated the screening for the parking lot could also be counted as Greenbelt Landscaping to reduce the number of required plantings. There are many items on the plan that are shown so close together in ten years it would not produce the desired result. She stated staff will work with the Applicant. Chair Fox agreed this is an unusual lot with a tight space where the requirements overlap; relief has to be given.

Buffering or Screening

Commissioner Grissim supported staff's suggestion to eliminate the row of deciduous shrubs by the lawn area and replace with lawn between the back of curb and the first boulder wall, as this area is limited in width and the shrubs could overtake the space. It will be easier to maintain and repair the negative effects of salt in the spring.

Chair Fox summarized staff will work with the Applicant to reduce the amount of Landscaping shown on the plan to achieve a pleasing visual without being overplanted and difficult to maintain.

Sidewalks and Pathways

Chair Fox stated if the asphalt pathway abutting M-59 is still on the site it should be removed prior to the conclusion of this project.

Lighting

Director Langer stated the Photometric Plan must be revised as the light intensity (footcandle value) was taken at ground level, and the Ordinance requires light intensity to be measured at five (5) feet above ground level. A revised plan is required as part of the construction set of plans.

Architecture / Building Materials

Chair Fox expressed concern about the product being used. The Applicant stated the previous sample board had masonry brick, the new sample board indicated clay brick; the accent bands at the top and the bottom are masonry. Chair Fox stated the clay brick shown is the kind that has been allowed on large structures such as Walmart; smaller structures typically use standard size brick.

The Planning Commission discussed types/sizes of brick, location, consistency, cost, style, modern trends.

Commissioner Voight stated he can see both arguments and does not really have a preference.

Commissioner LaRose stated she sees the choices as complementary to Bella Vita and if it requires less maintenance and costs less to install, she approves.

Commissioner Grissim stated she is torn as well; the new larger style as opposed to the smaller scale for smaller buildings. She continued as long as quality materials are being used, the Applicant's choices are acceptable.

Chair Fox stated he is fine with it either way and mentioned it as a historical reference. He would like to ensure the brick used is clay and not masonry as the masonry brick color fades over time, the size of the brick does not matter. The Planning Commission concurred.

Chair Fox asked if they had any questions regarding the review letters. The Applicant stated he was unsure if he had read all of them. Chair Fox stated for the record they are part of the record and if there are any concerns, those can be handled by staff or the agency providing them. The Applicant stated they have questions for Department of Public Works (DPW) and will follow up with them.

Commissioner Voight asked about a monument sign and the landscaping required. Chair Fox stated there is one sign at the corner for all of the businesses. Director Langer confirmed the signage will be handled separately by staff.

Commissioner LaRose offered the following Motion:

Move to recommend approval of Site Plan with Special Land Use Application #21-003, a request to construct a multi-tenant building approximately 4,550 square feet in size, with retail/office space and two (2) carry out restaurants, each having drive-through/pick-up service, as a special land use, on a vacant parcel in Section 22 of the Township, north of Highland Road and East of Bella Vita Drive (Parcel ID #4708-22-400-025). The recommendation for approval is based on the following findings:

- 1. The proposed special land use, carry out restaurant with drive-through service, meets the intent and purposes of the Ordinance as well as the specific Special Use standards outlined in Section 6.6 (Special Uses) and the Planning Commission has determined the proposed drive lanes do not have to comply with the standards in Section 4.28 (Fast Food and Drive-through Restaurants), as the proposed drive lanes are of a different nature, but still shall be permitted as a special land use in the GC-General Commercial zoning district.**
- 2. The proposed use is compatible with the existing and future land uses in the vicinity.**

3. **The proposed use will be served by public sanitary sewer and municipal water. The proposed use will be adequately served by existing essential facilities and public services, and the Fire Department has no objection.**
4. **The proposed use will not be detrimental, hazardous, or disturbing to the existing or future neighboring uses, persons, or the public welfare.**
5. **The proposed use will not create additional requirements at public cost for public facilities as the proposed site will be served by public sanitary sewer and municipal water.**

Approval is subject to the following conditions:

1. **The proposed Special Land Use, restaurant with drive-through service, is subject to approval by the Township Board.**
2. **The applicant shall adequately address the outstanding items noted in the Planning Department’s memorandum, dated April 1, 2021. Revised plans, if necessary, shall be subject to an administrative review by the Planning staff prior to the issuance of a land use permit.**
3. **The applicant understands and is in full agreement that the drive lanes as indicated on the site plans shall not be used for a drive-through restaurant, as outlined in Section 4.28 of the Ordinance, unless the site plan has been modified to comply with the Ordinance and approved by the Planning Commission.**
4. **A land use permit is required after approval of the Site Plan and Special Use Permit and prior to construction.**
5. **Applicant complies with any requirements of the Department of Public Works Director, Township Engineering Consultant (HRC), Hartland Deerfield Fire Authority, and all other government agencies, as applicable.**

Seconded by Commissioner Voight. Motion carried unanimously.

8. Call to Public:

None

9. Planner's Report:

None

10. Committee Reports:

Commissioner Mitchell asked if an ordinance amendment is needed to specifically define a pick-up window as opposed to a drive-through window with menu boards.

The Planning Commission briefly discussed the following:

- Pick-up windows vs drive-throughs
- Dry cleaning
- Stacking issues
- Pharmacy uses/COVID testing
- Food service without a menu board

Chair Fox stated this topic could be a discussion item for a future workshop.

11. Adjournment:

A Motion to adjourn was made by Commissioner Mitchell and seconded by Commissioner LaRose. Motion carried unanimously. The meeting was adjourned at approximately 8:20 p.m.

Hartland Township Planning Commission Meeting Agenda Memorandum

Submitted By: Troy Langer, Planning Director

Subject: Site Plan/PD Application #20-012 Newberry Place Planned Development – Preliminary Site Plan (Pattern Book submitted on April 15, 2021)

Date: June 3, 2021

Recommended Action

Move to recommend approval of Site Plan Application #20-012, the Preliminary Planned Development Site Plan for Newberry Place, subject to the following:

1. The Preliminary Planned Development Site Plan for Newberry Place SP #20-012, is subject to the approval of the Township Board.
2. The applicant shall adequately address the outstanding items noted in the Planning Department’s memorandum, dated June 3, 2021, on a revised Preliminary Plan Site Plan, subject to an administrative review by Planning staff prior to the Final Review of the Planned Development. This revised Preliminary Plan will also be presented to the Planning Commission and Township Board as part of the Final Review of the Planned Development.
3. Applicant complies with any requirements of the Township Engineering Consultant, Department of Public Works Director, Hartland Deerfield Fire Authority, and all other government agencies, as applicable.
4. Municipal water shall be available for this development. In the event that municipal water is not available for this project, the developer shall re-submit plans to be approved by the Planning Commission and Township Board that provide an acceptable water source.
5. After the Planned Development (PD) has been approved by the Township, the applicant/developer will be required to obtain Site Plan Review approval from the Township Planning Commission for any portion(s) of the development project.
6. In the event that any portion of the project involves work, within a regulated wetland, the applicant/developer shall obtain all necessary permits from the Michigan Department of Environment, Great Lakes, and Energy (EGLE), as part of the Site Plan Review application to the Planning Commission.
7. The applicant/developer shall obtain all required permits/approvals from the Michigan Department of Transportation (MDOT) and the Livingston County Road Commission (LCRC), as part of the Site Plan Review application to the Planning Commission.
8. (Any other conditions the Planning Commission deems necessary)

Discussion

Applicant: David Straub, Mayberry Homes

Site Description

The proposed Newberry Place Planned Development (PD) is located on the north and south side of Highland Road (M-59), west of Pleasant Valley/Fenton Road, in Section 23 and 26 of the Township. The development is comprised of four (4) separate parcels, with a combined total of approximately 108.7 acres. The four (4) parcels are undeveloped and are zoned CA-Conservation Agricultural. Two (2) parcels are on the north side of Highland Road (Parcel ID#'s 4708-23-400-036, 2 acres in area; and 4708-23-400-037, 28.22 acres in area). The remaining two (2) parcels are on the south side of Highland Road as follows: Parcel ID #'s 4708-26-200-006, 7.40 acres in area; and 4708-26-200-007, 71.11 acres in area.

In this memorandum the two (2) parcels on the north side of Highland Road will be grouped together and referred to as the North Parcel. Similarly, the two (2) parcels on the south side of Highland Road will be called the South Parcel.

The Future Land Use Map designates each parcel as Special Planning Area in the 2015 Comprehensive Plan.

Lands to the west, north, and east of the North Parcel are zoned CA-Conservation Agricultural. Four (4) single family residential lots of approximately one acre in size, border the east side of the North Parcel and take access off Fenton Road. A residential subdivision (single family) is located on the north. The adjacent properties to the west include a church (All Saints Lutheran Church) and the Township-owned Heritage Park.

The 2015 Future Land Use Map (FLUM) shows a designation of Public/Quasi Public to the west (church and park) and Low Suburban Density Residential both to the north and east (east of Fenton Road).

In terms of the South Parcel, parcels to the east, west, and south are zoned CA-Conservation Agricultural. The South Parcel shares a common boundary with Hartland Glen Golf Course on the west property line and the forty-acre agricultural parcel that is no longer part of the proposal. The property directly south of the subject site is occupied by an agricultural operation and residence. The 2015 FLUM shows a designation of Medium Suburban Density Residential for the land directly to the south. The 40-acre parcel along Highland Road and west of the South Parcel is designated as a Special Planning Area. In 2021, the 2015 FLUM was amended to designate the Hartland Glen Golf Course as a Special Planning Area. The golf course abuts the South Parcel on part of its western border.

Site History

As background information, the planned development project was initially reviewed by the Township in 2007, under two applications: Site Plan Application #383 (Newberry-North and East) and Site Plan Application #386 (Newberry West). The total project area for the 2007 plans was approximately 148 acres. On April 26, 2007, the Planning Commission approved the preliminary planned development applications (SP #383-P and SP #386-P), including the Pattern Book dated May 25, 2007. The project did not move forward to final approval. However, the Township has had discussion about the Special Planning Area going back to the 1990's with a goal of this particulate development being a special development in the community.

Site Plan Application #383-P and #386-P (2007)

The Newberry Place Planned Development (PD) project was initially reviewed by the Township in 2007, under two applications: Site Plan Application #383 (Newberry-North and East) and Site Plan Application #386 (Newberry West). Newberry West is a vacant 40-acre parcel, south of Highland Road and east of Hartland Glen Golf Course. The total project area for the 2007 plans was approximately 148.7 acres. On April 26, 2007, the Planning Commission approved the preliminary planned development applications (SP #383-P and SP #386-P), including the Pattern Book dated May 25, 2007. The project did not move forward to final approval.

Site Plan Application #535-C (2015)

In 2015, a new application for Newberry Place was submitted to the Township, under SP PD #535-C. The Concept Plan was reviewed by the Township in 2015, under SP PD #535-C. The total project area at that time was approximately 108.7 acres and did not include the western 40 acres that had been part of SP #386 (Newberry West).

Site Plan Application #535-P (2016)

The Preliminary Plan for the Newberry Place Planned Development project, SP PD Application #535-P was submitted in 2016. A public hearing was held at the April 7, 2016 Planning Commission meeting and the plans were last reviewed by the Planning Commission on April 21, 2016. The project did not proceed to final approval. Since 2016 the Township has held informal meetings with the applicant to discuss revised development plans. Several versions of the development plans were submitted for staff to review, between 2016 and June 2019. In 2018, the project area was expanded to include the 40 acres on the south side of Highland Road (formerly called Newberry West), thus the total project area was approximately 148.7 acres.

July 2019 Concept Plans

In July 2019, the applicant submitted a new set of plans to the Township for Newberry Place, as an update to the plans previously presented under SP #535-P. The plans were conceptual in nature, showing five (5) development districts on the Regulation Plan: Single Family District; Single Family Detached Only District; Multiple Family District; Mixed Use District; and Commercial District. The project area consisted of 148.7 acres. Conceptual architectural renderings were provided for single family and multiple family housing, mixed use buildings, and commercial buildings. The intent of the Regulation Plan was to provide a wide range of uses within several of the districts to afford flexibility to address future development and housing trends. The plan layout was not intended to be the final site plan for the planned development, but instead it provides a regulation plan for the development categories, including the maximum number of residential units and residential density in each category. This allows for flexibility in the types of residential housing options, but the number of units and density is set per the plan.

Due to the number of changes to the 2016 plan (SP PD #535-P), the new Concept Plan (July 2, 2019) was presented to the Planning Commission on July 10, 2019 for their consideration and comments. After the Planning Commission presentation, the applicant revised the plan to add 66 dwelling units in the Mixed Use District, as stated on the Regulation Plan. The actual residential units were not shown on the overall development plan. This updated plan, dated July 25, 2019, was presented to the Township Board on August 6, 2019 for comments.

Site Plan Application #20-012 – Preliminary Site Plan Application for Newberry Place PD

On September 9, 2020, an application and Pattern Book were submitted for Preliminary Site Plan for Newberry Place PD, under SP #20-012. The plans were similar in design as were presented in July 2019, with the project area being 148.7 acres in size. A public hearing at the Planning Commission was

scheduled for this application on December 3, 2020; however, the applicant withdrew the request prior to that date. The Pattern Book was not reviewed by the Planning Commission.

Site Plan Application #21-006 Concept Plan (February 23, 2021 Concept Plan)

In February 2021 applicant revised the development plans and submitted a new Concept Plan and Pattern Book. The 40-acre parcel (formerly called Newberry West) was no longer part of the planned development. The project area included the North Parcel and South Parcel for a total of approximately 108.7 acres. The Concept Plan showed four (4) types of development districts: Single Family Residential; Single Family Detached Only Residential District; Mixed Use District; and Commercial District. Conceptual architectural renderings were provided for single family and multiple family housing, mixed use buildings, and commercial buildings.

Due to the number of changes to the plans last seen by the Township in 2019, the applicant was directed to present the 2021 Concept Plan to the Planning Commission and Township Board for their review and comments. The Concept Plan was reviewed under SP #21-006, by the Planning Commission on March 18, 2021, and the Township Board on March 23, 2021. The following comments were provided by the Planning Commission at the March 18, 2021 meeting:

- Concerns with the allowance for quad units on the North Parcel, which were not shown on previous plans.
- Concerns with the name of the Single Family District, which allows for attached residential units and motor court units (duplex, and 4-6 plex units).
- Concerns with the mix of different residential housing on the North Parcel (single family detached plus attached condominium housing)- if a quad unit is constructed and the market changes, and that style is no longer desirable, how will that look with just the one quad unit?
- The Pattern Book should include architectural renderings for the commercial buildings at the corner properties on the North and South parcels at Highland Road and Fenton/Pleasant Valley Road. These drawings should indicate the architectural design elements that were part of the original 2016 PD Pattern Book.
- Concerns with the layout of the motor courts and pedestrian access to the front door. Three car garages should be discouraged, and large driveways prohibited. Side-load garages should be used in the Single Family District to avoid that view of the garage doors.

Summary of Development Plans (2007-2021)

Following is a chart that summarizes the development plans from 2007, 2016, 2019, and 2021 plans (February 2021 Concept Plan and April 2021 Preliminary Plan). The data in **bold** type is based on plans and applicable staff memorandums that are on file, which staff rechecked. The figures in non-bold type in the Summary Chart are provided by the applicant in previous documents and/or the current submittal. Please refer to the applicant's letter dated April 15, 2021 (Historical Density Comparison) in the current submittal. In some cases, staff was unable to confirm what data was used by the applicant. That said, density calculations in this report are based on staff's information.

The stated acreage for the development/total project area is based on data from the Township's Assessing database. It should be noted that some of the prior plans have stated different figures, but staff is using the Assessing information for the purpose of this staff report.

The residential density (dwelling units per acre) is calculated by using the total number of residential dwelling units, divided by the total acres of the development, with some exceptions as noted in the Summary Chart. Deviations in the data are shown in bold in the chart. Footnotes provide additional information as applicable.

A separate comparison chart is also provided as an attachment to this memorandum which provides detailed density calculations.

Summary Chart

| Application # / Plan Date | Commercial Space SQ. FT. | Number of Residential Units | Residential Density DU/AC (Overall Density) |
|--|---|----------------------------------|--|
| 2007 Pattern Book SP #383 and SP #386 Project area: 148.7 acres | 288,059 Sq. Ft. 280,103 Sq. Ft. | 545 units* 328 units | 3.66 DU/AC 2.21 DU/AC using 328 units |
| 2016 Preliminary Plan SP PD #535-P Project area: 108.7 acres | 100,409 Sq. Ft. 140,715 Sq. Ft. | 499 units | 4.59 DU/AC 5.60 DU/AC** |
| Concept Plans dated July 25, 2019 SP PD #535-P Project area: 148.7 acres | 133,950 Sq. Ft. 133,950 Sq. Ft. | 595 units 529 units*** | 4.00 DU/AC 3.56 DU/AC using 529 units |
| Concept Plans dated February 23, 2021 (SP #21-006) Project area: 108.7 acres | 133,950 Sq. Ft. | 417 units | 3.84 DU/AC |
| Preliminary Plans dated April 15, 2021 (SP #20-012) Project area: 108.7 acres | 133,950 Sq. Ft. | 417 units | 3.84 DU/AC 3.54 DU/AC (Pg. 2 of 2021 Pattern Book) |

**Number of units based on information presented on 2007 site plans from SP#383 and SP #386 (prepared by Beckett and Raedar)*

***Data is based on the March 29, 2016 staff memorandum was prepared by McKenna Associates and site plans prepared by Beckett and Raedar, dated March 2, 2016. The residential density on Sheet 02 is stated as 4.98 dwelling units per acre, using 444 residential units and 89.17 residential acres, versus using the entire planned development area of 108.7 acres. The staff report states an additional 55 units are possible in commercial areas, for a total of 499 units, but the plan does not clearly show where these units would be placed. The overall density in the staff report is stated as 5.60 DU/AC, however the acreage used for this calculation is not listed. If using 499 units and 89.17 acres, the resultant density is 5.60 DU/AC.*

**** The applicant is stating the number of units as 529 units, however the July 25, 2019 Regulating Plan had proposed 66 additional units in the Mixed Use District, although those individual units were not shown on the development plan. If these are added, the total is 595 residential units.*

Planned Development Procedure

Section 3.1.18 of the Township’s Zoning Ordinance provides standards and approval procedures for a Planned Development (PD). Approval of a Planned Development is a three-step process. A Concept Plan, Preliminary Plan, and Final Plan are all reviewed by the Planning Commission and the Township Board, with the Planning Commission making a recommendation and the Township Board having final approval at each step. The process usually requires a rezoning from the existing zoning district to the Planned Development (PD) zoning district. As part of the rezoning, a public hearing is held before the Planning

Commission consistent with the Michigan Zoning Enabling Act; this public hearing is held at the same meeting during which the Planning Commission reviews and makes a recommendation on the Preliminary Plan. Given the requirements for publishing a notice for the planned development, the public hearing has been scheduled for the June 10, 2021 Planning Commission meeting. Approval of the Final Plan by the Township Board usually constitutes a rezoning of the subject property to PD.

For all intents and purposes, the Preliminary Plan step is essentially the same as a preliminary site plan review for a conventional project in the Township. All the information and details required for a preliminary site plan approval must be provided for the Preliminary PD review and approval. Final PD review will involve detailed plans for those phases for which construction is intended to begin immediately; review of the Planned Development Agreement, and other written documents as applicable.

In this case the Preliminary Plan is in the form of a Pattern Book for the planned development and is not the final site plan. The Pattern Book serves as a guide for the planned development that includes the Regulation Plan for the four (4) development districts, listing the proposed overall residential density, maximum number of residential units in each district, and commercial space square footage for each commercial/mixed use areas. Site regulations, architectural guidelines, landscape regulations, and sign regulations (monument signs only) for the planned development are also provided in the Pattern Book.

A site plan application with detailed site plans will be required for each component of the project prior to the construction phase, such as commercial buildings/parking lots, mixed use buildings, and multiple-family buildings. The site plan application will be reviewed by the Planning Commission for compliance with the Regulation Plan as well as the guidelines, site regulations, and design details outlined in the Pattern Book, and all applicable regulations from the Zoning Ordinance. Land use permits will be required for single-family type structures and will be reviewed by Planning staff.

Overview of the Preliminary Plan and Proposed Uses

Overview of Development Districts

The comments provided in this review are based on the Pattern Book submitted to the Township on April 15, 2021. The Pattern Book provides the development plan for Newberry Place, an approximate 108.7 acre planned development at the eastern end of the Township.

It should be noted that the overall site plans, individual plans, landscape illustrations, sign drawings, and other illustrations in the Pattern Book are not drawn to scale, as they are meant to represent conceptual layouts/designs of Newberry Place Planned Development. Property lines for the North Parcel and South Parcel are not shown on the Regulation Plan, Site Landscape Plan, or Street Type Guidelines plan. Right-of-way lines are not shown on the plans, including the Lot Regulation plan drawings for each development category. As a result, the stated dimensions and setbacks on those drawings cannot be confirmed.

There are four (4) development districts listed on the Regulating Plan in the Pattern Book (page 2): Single Family Residential District; Single Family Detached Only Residential District; Mixed Use District; and Commercial District. The Regulating Plan includes charts that summarize the number of residential units in each district and the commercial square footage for the North and South parcels. A total of 417 residential units is proposed and total commercial space is 133,950 square feet. A variety of housing options in the residential and mixed use districts are provided in the Pattern Book, allowing for flexibility in the overall development plan; however, a total of 417 residential units is proposed as the maximum number of residential units. Similarly, the total commercial square footage is stated as 133,950 square feet, but this could occur using a variety of building designs throughout the development.

Residential density (dwelling units per acre) is calculated by using the total number of residential dwelling units, divided by the total acres of the development. Using the information provided in the Pattern Book, the overall residential density is 3.84 dwelling units per acre (417 dwelling units ÷ 108.7 acres = 3.84 DU/AC). The Regulating Plan (Page 2), in the Residential Unit Chart, states the density as 3.54 dwelling units per acre; however, staff is unsure how this was calculated. Clarification on this topic should be provided by the applicant. Additional comments on density are discussed in this memorandum.

Overview of the Planned Development

North Parcel

On the North Parcel, the Single Family Detached Only Residential District is located along the north and east boundaries of the PD, for single family, detached homes, which is compatible with the existing single family homes along those borders. Interior to the site is the Single Family Residential District. A park area is shown within this residential area. A sidewalk is shown at the northwest corner of the North Parcel that provides a pedestrian connection from the PD's residential area to the Township's Heritage Park.

The Commercial District occupies the southeast corner of the North Parcel, at the intersection of Highland Road and Fenton Road. The Mixed Use District is west of the Commercial District and has frontage along Highland Road. The main access to the North Parcel is provided via a boulevard entrance drive from Highland Road. A second access point is provided from Fenton Road.

South Parcel

The South Parcel has the following districts: Single Family Residential; Mixed Use; and Commercial. The Commercial District occupies the southwest corner of Highland Road and Pleasant Valley Road. Just south of the Commercial District is the proposed location for the fire station, with frontage along Pleasant Valley Road. Access points for the South Parcel are provided from Highland Road, with a boulevard entrance, and Pleasant Valley Road. The Single Family Residential District is situated south of the Commercial and Mixed Use Districts. Park and recreation areas are provided within the Single Family Residential District.

Proposed Development Districts and Uses

Following, is a discussion of the four (4) development districts and Permitted Principal Uses as outlined in the Pattern Book.

Single Family Residential District

This district allows for single family detached dwellings; attached style condominium up to five (5) units per building; duplex motor court condominiums; and 4 to 6-plex motor court condominiums. Consideration should be given to the possibility that this district could be comprised of a mix of the allowed residential uses or be entirely comprised of one (1) of the permitted residential uses. The regulating plan outlines that a maximum of 90 residential units would be permitted, within this district, on the north parcel; and 242 units would be permitted, within this district, on the south parcel. In total, 332 units would be permitted in the Single Family district on both the north and south parcel.

Single Family Detached Only Residential District

This district consists of nineteen (19) lots along the northern boundary of the North Parcel, for the construction of detached, single family houses, only. The number of units is capped at nineteen (19) units. The plans do not state the acreage of this district, or the proposed density.

Mixed Use District

As background information, the Mixed Use District allows for a diverse mix of housing options and uses as listed in the Pattern Book: commercial/office/retail uses; live-work units; single family detached dwellings; motor court condominiums (duplex; 4, or 6-plex condominiums); and multiple family (up to 14 units per building). Per the Regulating Plan, up to sixty-six (66) residential units could be built within the Mixed Use District. The Regulating Plan does not distinguish how many units on the north parcel and how many units on the south parcel. So, theoretically, all sixty-six (66) units could be developed on either the north or the south parcel.

The Regulating Plan depicts a potential layout of how this district could be developed. However, the applicant could elect to modify to a different layout. Nonetheless, in the plan shown, it was anticipated that the residential units would be located above the commercial buildings. In that plan, there is a large area (on the south parcel) that is left open. It was generally discussed that, in the event residential units are constructed above the commercial buildings that additional off-street parking may be needed and this open area could be utilized for additional parking. Previously, on other submittals, the applicant had labeled this area as “Park/Future Parking”, to be utilized for additional parking as needed or serve as a park if not used for parking. The current Pattern Book does not provide information on the intended uses for this area. The Open Space/Usable Open Space Plan shows a parking lot in this area with a portion designated as Usable Open Space. Clarification on this item should be provided by the applicant.

It was also discussed that if residential units were not constructed over the commercial buildings, the applicant could use this open area for construction of residential only buildings. These could consist of attached style condominiums (up to 5 units only); duplex quad motor court homes, quad motor court 4-6 plex; and potentially apartments. The concept plan showed building elevations of a Tri-Unit building, and Quin Unit building, and a ten (10) unit building. The preliminary plan is now showing a fourteen (14) unit building as well as a detached garage. These were not shown on the conceptual plans. No building elevations have been shown to depict the fourteen (14) unit building or the detached garage. A plan that depicts how 66 units could be developed on the property, where the units are not above the commercial buildings, has not been provided.

The Regulating Plan identifies a maximum of 45,213 square feet of commercial development on the north parcel and 39,861 square feet of commercial development on the south parcel, for a total of 85,074 square feet of commercial development.

Specific Permitted Principal uses are not listed for commercial, retail, office, or live/work categories. There is a statement that commercial use buildings shall conform to the uses permitted in the Township General Commercial (GC) Zoning District. It is unclear if that would permit any of the Special Land Uses listed in the GC Zoning District regulations.

Consideration should be given to the possibility that this district could be comprised of a mix of the allowed uses or be entirely comprised of one (1) of the permitted uses. However, the applicant is claiming that because the mixed use district is limited to a maximum of sixty-six (66) residential units; and there are 435 REU's allocated to this entire development, the applicant would need to develop the commercial as well as residential units to re-coup costs associated with the REU's. Although there are limitations on the number of residential units and commercial development, there is tremendous flexibility in this district and the potential layout of this district does create unique challenges. There is the potential that this developer or a future developer could come back to the Township to request an amendment in this district.

The Regulating Plan for all other districts depicts a potential design at the maximum number of residential units and/or commercial development in each district. However, the Regulating Plan does not provide this for the Mixed Use District. Consideration should be given toward the Regulating Plan showing what all the commercial, 85,074 square feet, and sixty-six (66) residential units would look like in the Mixed Use District. There are two (2) variations of residential units that are being proposed. One of the variations would include residential units above the commercial buildings. The other variation would include no residential units above the commercial buildings. In this scenario, the developer could construct sixty-six (66) residential units. Consideration should be given to an example of what this would look like. Is this possible with any commercial buildings, or would this reduce the amount of commercial buildings in the Mixed Use District?

Commercial District

Specific Permitted Principal uses are not listed for Commercial District. There is a statement that commercial use buildings shall conform to the uses permitted in the Township General Commercial (GC) Zoning District. It is unclear if that would permit any of the Special Land Uses listed in the GC Zoning District regulations. Consideration should be given to the possibility that this district could be comprised of a mix of the allowed uses or be entirely comprised of one (1) of the permitted uses.

The Regulating Plan depicts 4,836 square feet of commercial could be developed on the north parcel; and 44,040 square feet of commercial could be developed on the south parcel, for a total of 48,876 square feet of commercial development.

A previous pattern book from 2016 showed building elevations of wall features and building elevations of some of the potential commercial buildings. These elevations are discussed elsewhere in this staff memorandum and copies of those have been attached.

The north parcel generally depicts a single building, that resembles a gas station convenience store (automotive fueling station). There have been comments at the conceptual hearing about the location of a gas station so close to existing single family residential homes, located along Fenton Road. Please keep in mind that any of the permitted uses in the GC (General Commercial) district could be permitted in this location, up to a maximum size of 4,836 square feet in area.

Other General Comments on the Pattern Book

Regulating Plan (Page 2)

Under the list entitled “General Use Type”, the four (4) development districts are listed, with a designated color. The 8-foot-wide bituminous Bike/Safety Path (mint green color) is shown on the north and south sides of Highland Road and the west side of Fenton Road and Pleasant Valley Road. It should be noted that a 5-foot-wide concrete sidewalk is to be located on the south side of Highland Road and not the 8-foot-wide Bike/Safety Path. The page should be updated accordingly and should include the 5-foot-wide concrete sidewalk to the list, with a specific color designation.

Single Family Lot Regulation (Page 5)

A plan view drawing of the lot layout for a single family attached townhome condominium building (up to 5 units) should be provided in the Pattern Book (see Page 5, Single Family Lot Regulation). The plan should show the lot boundaries, building footprint, and setbacks similar to drawings in the Pattern Book for other types of residential buildings.

Street Type Guidelines (Page 12)

The following revisions are required for the Legend and Map:

- 66' Entrance Street ROW is listed in the Legend but is not shown on the plan (olive green color)
- 110' Boulevard ROW should be added to the plan/legend with a specific color (located on south side of Highland Road)
- 100' Boulevard ROW should be added to the plan/legend with a specific color (located on north side of Highland Road)
- 5' Concrete Sidewalk should be shown on the south side of Highland Road, in place of the 8' Bituminous Bike/Safety Path, with a specific color on the plan/legend, to match that same color designation on Page 2 (Regulating Plan).

The Landscape Regulations and Landscape Illustrative drawings, provided on Pages 37-43 in the Pattern Book, refer to the Street Types in the development, and thus the same street categories should be provided on Page 12.

Eligibility Criteria (Section 3.1.18.B.)

To be eligible for PD approval, the applicant must demonstrate that the criteria in Section 3.1.18.B. will be met.

1. **Recognizable Benefits.** *The planned development shall result in a recognizable and substantial benefit to the ultimate uses of the project and to the community and shall result in a higher quality of development than could be achieved under conventional zoning.*

The applicant has provided a letter, dated April 15, 2021, that addresses this topic.

2. **Minimum Size.** *Planned Developments must be a minimum of 20 acres of contiguous land.*

The proposed project is approximately 108.7 acres in size, with 20 acres of contiguous land and meets the criteria.

3. **Use of Public Services.** *The proposed type and density of use shall not result in an unreasonable increase in the use of public services, facilities and utilities, and shall not place an unreasonable burden upon the subject site, surrounding land, property owners and occupants, or the natural environment.*

Traffic Generation

The proposed development will utilize vehicular access, primarily via Highland Road, which is an existing public roadway under the jurisdiction of the Michigan Department of Transportation (MDOT). Secondary access points to the development are from Fenton Road (North Parcel) and Pleasant Valley Road (South Parcel), which are under the jurisdiction of the Livingston County Road Commission (LCRC).

The Traffic Impact Study (TIS) dated December 8, 2015, was provided as part of SP PD Application #535-P and was reviewed as part of that application. Several improvements on Highland Road were required, including signalization at the intersection of Highland Road and Pleasant Valley/Fenton Road; reconfiguration/addition of cross-over turn lanes on Highland Road; and improvements to Pleasant Valley/Fenton Road.

The applicant provided a copy of a letter from MDOT, dated February 14, 2017, which summarizes MDOT's comment on the final version of the TIS dated January 11, 2017. Per the applicant's comments at the Planning Commission meeting on July 11, 2019, the plans have been under review by MDOT since 2018; however, a final report from MDOT has not been submitted.

The LCRC provided a review letter dated February 15, 2017, which was in response to an updated traffic impact study dated January 11, 2017. More recent communications from the LCRC, dated April 10, 2019, were provided and were based on plans dated April 2, 2019. Based on those plans, the LCRC stated the location of each proposed private road approach off Pleasant Valley Road ((2 approaches) met the sight distance and offset requirements. Additionally, the LCRC stated the proposed commercial approach off Pleasant Valley Road and commercial approach off Fenton Road met the LCRC sight distance and offset requirements.

It should be noted that the last time this entire development was presented to the Planning Commission was in 2016. At that time, the property was similar in size to the current proposal, which is 108.7 acres in area. However, after 2016, the applicant had modified the plans to incorporate an additional 40-acre parcel, located immediately to the west. This parcel was eliminated from those plans in 2021. As a result, staff is not sure if some of the letters provided were in reference to a different plan that contained the 40-acre portion.

Public Safety

Per the discussion during the review of SP PS #535-P, a need for a new fire station in this area of the Township was identified. The current set of plans shows a designated area for a fire station on the South Parcel, adjacent to Pleasant Valley Road.

Stormwater and Drainage Systems

The Livingston County Drain Commissioner's office (LCDC) has been involved with the project since 2016. A review letter from the LCDC, dated June 6, 2019, outlines their concerns based on the plans submitted at that time. Per the applicant, the comments remain valid for the current set of plans for the planned development. Based on the LCDC letter, wetland areas on the south parcel are intended to be used as part of the overall stormwater detention/management plan. The applicant should contact the Michigan Department of Environment, Great Lakes, and Energy (EGLE) regarding the wetland areas on the site and what approvals and permits may be required.

Water/Sewer

This development will require municipal water and sewer. The Township is currently exploring extension of municipal water lines down M-59 that could provide water service to this property, on both sides of Highland Road. The Public Works Director has provided a review letter dated June 2, 2021. In the event that municipal water is not available to serve this site, this development would require fairly extensive changes.

In a letter dated April 15, 2021, the applicant has indicated there are 435 REU's for sanitary sewer that will be utilized as part of this project.

- 4. Compatibility with Comprehensive Plan.** *The proposed development shall not have an adverse impact upon the Comprehensive Plan for the Township. Notwithstanding this requirement, the Township may approve a Planned Development proposal that includes uses which are not called for on the Future Land Use Map, provided that the Planning Commission and Township Board determine that such a deviation from the Future Land Use Map is justified in light of the current planning and development objectives of the Township.*

The 2015 Comprehensive Plan Amendment designated the subject 108 acres of land as a Special Planning Area (SPA). The intention of the Planning Commission is to work closely with the landowners in this area to establish the terms of an agreement for a mixed-use Planned Development. Further, the Planning Commission has determined the PD can be created with an environment that encourages pedestrian linkage between activity nodes and resource features. Specific principles were agreed upon for the Special Planning Area in the 2015 Comprehensive Plan Amendment, as listed below.

- a. Development within the Special Planning Area shall provide for a variety of housing forms (for example, single family, townhouses, condominium, apartments, and senior housing), along with retail, office, recreation, and entertainment space. *The applicant proposes detached single family homes, attached single family townhouses, multiple family housing, mixed-use, commercial/office uses, and park/recreation areas.*
- b. Development within the Special Planning Area shall provide for public facilities and other neighborhood amenities. *Proposed facilities public include the site for a fire station, residential parks, urban plazas, and pocket parks.*
- c. Development within the Special Planning Area shall provide pedestrian and vehicular links between internal land uses and adjacent property not necessarily located within the SPA. *The North parcel is self-contained without connections to adjacent sites except for a pedestrian connection to Heritage Park and the 8-foot-wide bituminous Bike/Safety Path along the frontage(s) of Highland Road and Fenton Road. The South Parcel is also self-contained and does not connect to adjacent sites via streets. An 8-foot-wide bituminous Bike/Safety Path is shown along the frontage(s) of Highland Road and Fenton Road. The Regulation Plan shows internal sidewalks throughout the PD that connect to the different development districts and recreation/park areas on the North and South parcels. Crosswalks are provided internally.*
- d. Development within the Special Planning Area shall comply with the Township's goal of creating walkable pathways to the Township settlement area and other public and private facilities. *The PD is connected internally via an extensive system of sidewalks. A 5-foot-wide concrete sidewalk is to be placed shown along the frontage of Highland Road on the South Parcel, however the plan shows an 8-foot-wide bituminous Bike/Safety Path, on several sheets in the Pattern Book and should be revised. The 8-foot-wide bituminous Bicycle/Safety Path is shown along the north side of Highland Road, west side of Fenton Road and Pleasant Valley Road.*
- e. New development shall be designed to harmoniously co-exist with pre-existing historical and natural features within the Township. *Detailed plans were not provided showing existing conditions /natural features and proposed removal limits for existing vegetation or impacts to wetland areas. It is impossible to evaluate compliance with this standard at this time. Detailed site plans will be required as part of the site plan application for each phase of development.*
- f. New development proposed for the Special Planning Area must include landscape, streetscape, traffic and architectural solutions that are superior in design and visually enhance the community. Design that respects the existing historic features is essential. *The Pattern Book provides the framework for the PD regarding development district, circulation, site amenities, and design regulations for landscaping and architecture. The intent is to provide a cohesive mixed-use, walkable planned development based on the design guidelines in the Pattern Book. Conceptual illustrations are provided for various residential and commercial buildings; however, conceptual architectural drawings for a car wash, automobile fueling and convenience station, and automobile fuel island canopies were not provided.*

Building material options are outlined as well as specifics on site features such as fencing, walls, and accessory buildings. Conceptual landscape plans are provided for parks, open spaces, boulevard entrances, and residential streets. Landscaping will meet or exceed requirements outlined in the Township's current Zoning Ordinance, unless otherwise described in the Pattern Book.

- 5. Unified Control.** *The proposed development shall be under single ownership or control such that there is a single person or entity having responsibility for completing the project, or assuring completion of the project, in conformity with the Ordinance.*

The applicant provided a letter, dated April 15, 2021 that responds to this item. The four property owners associated with Newberry Place PD have signed a document dated October 21, 2020, stating they are in agreement with the request to proceed with Preliminary PD approval.

6. Fiscal Impacts.

The applicant has provided a response to this topic in the letter dated April 15, 2021.

Planned Development Design Standards (Section 3.1.18.C.)

This section outlines the design standards for a planned development. Additional standards will be discussed from applicable sections of the Zoning Ordinance.

- 1. Permitted Uses.** *The predominant use on the site shall be consistent with the uses specified for the parcel on the Township's Comprehensive Plan for Future Land Uses.*

The 2015 Future Land Use Map (FLUM) designates each of the four (4) parcels as Special Planning Area. Currently all four (4) parcels are zoned CA (Conservation Agricultural). The uses proposed for Newberry Place PD generally align with those stated for the Special Planning Area, in the 2015 Future Land Use Plan. In the Pattern Book, Principal Permitted Uses are listed for the Mixed Use District and the Commercial Use District, noting that commercial use buildings in those districts shall conform to the uses permitted by the Township General Commercial Zoning District. The assumption is that the reference is to the Permitted Principal land uses listed in the GC-General Commercial zoning district.

Special land uses are not addressed in the Pattern Book and clarification is required regarding this topic. It is unusual to provide for special land uses within a planned development. Typically, a special land use requires a public hearing at the Planning Commission, who makes a recommendation, and the final decision is made by the Township Board. Specific criteria are typically associated with each special land use as outlined in the Zoning Ordinance. The approval process for a special land use should be clarified in the Pattern Book, and possibly a list of permitted special land uses should be provided in the Pattern Book. For instance, in GC, an automobile fueling station, car wash, or restaurant with drive-in or drive-through service are considered special land uses. The other option is to consider all uses listed in GC as Permitted Principal uses and eliminate the special land use category.

- 2. Residential Density.** *Residential density in a planned development shall be consistent with the density designation within the Township's Comprehensive Plan.*

As noted previously, the project area, comprised of four (4) parcels, is designated as Special Planning Area in the 2015 Comprehensive Plan Amendment. The intent of the Special Planning Area is to allow for flexibility with respect to residential density, and a specific density is not provided. It should be noted that in the 2011 Comprehensive Plan Amendment, the Planning Commission determined the Special

Planning Area should be planned for a base density of 3 to 4 dwellings per acre. Section 3.1.18.C.iv., of the Zoning Ordinance permits the Planning Commission to recommend up to a forty (40%) percent increase in dwellings on a site in recognition of outstanding attributes as listed in this section. The Township Board in its sole discretion shall have the ability to approve such density increase up to forty (40%) percent subsequent to an affirmative recommendation from the Planning Commission. This additional “bonus” density dwelling units can be awarded to the development if certain desirable design features are offered by the developer that significantly enhance the appearance and function of the site. The “bonus” density will only be awarded at the discretion of the Township in accordance with established development regulations of the Township and the State of Michigan.

The proposed overall residential density (Dwelling Unit/Acre) for the entire project area is 3.84 dwelling units per acre (417 dwelling units ÷ 108.7 acres = 3.84 DU/AC).

Based on the Zoning Ordinance, 4 dwelling units per acre over 108.7 acres would permit a maximum of 434.8 (or 435 dwelling units). This does not include any bonus density provision. The bonus density provision would permit an additional 174 dwelling units, or a maximum 609 dwelling units.

3. Design Details. *The applicant shall prepare a detailed description of design details to be implemented in the proposed planned development, to be presented in a Pattern Book.*

The design details for the planned development are provided in the Pattern Book, such as the Regulation Plan, site regulations, architectural guidelines, landscape regulations, and sign regulations. The Pattern Book is meant to be the guide for the overall character of the development yet allow for flexibility. The Regulation Plan establishes the development districts and overall residential density, as well as the maximum square footage dedicated for commercial development. The Regulation Plan however is conceptual in nature regarding the final layout of the planned development. Each phase of the development will be reviewed for compliance with the regulations outlined in the Pattern Book or the Township Zoning Ordinance, as applicable.

4. Minimum Design Detail Requirements. *The following minimum standards shall apply to a planned development unless a different standard is approved in the design details submitted and approved in accordance with Section 3.1.18.C.vi. (Minimum Design Detail Requirements) of the Zoning Ordinance. If a Pattern Book is created and approved, the design details outlined in the Pattern Book shall replace the specifications of this subsection. If such Pattern Book fails to address a minimum design detail requirement, the specification indicated in this subsection shall prevail.*

5. Minimum Yard Requirements. The site plans in the Pattern Book are not drawn to scale thus the stated dimensions cannot be verified. In some cases, the numbers are illegible or are not stated on the drawing. Additionally, the stated setbacks in some cases are measured from the edge of a sidewalk and not a property line of right-of way line. As a result, the analysis is somewhat limited by those facts.

The table below summarizes the setback requirements per Section 3.1.18.C.vi.a. as compared to the proposed standards in the Pattern Book. Those items that do not meet the minimum Zoning Ordinance requirements are identified in italics.

| Yard Location | Minimum PD Standard | Proposed Standard in Pattern Book |
|---|---------------------|--|
| Along perimeter adjacent to public road (M-59 and Pleasant Valley/Fenton Rd.) | 50 ft. Residential | 80 ft. from ROW along M-59 OR 50 ft. from ROW along Pleasant Valley/Fenton - Mixed Use District Lot Regulations |
| | 75 ft. Non-Res. | 80 ft. from ROW along M-59 OR <i>50 ft. from ROW along Pleasant Valley/Fenton</i> – Commercial District |
| Along perimeter, but not adjacent to a road | 40 ft. | See pg. 5, 7, and 8 of the Pattern Book for proposed setbacks in various districts |
| Along an internal road | 40 ft. Residential | <i>15 ft.-Single Family Detached and Single Family Attached*</i> (10.5 ft. encroachment into front yard setback allowed for front porch + porch steps) |
| | 50 ft. Non-Res. | <i>0 ft.- Mixed Use District</i> <i>15 ft.-Mixed Use District for Single Family Detached & Attached Style Condominiums*</i> <i>30 ft. -Mixed Use District for Multiple Family (up to 14 units per bldg.)**</i> |
| Between parking lot & property line & adjacent to a road | 20 ft. Residential | Standards not provided |
| | 40 ft. Non-Res. | Standards not provided |
| Between parking lot & property line but not adjacent to road | 50 ft. Residential | Standards not provided |
| | 20 ft. Non-Res. | Standards not provided |

*Setback as measured to sidewalk, not to ROW or property line

**Setback as measured from front of building to back or curb

- 6. Required Distance Between Buildings.** *Distances within a planned development shall comply with the following spacing unless otherwise specified by the PD agreement.* The table below summarizes the minimum distance requirements between buildings per Section 3.1.18.C.vi.a. as compared to the proposed standards in the Pattern Book. Those items that do not meet the minimum Zoning Ordinance requirements are identified in italics.

| Category | Minimum PD Standard – Distance between bldgs. | Proposed Standard |
|---|--|---|
| Single Family Detached Structure | 30 ft. from any other detached single family structure; min. 15 ft. side yard on both sides Rear yard setback-TBD as part of PD | <i>5 ft. side yard (min. 10 ft. between bldgs.)</i> 15 ft. rear yard 10 ft. Alley setback |
| Residential bldgs. With more than 1 unit (attached dwellings) To use standards in Sec. 3.1.7 (MDR-Med. Density Res.) | 10 ft. side yard 25 ft. rear yard | <u>Attached Townhome</u> (up to 5 units) 10 ft. side yard (20 ft. min. between bldgs.) <i>15 ft. rear yard</i> <i>10 ft. Alley setback</i> <u>Duplex Motor Court Condo</u> <i>7.5 ft. side yard (min. 15 ft. between bldgs.)</i> <i>15 ft. rear yard</i> <u>4-6 Plex Motor Court Condo</u> <i>5 ft. side yard (min. 10 ft. between bldgs.)</i> <i>10 ft. rear yard</i> <u>Multiple Family (up to 14 units)</u> 20 ft. between bldgs. (min. distance) |
| Distance between any residential bldg. & non-residential building | 100 ft. min. | <i>50 ft.</i> |

7. Building Height. *No building in a planned development shall be greater than thirty-five (35) feet in height.*

As a note of information, building height is defined in the Zoning Ordinance as the vertical distance from the established grade to the average height between the eave and ridge for a hip roof.

The building height in the Pattern Book is listed as three (3) stories or thirty-five feet, whichever is less. The height is measured from the eave of the roof. The building height standard applies to residential buildings (single family, detached; townhouse condominium/single family attached; and multiple family) and commercial buildings, including mixed use buildings. Scaled building elevations were not provided.

The Pattern Book does not include concept elevation drawings for an automotive fueling/gas station canopy. In the 2016 PD Plan submittal, the gas station canopy height was shown as 43 feet, as measured to the top of the architectural feature on the canopy.

8. Parking and Loading. *Planned developments shall comply with the parking and loading requirements specified in Section 5.8. and Section 5.9 of the Zoning Ordinance.*

The Pattern Book states parking and loading requirements will comply with the most current Township Zoning Ordinance. Parking and loading will be reviewed with each site plan application submittal.

9. Landscaping. *Landscaping requirements are provided in Section 3.1.18.C.vi.e.* These are considered minimum design standards for a planned development. The Pattern Book provides a conceptual landscape program with regulations and with schematic drawings on pages 9-10 and 37-46. Following is a discussion of the proposed landscape regulations by topic.

General Landscape Regulations using Hartland Township's Zoning Ordinance

The Pattern Book states all landscaping is to meet or exceed Hartland Township's current zoning ordinance for landscape requirements unless described otherwise in the Pattern Book. The current Township Zoning Ordinance has site landscaping requirements for six (6) general areas: greenbelt; foundation; parking lot interior and perimeter; retention/detention facilities; monument signs; and screening and buffering. These standards will be applied to Newberry Place PD except where deviations occur as outlined in the Pattern Book.

The plans in the Pattern Book are intended to be conceptual and are not drawn to scale. The property/boundary lines for the PD are not shown, nor is the right-of-way along Highland Road and Pleasant Valley/Fenton Road. Sidewalks and Bike/Safety paths along Highland Road and Pleasant Valley/Fenton Road are other elements to be taken into consideration. Staff has concerns there will not be sufficient space set aside for the greenbelt areas along Highland Road and Pleasant Valley/Fenton Road, to meet the Township Zoning Ordinance standards. Spatial limits may also be an issue for providing the required screening of parking lots facing Highland Road and Pleasant Valley/Fenton Road. If sufficient space cannot be provided for these areas, landscape regulations and landscape plans should be included in the Pattern Book. The applicant should address this issue at this time by providing a scaled drawing of a typical greenbelt areas and parking areas along Highland Road.

Open Space (Page 10-11)

Pages 10-11 outline the Open Space Guidelines. Illustrative drawings are included for an Urban Plaza Landscape and the Central Park in Residential District, but not for a Pocket Park. The current Zoning Ordinance does not have specific landscape standards for parks or urban plazas thus there are no guidelines to follow. In this case specific landscape guidelines should be added to the Pattern Book for these open space areas. Additional comments concerning Open Space are provided in the next section (entitled 11. Open Space)

Private Right-of-Way Landscaping (Page 37)

Under the section entitled "Public Realm", four (4) categories of private ROW are listed. Two (2) categories should be added, the 16-foot Alley ROW and the 66-foot Entrance Street ROW. The categories listed on this page (Page 37) should match the categories on Page 12, Street Type Guidelines. As noted previously, Page 12 needs to be revised as well to provide accurate information. Schematic landscape plans associated with the 16-foot Alley ROW should be added to the Pattern Book. In particular, canopy trees should be shown on the plan, with tree spacing stated. Also, schematic landscape plans for the Newberry Street ROW (60' Wide) should be added to the Pattern Book. This plan was provided in previous versions of the Pattern Book.

Site Landscape Plan (Pages 38-39)

These two pages show landscaping and site features in the planned development, on a broad scale. Page 38 (North Parcel) has a legend for the categories (color-coded) however, the following categories are not represented the plans (on page 38-39): Greenbelt Landscape Buffers; Parking Buffer/Screening; and Tri Plex. Staff is unsure what Tri-Plex represents.

These pages are difficult to read. Plant symbols are shown on the plans and a plant list is provided. Due to the scale of the plans, one cannot distinguish the plant types, so the plant list seems irrelevant, unless the intention is to use this plant list in place of the Plant Material List in the Zoning Ordinance. These pages also show Open Space and Usable Open Space for the PD. Some areas designated as Open Space are actually outside the property boundaries of Newberry Place Planned Development and could not be counted as open space (on the North Parcel).

Schematic Landscape Plans for streets (Pages 40-44)

These drawings essentially the same as were presented in the Pattern Book under SP #383-P and SP #386-P), dated May 25, 2007. The overall design of the planned development has changed since 2007, thus there is some question as to how relevant the schematic landscape plans are. Nonetheless, the drawings provide some basic design standards.

Schematic landscape plans are found in this section for three (3) of the four (4) categories listed on Page 37 (Private Right-of-Way Landscaping):

- 110' Boulevard Landscape
- 100' Boulevard Landscape
- Residential Street Landscape

As noted earlier, schematic landscape plans for the 16-foot Alley ROW and Newberry Street ROW (60' wide) should be added.

A schematic landscape plan is provided for the 66' Entrance Street (Page 42), however, this street category is not listed on Page 37 (Private ROW landscaping). It is listed on Page 12 but is not shown on the site plan on Page 12.

The schematic landscape plan for each street category shows planting cut-out areas in the sidewalk that is located between the street and a building. Two (2) canopy trees are to be planted in each cut-out area per the stated regulations. Additional standards should be provided for each street type, stating the minimum/maximum dimensions for the planting cut-out areas; or state the canopy/street trees shall be spaced no greater than twenty-five (25) feet apart. This is to ensure that a sufficient number of canopy/street trees will be planted along the street in each street category. Page 43 states one (1) deciduous street tree is required per fifty (50) linear feet of road frontage. Staff would recommend one (1) street tree per thirty-five (35) linear feet of road frontage (maximum spacing).

Greenbelt (Page 46)

This is an illustrative plan for greenbelt plantings along Highland Road and entrance signs at a boulevard entrance, although the exact location is not stated. The graphics and plant symbols are difficult to read. The right-of way for Highland Road (M-59) is not shown but it appears the greenbelt plantings could be located within the right-of-way, which would require approval from MDOT. This harkens back to the previous comment about the applicant to provide a scaled drawing of a typical greenbelt area where abutting a parking lot, along Highland Road. The plan should show the street, street ROW, sidewalk along Highland Road, greenbelt, parking lot, and landscape area adjacent to the parking lot, for plantings to screen the parking lot. This is to assure sufficient space is dedicated for those areas to meet the Zoning Ordinance requirements.

Other Comments related to Walls and Fences

Wall and fence guidelines are discussed on pages 32-33, for residential and commercial districts. Following are comments regarding fences:

- Per the Township Zoning Ordinance, no fence shall be permitted closer than the front lot line than the front wall of the principal building, in residential districts. Per the Wall & Fence standards on Page 32, fences may not be located in front or corner side yards unless approved by the Architectural Review Board, for single family districts. If approved by the Architectural Review Board, this would be a deviation from the current Zoning Ordinance.
- Fence height is limited to four (4) feet for obscuring fences and walls per the Pattern Book (page 32). In certain applications where screening is required, as between uses of differing intensity, would a four (4) foot fence or wall be sufficient for screening?
- Page 33, Commercial Areas, item D (Entrances to Newberry Place), states regulations for entranceway structures to Newberry Place (gates, walls, or columns). The stated setback for such a structure is one (1) foot from the right-of-way of M-59 or Pleasant Valley/Fenton Road. The current Zoning Ordinance states a minimum setback of ten (10) feet from the street right-of-way. Additionally, a sign shall be outside the clear vision zone as defined in Section 5.1 of the Zoning Ordinance. Consideration should be given to adding these standards to the Pattern Book or state that standards for walls and fences shall default to the Zoning Ordinance.
- Page 45, Greenbelt, item 1.c., states for any greenbelt screen less than 20 feet in depth shall include an obscuring fence/wall with a height of six (6) feet. Per the Zoning Ordinance, fences and walls are not listed as a feature to be permitted in the greenbelt. A 6-foot-high wall along Highland Road may not be desirable.

Other Comments related to Landscaping

- Page 9 – the dimensions of each parking island should comply with the Zoning Ordinance standards (Section 5.11) and adequate space should be provided to accommodate a canopy tree. Clarification is requested regarding the white-toned areas on the plan (tip of each parking island).
- Page 13 – an 8-foot-wide parking aisle is required for a parallel parking space. The plan states 6-foot-wide parking aisle for the 100' and 110' boulevard streets.
- Page 14 –three (3) areas are labeled as 5 feet in width however the areas are drawn at three different widths. A scaled plan should be provided, or the street section drawings should be revised to consistently show a 5-foot-wide area.

10. Open Space. *Open space shall be provided to complement and accentuate the high-quality design of the proposed planned development. At a minimum, the planned development shall provide open space consistent with the previous zoning designation for the site. Provision of a greater amount of open space shall be considered an example of design excellence that shall contribute to the basis for consideration of a residential density bonus. Open space included in the planned development shall be maintained in perpetuity in accordance with the provisions of the planned development agreement.*

Per this section of the Zoning ordinance (Section 3.1.18.C.vi.f.), the planned development shall provide open space consistent with the previous zoning designation for the site, at a minimum. Currently the project site is zoned CA-Conservation Agricultural. In CA, the open space requirement is a minimum of 85%, for a single-family detached dwelling. It is unclear how to apply this standard when the planned development also includes commercial uses.

Historically, however, open space requirements outlined in Section 3.15 of the Zoning Ordinance have been applied for other single-family residential planned developments in the Township such as Walnut Ridge Estates and Fiddler Grove.

Section 3.15 of the Zoning Ordinance states residential condominium developments (in several zoning district classifications) should provide a minimum of 25% open space, with a minimum of 10% of the total open space to be useable open space (“useable open space” is defined as land area suitable for active recreation).

Open space guidelines are provided in the Pattern Book on Page 10 for two (2) different categories: Residential Districts; and Commercial/Mixed Use Districts. Residential Districts will provide a minimum of twenty-five percent (25%) open space overall, which includes any greenbelts, and a minimum ten percent (10%) usable open space overall. The specific Residential District categories are not listed here. In the Commercial/Mixed Use Districts, a minimum of fifteen percent (15%) open space will be provided and a minimum two percent (2%) usable open space overall. These percentage guidelines are meant for the overall development regardless of the phase.

Under the heading of Usable Open Space Guidelines, Residential Districts will provide a minimum of ten percent (10%) usable open space throughout the districts. In Commercial/Mixed Use Districts, a minimum of two percent (2%) of usable open space will be provided.

Usable open space can include natural areas, flexible park areas, and urban plazas. The cover letter from the applicant, dated April 15, 2021, indicates that more than fifteen (15) acres of the total parcels is usable open space, mostly in the form of recreation parks and pedestrian plazas. Additionally, the applicant indicates that approximately 13.09 acres of wetland habitat will be preserved.

Open space calculations for these districts (Residential and Commercial/Mixed Use) cannot be computed at this time as the Pattern Book does not offer any information on the size of each district. It is unclear where the 15 acres of usable open space will be provided. Illustrative drawings for open space areas are provided in the Pattern Book Page 10-11) and are meant to be conceptual in nature. The Site Landscape Plan for the North and South Parcels (Page 38-39) show possible locations of open space and usable open space areas. As noted, some areas shown as open space on the North Parcel are actually outside the property boundaries of Newberry Place Planned Development and could not be counted as open space. This issue should be corrected in the Pattern Book.

A separate plan is provided showing areas designated as Open Space and Usable Open Space; however, the specifics on the size of each area and what amenities are offered in each area are not provided. Staff is unsure why this page is not included in the Pattern Book and clarification is required as to the purpose of this page.

The exact locations of the open space and usable open space areas will be further defined as part of each site plan application for the various phases of the project. The applicant should be required to provide open space calculations with each site plan application so that the open space percentages for each district and overall open space can be quantified and cross-checked with the Pattern Book regulations.

11. Natural Features. *Consistent with the stated intentions for creation of these regulation, the preservation of the natural features of the Township are an important planning consideration. A PD proposal must consider the natural topography and geologic features, scenic vistas, trees and other vegetation and natural drainage patterns that exist on the site and propose a development pattern which preserves and avoids disruption of those natural features as much as possible.*

A site plan was not provided showing the existing natural features/topography, or an overall development plan showing proposed grading, tree clearing and other environmental impacts This information will be

required with each site plan application. A copy of the Wetland Determination report dated September 9, 2015, was provided by the applicant. In that report, it was noted there is a wetland of nineteen (19) acres, which extends beyond the subject property; and because it is larger than five (5) acres, it is likely regulated by the State of Michigan. There are other wetlands identified in the report that are unregulated, as well as regulated.

Any work in a regulated wetland will require a permit and approval from the Michigan Department of Environment, Great Lakes, and Energy (EGLE), formerly known as the Michigan Department of Environmental Quality (MDEQ).

12. Sidewalks and Pedestrian Access. *The applicant must demonstrate the PD site and all uses within the site will be connected to any existing pedestrian and nonmotorized vehicle paths and trails within a public right-of-way or easement open to the public.*

The Regulation Plan (Page 2) shows the conceptual location of an 8-foot bituminous Bike/Safety Path along the frontage of Highland Road on the North and South Parcel, and along the west side of Fenton Road and Pleasant Valley Road. As noted previously, this plan and Page 12 (Street Type Guidelines) should be revised to show a 5-foot concrete sidewalk along the frontage of Highland Road on the South Parcel.

Staff assumes pedestrian circulation is provided via a network of sidewalks throughout the planned development, although the plan is difficult to read due to its scale. In the North Parcel, a pedestrian walk is shown in the northwest corner that connects to the Township's Heritage Park.

Other Pattern Book Details

Following is a discussion on two other sections in the Pattern Book which are Architecture/Building Materials and Signage.

Architecture / Building Materials

Residential Buildings

The project includes a mixture of residential housing styles for which there are no architectural standards in the Township's Zoning Ordinance (Section 5.24.14). Architectural guidelines for residential structures are found in the Pattern Book (page 17-23). Building material specifications are found on Page 17 and 20. Percentages for some of the materials are provided on those pages and are stated on the elevation drawings for the attached style condominiums (up to 5 units only). Architectural drawings for single family detached homes do not list the building materials. Façade materials include a combination of siding (horizontal, vertical, shakes), manufactured stone, and brick. The siding products include vinyl, cementitious or wood.

Conceptual building elevations are provided for single family detached homes, attached style condominiums (up to 5 units only), duplex motor court homes, and 4-6 plex motor court homes. Only the front elevations are shown for the motor court homes.

Architectural guidelines for Mixed Use/Multiple Family housing are provide on pages 28-31. Conceptual building elevations are not provided for a multiple family building (up to 14 units per building) nor for any type of detached garage buildings associated with a multiple family building. Façade materials include a combination of siding (horizontal, vertical, shakes), manufactured stone, and brick. The siding products include vinyl, cementitious or wood. Façade material percentages are provided for each building elevation.

During the discussion of the Concept Plan (SP #21-006), the Planning Commission had the following comments:

- Page 22 (Duplex Motor Court Homes): The elevation drawings should show the entrance drive between the duplex buildings, to match the site plan rendering of the motor court layout.
- Page 29-31 (apartment buildings): Concerns with the garage doors, and the aesthetics if facing a street. The plan should show the locations of the garage doors.
- Illustrative drawings should be provided for the motor court houses, showing all sides of the buildings (pages 22-23).

Commercial and Mixed Use Commercial Buildings

Façade Materials

It is the expectation that high-quality non-prototype architecture will be offered in the PD, that exceeds the minimum design material requirements of the Ordinance; thus, a review of the architectural renderings, façade materials, and façade material percentages as presented in the Pattern Book, is required.

Architectural guidelines for commercial and mixed use (commercial-office/residential) buildings are found in the Pattern Book on page 24. Conceptual drawings of the buildings are provided on page 25-27, with façade materials and percentages listed. A footnote states “Any façade material not listed shall comply with the Group #1 commercial architectural standards of the most current Township Zoning Ordinance”. The intent is to comply with the Ordinance architectural standards but provide additional regulations in the Pattern Book where deviations occur.

Per the regulations for Building Walls on page 24 of the Pattern Book, the following proposed façade materials are listed:

- Brick (natural clay): minimum 40%; maximum 100%
- Stone (natural or cast): maximum 50%
- Siding (wood, vinyl, cementitious, or shake): maximum 10%

As a comparison one should review Section 5.24.14 of the Township Zoning Ordinance, which lists the Façade Material Groups and Façade Materials. A façade materials chart lists the maximum percentage allowed per material for each façade materials group. The proposed façade material percentages align with the Zoning Ordinance for Group #1, except that a minimum 40% brick is required in the Pattern Book whereas the Zoning Ordinance requires a minimum of 30%, thus a higher standard is proposed for this category.

When reviewing the façade materials listed on the architectural renderings for commercial/mixed use commercial buildings (Pages 25-27), additional products are listed such as Decorative Block and Panel System. Product information and minimum/maximum percentages are not listed on page 24 under Building Walls. Without the product information, it is unclear if either of those products are listed in the Façade Materials chart in Section 5.24.14. of the Zoning Ordinance. It is possible Decorative Block is similar to a façade material listed in the Ordinance, Decorative Concrete Masonry Unit, which is allowed, up to a maximum 25%. Plain faced, striated, fluted or scored concrete masonry units are not permitted.

Brick/Decorative Block varies between 40% and 57% on the drawings. If the proposed product is brick, the Pattern Book states the minimum as 40% and maximum of 100%, thus it would comply. If the product is Decorative Block, and if this product is similar to Decorative Concrete Masonry Unit (as allowed in the Ordinance), then the maximum allowed is 25%. The percentage of each proposed façade material (brick and decorative block) should be listed on the architectural drawings in order to check for compliance.

Flat metal panels are allowed as a façade material in the Ordinance and limited to 20% maximum. Again, it is unclear what product is being used in the proposed Panel System thus it cannot be determined if the Ordinance standards apply, or if the product is regulated by the Pattern Book.

It also appears that in several instances siding exceeds the maximum allowed percentage of 10% as allowed in the Pattern Book (range of 11% to 16% on commercial buildings).

In summary, clarification is required regarding the façade materials, including product information, minimum/maximum percentage of each façade material, and whether the product is regulated by the Zoning Ordinance or the Pattern Book. An update to the Building Walls material list may be required.

Architectural Drawings

Based on prior site plans and discussions with the applicant, two (2) gas stations, each with a fueling station canopy, are proposed, with one on the North Parcel and the other on the South Parcel. An architectural rendering of the fueling station canopy should be provided in the Pattern Book, with façade material information and total height of the canopy stated. Architectural drawings for drive-through buildings and the carwash should be included in the Pattern Book, as these were proposed on previous plans.

Signage

The sign program for the planned development is a combination of regulations, primarily using the most current sign regulations in the Hartland Township Zoning Ordinance, with the exception of entry wall and pier designs and monument or ground signs. Separate sign standards are provided in the Pattern Book for six (6) different types of signs, all essentially ground signs. A drawing of a pier/lighted column is also shown; however, there does not appear to be signage on the pier/column (page 35).

At the top of page 47, (entitled Sign Regulations), there is the following statement: “Newberry Place sign regulations will comply with the most current Hartland Township Zoning Ordinance with the exception of the entry wall and pier design and monument sign regulations set forth on pages 43-45.” The page reference is incorrect as pages 43-45 are related to landscape regulations thus this should be corrected. Based on this language staff presumes all other types of signs are to default to the current Zoning Ordinance standards, such as wall signs.

Signage regulations and site plans associated with signs are found on the following pages in the Pattern Book: page 34 (Landmark Corner Sign); page 35 (Newberry Place Entry Wall and Pier Design); page 36 (plan view of Entry Wall and Pier Design); page 47 (Sign Regulations + Newberry Place Ground Signs); page 48 (this appears to be a repeat of page 47); and page 49 (Monument Sign Locations with site plan).

Following is a summary of the type and number of monument signs on the North and South parcels. Please use page 49 as a reference.

| Sign Type | North Parcel - # of signs | South Parcel - # of signs |
|---|----------------------------------|----------------------------------|
| Commercial Fuel Price Sign | 0 | 1 |
| Combined Ground Sign | 3 | 2 |
| Commercial Tenant Ground Sign | 2 | 2 |
| Commercial Business Monument Sign | 1 | 1 |
| Ground Sign to Residential Development | 1 | 1 |
| Entry Wall Sign and Pier/lighted column | 3 | 3 |

There are some observations to be noted about the sign information in the Pattern Book. Page 34 provides drawings of the Landmark Corner Sign however it is unclear as to the location(s) of this sign in the planned development. Landmark Corner Signs are not shown on Page 49. Clarification is requested as to the location(s) of these signs. These signs should be shown on Page 49 (Monument Sign Locations).

Page 49 only shows one (1) Commercial Fuel Price Sign on the South Parcel, and no such sign on the North Parcel. If a gasoline station is to be located on the North Parcel, one would assume there will be a Commercial Fuel Price Sign associated with that business.

Lastly it is unclear if the Pier/Lighted Column is considered a sign, or a light fixture. Signage is not shown on the drawing of the pier. Page 36 shows this structure in the center island of a boulevard entrance however it is unclear where this entrance is located in the development. Additional information should be provided by the applicant as to the purpose of the piers and where they will be located.

The design elements and materials are the same for each monument sign, thus providing continuity in the sign program. Each monument sign is comprised of a precast concrete sign with stained concrete relief logo; brick wall with sign panels (no panel on the entry wall sign); planter boxes; and brick columns. Each column is topped with a light fixture. Anodized aluminum letters spell out “Newberry Place” which are mounted onto the sign structure. These design elements are physically joined together into one sign structure, making it difficult to determine what is the actual sign area to be measured.

The Zoning Ordinance provides guidance in the measurement of sign area in Section 5.26.7.B. The area of a sign shall be measured by calculating the square footage of the sign face. The most protruding points or edges of sign are placed within a rectangle including the frame. Essentially the sign area is determined by multiplying the dimensions of the rectangle (height x length of the sign face).

The Zoning Ordinance standards for a monument sign are provided in a chart in Section 5.26.8.M. The maximum allowed sign size is 64 square feet. The maximum allowed sign height is seven (7) feet. These standards apply to all zoning districts, including a planned development. A fuel price sign is allowed to be a maximum twenty (20) square feet in area. If the sign is included on a monument or wall sign, the fuel price area must be included as part of the total permitted sign area. In most cases one (1) monument sign is permitted per property.

Sign calculations were not outlined in the Pattern Book however the sign drawings have the dimensions stated for most of the sign elements. The drawings are not drawn to scale. Due to the complicated design of the monument sign and missing dimensions in some cases, it is difficult to calculate sign area. It could be said that each monument sign structure has at least two (2) signs: the precast concrete structure with stained relief logo and the separate sign panel/box that displays several tenant signs or fuel pricing. The individual letters for “Newberry Place” could be considered a third sign however dimensions are not provided on the drawing thus sign area cannot be determined.

The chart below outlines the sign sizes for the two (2) categories mentioned above, for each type of monument sign. The sign height is listed as well.

| Monument Sign Type | Precast concrete Sign (SF) | Sign panel w/ tenant names (SF) | Sign height |
|--|-----------------------------------|---|--------------------|
| Commercial Fuel Price Sign | 59.29 SF | 70.6 SF Overall 35.6 SF Fuel price portion of sign | 10'-0" |
| Combined Ground Sign | 28.1 SF | 29.2 SF | 7'-8" |
| Commercial Tenant Ground Sign | NA | 70.6 SF | 8'-3" |
| Commercial Business Monument Sign | 59.29 SF | 70.6 SF | 10'-0" |
| Ground Sign to Residential Development | 28.1 SF | 29.2 SF | 7'-8" |
| Newberry Place Entry Wall | 159.6 SF | NA | 12'-0" |

The sign drawings state the sign panel on the Commercial Fuel Price sign is opaque and the fuel sign is flip sign (not digital). The other panel signs are stated as having cut out lettering with opaque background.

Other Requirements-Zoning Ordinance Standards

Nothing additional at this time.

Hartland Township DPW Review

A review letter is provided from the Hartland Township DPW Director, dated June 2, 2021

Hartland Township Engineer’s Review (HRC)

No comments at this time.

Hartland Deerfield Fire Authority Review

The Hartland Deerfield Fire Authority has reviewed the plans and provided comments in the letter dated May 25, 2021. Approval is subject to the contingencies being addressed as outlined in the letter.

Attachments:

1. DPW Review letter, dated June 2, 2021 – *PDF version*
2. Hartland Deerfield Fire Authority review letter, dated May 25, 2021 – *PDF version*
3. Applicant’s Summary dated April 15, 2021
4. Agency review letters from applicant April 15, 2021
5. Newberry property owner signature page
6. Newberry Place Preliminary PD Pattern Book April 15, 2021
7. Newberry Place PD Open Space Plan dated April 15, 2021
8. SP #21-006Newberry Place Concept Plan 02.23.2021 – *PDF version*
9. SP PD #535-P Newberry Place PD 2016 Overall Plan – *PDF version*
10. SP PD #535-P Newberry Place PD 2016 Commercial Architecturals – *PDF version*

SP #20-012 Newberry Place PD Preliminary Plan

June 3, 2021

Page 26

CC:

HRC, Twp Engineer (via email)

M. Luce, Twp DPW Director (via email)

A. Carroll, Hartland FD Fire Chief (via email)

T:\PLANNING DEPARTMENT\PLANNING COMMISSION\2020 Planning Commission Activity\Site Plan Applications\SP #20-012 Newberry PD Preliminary\Staff reports 2021\Planning Commission 2021\SP #20-012 Newberry Place PD Prelim staff report PC 06.03.2021.docx



DEPARTMENT OF PUBLIC WORKS

Michael T. Luce, Public Works Director
2655 Clark Road
Hartland MI 48353
Phone: (517) 294-0056

TO: Planning Department
DATE: 06/02/2021
DEVELOPMENT NAME: Newberry Place Planned Development
DEVELOPMENT ADDRESS / PIN#: Highland Road #4708-23-400-016 & 4708-26-200-005
APPLICATION #:
REVIEW TYPE: Preliminary Site Plan

After reviewing the preliminary site plans Public Works has no objections at this time. Subsequent reviews will be required for each site plan in the development as well as REU requirements for each site plan as they are submitted.

Hartland Township Public Works is requesting additional detail regarding the water and sewer infrastructure included in the preliminary site plan.

1. Source of water supply (well or municipal water)
2. Water main material, sizes and connection detail sheet
2. Water service lead location, size and materials including fittings
3. Sanitary sewer material and sizes and connection detail sheet
4. Monitoring manhole for sewer connection and location if required
5. Hydrant model (EJ5BR) shown on plans
6. Utility easements noted as public or private
7. Water treatment detail sheet

Please feel free to contact me with any further questions or comments regarding this matter, and thank you for your time.

Michael T. Luce
Public Works Director



HARTLAND DEERFIELD FIRE AUTHORITY

FIRE MARSHALS OFFICE

Hartland Area Fire Dept.
3205 Hartland Road
Hartland, MI. 48353-1825

Voice: (810) 632-7676

E-Mail: jwhitbeck@hartlandareafire.com

May 25, 2021

To: Zoning/Planning
Hartland Township
2655 Clark Road
Hartland MI 48353

Re: Request for Review of the *Newberry Place Preliminary Submittal 4.15.2021*

Based upon the drawings submitted by email on April 15, 2021 in the pattern book, this office has the following questions/comments:

- There is a question in many locations of the width of the roadway and access to the entrances is adequate for fire apparatus. For your convenience, a turning radius sheet has been attached to this letter in a .pdf format. Please be sure that future submittals meet the guidelines in the turning radius sheet.
- Alley fire lane is currently only 16' wide, so no parking allowed on the street. Street widths from 26' – 30' only allows parking on one side of the street. Increasing the width to 32' allows for parking on both sides of the street giving the 20' access roadway for fire apparatus.
- To allow for parking on one side of the Boulevard the street width needs to be increased to 26'.
- Will there be a deceleration lane coming into the complex?
- The North side of this development as currently drawn will need to have suppressed homes along with hydrants due to the one way in and out access. Per previous conversations with Mayberry Homes, discussion revolved around the suppression of all residential occupancies within this project. There are significant allowances that can be given due to installing fire sprinklers inside the residences. Those allowances could be hydrant spacing further apart, road widths decreased and longer single access roads without a second means of egress.
- This project will be built with flexibility due to market demands so new plans will need to be reviewed and approved as the project progresses.

The submittal of the Newberry Place Preliminary Submittal is recommended for approval by this office per the contingencies listed above. We look forward to working with the Township and the developer throughout the building of the different phases to further solidify the details.

Yours In Fire Safety,

Jenn Whitbeck
Fire Inspector



RECEIVED
APR 15 2021
HARTLAND TOWNSHIP

April 15, 2021

Hartland Township

Re: Newberry Place – PD Preliminary Submittal

Enclosed is the submittal of the Newberry Place Planned Development.

Following is a list of our submission:

- Letter of Intent (11 copies)
- Density Comparison Summary (11 Copies)
- Pattern Book (11 copies)
- Wetland Determination (11 copies)
- Natural Features Exhibit (11 copies)
- Livingston County Drain Commissioner Review (11 copies)
- Michigan Department of Transportation Review (11 copies)
- Livingston County Road Commission Review (11 copies)
- Open Space Exhibit (11 copies)
- Ownership Approval Exhibit (11 copies)
- USB Stick Containing All of the Above

We look forward to moving this development forward.

Thank you,

David Straub
Mayberry Homes
248-303-0455



April 15, 2021

Hartland Township Planning Commission

Re: Proposed Newberry Place Planned Development ~ Historical Density Comparison

The following information represents a summary of the density requests that the Township has considered for the Newberry Place Planned Development.

- 2007: Pattern Book had 328 Residential Units and 280,103 sq. ft. of commercial space.
- 2016: Preliminary Plan had 499 Residential Units, 4.59 DU/AC, and 140,715 sq. ft. of commercial space.
- 2019: Conceptual Plan had 529 residential units, 4.03 DU/AC, and 133,950 sq. ft. of commercial space. This plan included the west 40 acres.
- 2021: The current submission has 417 units, 3.84 DU/AC and 133,950 sq. ft. of commercial space. The west 40 acres is no longer included.



April 15, 2021

Hartland Township Planning Commission

Re: Proposed Newberry Place Planned Development

Planning Commission Members,

This letter is to advise the Planning Commission for Hartland Township that the proposed Newberry Place Planned Development meets all the guidelines, design criteria, and ordinances based upon the Hartland Township Zoning Ordinance. Further, we specifically address the following in our Preliminary submittal:

1. Recognizable Hartland Community Benefits

- a. The PD includes property that will be dedicated for a new Fire Station.
- b. The PD will provide a more useful pattern of high quality open space and recreation areas by providing more than 15 acres of the total parcels as “useable open space” mostly in the form of recreation parks and pedestrian plazas that can be used by the entire Hartland community. The intent of the PD is to provide and encourage a walkable community for all PD uses and for the Hartland community.
- c. The PD will be a walkable community with internal connections to keep residents and visitors off the connector roads.
- d. The PD provides a higher density development pattern with services in close proximity for residents of the Newberry Place Community as well as the Hartland Community, decreasing the effects of urban sprawl on the environment and allowing the preservation of 13.09 acres of wetland habitat. The proposed uses will provide a choice of living environments including family, age-targeted and rental housing as well as office and retail uses.
- e. The PD provides a cohesive architectural style which is carried throughout all the uses as well as the site amenities providing a unique neighborhood development unachievable through conventionally zoned developments.
- f. The PD will provide commercial aspects that are currently unavailable in this location. This will provide shopping, food, and fuel to current neighborhoods that is closer than current locations. This will also provide for additional jobs for the Hartland community.
- g. The PD zoning allows deviation from conventional pavement and parking dimensions which in turn preserves open space and reduces impervious surface allowing for greater infiltration of rainwater and calms traffic.
- h. The PD provides opportunity for future connections to the vacant land to the west providing direct access to valuable services without increasing traffic on M59.

- i. The PD will provide a large additional tax base as well as a good size population of school aged children to the Hartland community.
 - j. The PD will utilize the municipal water service and may include a special assessment for this service.
 - k. The PD will absolve \$1,931,165.01 in outstanding sewer assessments or 435 REUs that are currently associated with some of the parcels that make up the Newberry Place PD. This is significant township debt which is being absorbed in the cost of the project.
 - l. The PD will extend the existing Hartland sewer system on the north parcel approximately 535 feet to Fenton Road such that future development east of the PD will have access to it closer than it currently is.
 - m. The PD will extend the existing Hartland sewer system on the south parcel such that future development east of the PD will have access to it closer than it currently is. This includes extending the sewer across property that is not owned by the developer.
2. The total area of the project is more than 108 acres and therefore meets the minimum size requirement for a PD. The property contains areas of wetland that will be undisturbed and has been reviewed on site with EGLE.
 3. The PD is compatible with the comprehensive plan for Hartland Township which designates this area as a Special Planning Area. The mix of uses within the PD does not impair the public health, safety, welfare, or quality of life of the development or the Hartland community.
 4. Single family structures will be Energy Star certified.
 5. Landscaping, signage, lighting, and building materials are all intended to be of a high design quality and aesthetically pleasing. Buffering the PD from existing residential uses on adjacent properties is a key component of the site plan design.
 6. The PD will be controlled under a Master Plan based upon restrictions as defined in the Preliminary submittal documents.

Sincerely,

Bob Schroeder

President, Mayberry Homes, LLC



King & MacGregor
Environmental
Inc.

September 9, 2015

Sent Via Email

Mr. Scott Thomas
Mayberry Homes
1650 Kendale Boulevard, Suite 200
East Lansing, MI 48823

Re: Wetland Determination – M-59 & Pleasant Valley Road

Dear Mr. Thomas:

Pursuant to your request, on September 8 and 9, 2015, a wetland determination was conducted on the above-referenced site. The intent of this report is to provide a description of the location and character of the wetland areas identified within the subject parcel(s) and an opinion as to the possible jurisdiction of the Michigan Department of Environmental Quality (MDEQ) over wetland areas identified on-site.

The methods used to conduct this wetland determination are consistent with our understanding of the procedures and general practices used by the MDEQ and the U.S. Army Corps of Engineers Wetlands Delineation Methodology. Our determination included review of in-office information including the national *Web Soil Survey*, and *MDEQ Wetlands Map Viewer* mapping.

The subject parcels total approximately 108 acres in size and are located in Sections 23 and 26, Hartland Township (T3N, R6E), Livingston County, Michigan. The enclosed Preliminary Wetland Boundary Flag Map and MDEQ Jurisdictional Assessment depicts the approximate location of these wetland areas.

Wetland A

Wetland A is an emergent wetland area located on the southern one-third of the property. The vegetation identified in this area included species such as narrow-leaved cattail, *Phragmites* reed, reed canary grass, and calico aster. The soils are described in the national *Web Soil Survey* as Rifle muck, a very poorly drained soil. The soils evaluated on-site were consistent with this description. The boundaries of this wetland were identified using flags A 1 through A 48.

Wetland B

Wetland B is a forested/emergent wetland area located on the southern one-third of the property. The vegetation identified in this area included species such as American elm, red ash, blue-beech, sandbar willow, red maple, reed canary grass, and skunk cabbage. The soils are described in the national *Web Soil Survey* as Carlisle muck, a very poorly drained soil. The soils evaluated on-site were consistent with this description. The boundaries of this wetland were identified using flags B 1 through B 47.

Wetland C

Although flagged as a separate wetland line due to the location of the western property boundary, Wetland C is actually the northern portion of Wetland B. The vegetation and soil conditions observed in this area were similar to the conditions observed throughout the rest of Wetland B. The boundaries of this wetland were identified using flags C 1 through C 21.

2520 Woodmeadow SE
Grand Rapids, MI 49546
Phone: 616/957-1321
Fax: 616/957-2198

43050 Ford Road, Suite 130
Canton, MI 48187
Phone: 734/354-0594
Fax: 734/354-0593

162 Kuivila Road
Crystal Falls, MI 49920
Phone: 906/367-0171

email: kme@king-macgregor.com

Wetland D

Wetland D is a forested/emergent wetland located on the southern one-third of the property. The vegetation identified in this area included species such as reed canary grass, stinging nettle, sensitive fern, poison ivy, and calico aster. The boundaries of this wetland were identified using flags D 1 through D 51.

Wetland E

Wetland E is a forested/emergent wetland located in the center of the property. The vegetation identified in this area included species such as sandbar willow, black willow, box-elder, sensitive fern, reed canary grass, grass-leaf goldenrod, and smartweed. The boundaries of this wetland were identified using flags E 1 through E 51.

Upland Areas

The upland areas adjacent to the on-site wetlands included fallow wheat fields dominated by weedy annual species such as fox-tail and agricultural fields planted to soybeans. There was no evidence of standing water or saturated soils in any of the upland areas.

MDEQ Jurisdiction/Regulatory Discussion

In order for the MDEQ to have regulatory authority over a wetland, the wetland must be within 500 feet of a lake, pond and/or stream, have a direct surface water connection to a lake, pond and/or stream, or be greater than five acres in size. Wetland A is likely to be regulated by MDEQ because it is part of the larger wetland east of Pleasant Valley Road and the total area of the wetland on the east and west sides of Pleasant Valley Road is approximately 19 acres. Wetland B/C is likely regulated by the MDEQ due to it also being greater than 5 acres in size. Wetlands D and E are likely not regulated because they are not within 500 feet a lake, pond and/or stream, and they are less than five acres in size. A survey of the flagged wetland boundaries should be conducted to specifically locate the wetland areas and determine their exact size.

A permit must be obtained from the MDEQ prior to conducting most filling, dredging and/or draining activities or maintaining a use of a regulated wetland.

Please be advised the information provided in this report is a professional opinion. The ultimate decision on wetland boundary locations and jurisdiction thereof rests with the MDEQ and, in some cases, the Federal government. Therefore, there may be adjustments to boundaries based upon review of a regulatory agency. An agency determination can vary, depending on various factors including, but not limited to, experience of the agency representative making the determination and the season of the year. In addition, the physical characteristics of the site can change with time, depending on the weather, vegetation patterns, drainage, activities on adjacent parcels, or other events. Any of these factors can change the nature / extent of wetlands on the site. We recommend the MDEQ be requested to confirm our wetland boundaries and jurisdictional opinion. This report does not address any local ordinances that may apply to this site.



Thank you for the opportunity to provide this wetland determination. If you have any questions, please feel free to call my cell phone at (734) 634-5702 or contact me via email at jsallee@king-macgregor.com at your convenience.

Sincerely,



King & MacGregor Environmental, Inc.
James Sallee

Enclosure





Brian Jonckheere

Livingston County Drain Commissioner
2300 E. Grand River Ave., Ste. 105
Howell, MI 48843-7581
Phone: 517-546-0040 FAX: 517-545-9658
Website: www.livgov.com/drain Email: drain@livgov.com

June 6, 2019

Mr. John Barber
TetraTech
401 S. Washington Square
Lansing, MI 48933

Re: Newberry Place
Preliminary Site Plans
Southeast 1/4 of Section 23 and
Northeast 1/4 of Section 26
Hartland Township

Dear Mr. Barber:

I received Preliminary Site Plans for the above referenced site on April 5, 2019 with Fees paid on April 16, 2019. The submitted information has been reviewed for conformance with the L.C.D.C. "Procedures and Design Criteria for Stormwater Management Systems." Our comments on the proposed drainage design are as follows:

- 1.) Drainage System Ownership - The plans should contain a general note stating that "The proposed drainage system is to be privately owned and properly maintained by the developer and/or property owner's association."
- 2.) Overall Drainage Concept - The proposed mixed use development is to be located on both the northwest and southwest corners of Highland Road (M-59) and Pleasant Valley (Fenton) Road. The portion on the northwest corner is to be accessed from Highland Road and contain four commercial buildings along the Highland Road frontage, as well as 66 single family residential sites with a park area located to their north. The portion of the development on the southwest corner is to be accessed from both Highland Road and Pleasant Valley Road. It is to contain 5 commercial buildings, a gas station/car wash/lube center

facility, 321 multiple family residential units with a clubhouse/pool area and 142 single family residential sites.

The runoff from most of the site north of Highland Road currently sheet drains through some onsite low areas toward the south where it crosses under Highland Road through an 18" diameter culvert. The developed runoff from this area is to be routed by proposed storm sewers to the "North" stormwater detention basin located along Highland Road in the southwest corner of the parcel. This basin is proposed to discharge to an existing storm sewer in the Highland Road R.O.W.

The runoff from most of the site south of Highland Road currently sheet drains through onsite wetland areas toward the southwest where it crosses under Hartland Glen Lane and flows west through the adjacent golf course to Silver Lake. The developed runoff from this area is to be routed by proposed storm sewers to the "Wetland", "Southwest" and "Southeast" stormwater detention basins located around the site's westerly and southerly boundary. These basins are proposed to discharge to the Hartland Glen Lane road ditch or the adjacent wetland areas.

Although the property is not currently within a drain special assessment district, we note that the southerly boundary of the development coincides with the northerly boundary of the Hartland County Drain Special Assessment District. Documentation of overflow paths discussed later in this letter will be necessary to determine if any lands in the proposed development should be added to the Hartland County Drain Special Assessment District.

- 3.) Topographic Survey - A separate Topographic Survey of the site containing many of the currently missing Preliminary Plan Checklist items should be provided. Some of the missing survey related items include the following:
 - a.) Complete property descriptions of the subject parcels should be provided. The parcel boundaries should be labeled with their respective bearings and distances. The section corner ties for the parcels should also be shown.

- b.) A project location map, survey legend and site bench marks should be included.
 - c.) The tax roll number and owners name of the subject parcels and the surrounding parcels should be shown. The right-of-way widths of the adjacent roadways should be noted. Any existing easements should be shown and identified.
 - d.) The existing buildings and topographic information shown should extend at least 100 feet outside the site boundaries. Complete information including pipe size, rim and/or invert elevations should be provided for all onsite and adjacent roadway manholes, catch basins, culverts and gate valves.
 - e.) All onsite and adjacent wetland boundaries should be labeled and their regulatory status indicated.
 - f.) Soil borings, at least 10 feet deep, should be provided within the proposed stormwater detention basin areas. The soil boring logs should indicate the underlying soil types and the ground water elevations.
- 4.) Site Plans - The Preliminary Site Plan sheets should indicate the proposed street names, lot numbers and setbacks for the single family residential sites. They should also indicate building and/or unit numbers for the proposed multiple family residential buildings. A Site Data tabulation of the parcel areas, number of proposed commercial buildings, numbers of residential sites and residential units, etc. should be provided, as well as typical cross sections for the proposed roadways.
- 5.) Drainage Areas Plans - The preliminary plans should show the drainage boundary, acreage and "C" value of the tributary area to each proposed inlet, catch basin and culvert. All offsite tributary areas should also be mapped and their acreages noted.
- 6.) Stormwater Detention - Our calculations confirm that the required 100 year frequency storm storage volume has been correctly computed for each of the proposed detention basins based on the tributary areas and weighted average runoff coefficients shown and a discharge rate of 0.20 cfs/acre. However, sufficient downstream capacity to accommodate this proposed discharge rate must be documented for each basin. An overflow spillway should be shown for each basin and the overflow path of each receiving wetland

should also be documented. The bankfull volume for each basin should be calculated using the equation $5160xAxC$. Other stormwater detention related items requiring further attention on the plans include the following:

North Basin - The proposed basin contours shown on Sheet C-103 do not coincide with the elevations shown in the detention calculations on Sheet C-101. The proposed discharge from this basin to the existing 30" storm sewer in the Highland Road R.O.W. will require M.D.O.T. approval. Since the current runoff from this portion of the site appears to flow under Highland Road in an existing 18" culvert, M.D.O.T. may not permit the proposed connection.

Wetland Basin - The tributary area boundary shown on Sheet C-106 for this basin does not coincide with the proposed storm sewer layout shown on the same sheet. It appears the runoff from the two proposed commercial buildings facing Highland Road, and the parking lot areas south of them, will be directed to the Southwest Basin, rather than the Wetlands Basin. If this is the case, approximately 6 acres of tributary area should be moved in the detention design calculations from the Wetlands Basin to the Southwest Basin. The currently proposed wetland storage elevation will encroach onto the neighboring property along Hartland Glen Lane. The basin's one foot freeboard elevation should be fully contained within the subject property. Existing roadway and ditch bottom grades should be shown along Hartland Glen Lane to verify a reasonable outlet elevation for this detention area. Forebays should be provided at the inlet points of the basin.

Southwest Basin - It appears this proposed basin should be expanded to accommodate the additional 6± acres of tributary area as discussed above. Any existing culverts flowing under Hartland Glen Lane located near the south property line should be shown together with their diameter, type of pipe and invert information to help verify a viable downstream flow path for this basin's discharge.

Southeast Basin - Two sets of proposed contours are currently shown around this basin's perimeter, neither of which are connected to the existing contours along the property line. An outlet control structure discharging to the adjacent wetlands north and west of the basin should be

shown. It appears that the proposed development area east of this basin will block off the existing overflow path of the wetland area along Pleasant Valley Road. An overflow path to the west must be maintained for this wetland area. The discharge path from this basin to the west should be confirmed as to whether the Hartland County Drain or Silver Lake (Along the east edge of the Handy Maxfield Shores Subdivision) serves as the ultimate outlet for this runoff.

- 7.) Storm Sewers/Culverts - All proposed storm sewers and culverts should be designed to accommodate the runoff from a 10 year frequency storm over the tributary areas. Complete storm sewer/culvert design calculations should be included in the development's Construction Plan submittal. Additional storm sewer related items which should be addressed on the Preliminary Site Plans include the following:
 - a.) The size of the proposed east-west roadway storm sewer shown behind the commercial buildings on the north side of Highland Road should be reviewed, as a 24" pipe is currently shown downstream of a 36" pipe.
 - b.) The proposed storm sewer systems should provide outlets for the rear yard drainage of the single family residential lots, where necessary.
 - c.) Additional catch basins will be required in the proposed large parking lot areas located behind the proposed commercial buildings shown on either side of Highland Road.
 - d.) The flow from the existing 18" culvert running under Highland Road should be discharged to the proposed storm sewer system and accommodated in its design.
 - e.) Road ditch culverts should be provided, where necessary, at the proposed Pleasant Valley Road entrances.
- 8.) Site Grading - Proposed finished floor elevations should be shown for the commercial buildings on the north side of Highland road. Minimum finished residence grades should be provided for each proposed single family lot within the development. Typical Lot Grading Details should also be included in Preliminary Site Plans.
- 9.) Drainage Easements - Drainage easements should be provided for all proposed storm sewers crossing private property and

Newberry Place

June 6, 2019

Page 6

for all stormwater detention basins. The width of storm sewer easements should be based on the sewer's depth, in accordance with the L.C.D.C. Design Criteria. The stormwater detention easements should encompass the basin's freeboard elevation plus an additional 10 feet for maintenance purposes.

I am withholding approval of the Preliminary Site Plans for Newberry Place until the above mentioned items have been addressed.

Very truly yours,



Kenneth Recker

Livingston County Chief Deputy Drain Commissioner

Cc: Robert West, Hartland Township
Troy Langer, Hartland Township
Kim Hiller, Livingston County Road Commission
Mike Darga, HRC
Pascal Bui, MDOT
Paul Lewsley, Environmental Engineers



STATE OF MICHIGAN

DEPARTMENT OF TRANSPORTATION
BRIGHTON TRANSPORTATION SERVICE CENTER

RICK SNYDER
GOVERNOR

KIRK STEUDLE
DIRECTOR

February 14, 2017

Ms. Julie Kroll, P.E.
Fleis & Vandenbrink
27725 Stansbury Blvd.
Suite 150
Farmington Hills, MI 48334

RE: Comments on Final Traffic Impact Study for the Proposed Newberry Place Planned Development M-59 at Fenton/Pleasant Valley Roads

Dear Ms. Kroll:

The following are the Michigan Department of Transportation's (MDOT) comments on the final version of the TIS dated January 11, 2017.

The proposed mitigation measures are sufficient to accommodate the forecasted increases in traffic volumes due to the construction of the new development. However, there are some additional comments on the proposed timeline in regards to the recommended improvements. Please see the summary below.

2018 Opening Year with mitigation

We are in agreement that the intersections of M-59 at Pleasant Valley-Fenton Road and the crossover east of the M-59 at Pleasant Valley/Fenton Road meet signal warrants under existing conditions. The MDOT is trying to secure funding for the installation of the two signals. More information as to the schedule of their installation will follow.

As the TIS indicates, 2018 opening day conditions indicate that there will be long vehicle queues at the intersections of M-59 & Fenton Road / Pleasant Valley Road and EB to WB crossover E. of Fenton Road, if the locations are not signalized. Both intersections operate at a failing LOS (E & F) during both peak periods without signalization. The proposed mitigation measures (signalization and prohibiting left turns at the intersection of M-59 and Pleasant Valley/Fenton Roads) will be need to be implemented prior to or in conjunction with the opening year - 2018.

Other required mitigations during opening year (2018) that are due to the traffic generated by the proposed development:

- 1) Eliminate the back to back crossovers along M-59 west of Fenton Road / Pleasant Valley Road and construct a new WB to EB crossover west of the proposed site driveways to M-59.

- 2) In addition to the two signals mentioned above, signalize the relocated WB to EB crossover west of Fenton Road / Pleasant Valley Road.
- 3) Construct a full width right turn lane at the proposed south site driveway to EB M-59. Based on the Warrant Graph for Right Turn Lanes (Note 604A), a full right turn lane is warranted under opening day volumes (2018) as opposed to full buildout as the TIS recommends. Therefore, this full width right turn lane will be required to be constructed prior to or in conjunction with the opening year (2018).
- 4) Accommodations during design of the proposed signals for the proposed dual storage lanes for the EB to WB crossover east of Fenton Road / Pleasant Valley Road and WB to EB crossover west of Fenton Road / Pleasant Valley Road.
- 5) South side site plan -internal circulation and access point being too close to the main driveway access off EB M-59. A revised site plan for the south side development was not submitted showing that the access point was relocated further south as required as stated in the December 22, 2016 comments. Approval for the main driveway access off EB M-59 is contingent upon this internal access point being relocated due to the strong potential for backups onto EB M-59.
- 6) Page 16 of the TIS recommends under 2018 opening year improvements, that the NB and SB right turn lanes on Fenton/Pleasant Valley be increased to 150 feet and 100 feet respectively but this was not discussed under opening day improvements. The LCRC should make the final determination as to when the full improvements need to be addressed.

Prior to Full Buildout – estimated 2019:

- 7) Based on the Warrant Graph for Right Turn Lanes (Note 604A), a right turn taper is warranted for the north site driveway at WB M-59 under opening year 2018 conditions. It appears a full right turn lane will be warranted sometime in 2019 should the proposed developments go in based on the buildout year trip generation table. MDOT will allow this full right turn lane to be phased in as the proposed developments warrant this full width right turn lane.

2027 Buildout year with mitigation

- 8) Provide dual storage lanes for the EB to WB crossover east of Fenton Road / Pleasant Valley Road.
- 9) Provide dual storage lanes for the WB to EB crossover west of Fenton Road / Pleasant Valley Road.
- 10) Extend one crossover lane through the intersection of M-59 & Fenton Road / Pleasant Valley Road for both crossovers east and west of Fenton Road / Pleasant Valley Road. Along EB M-59 the crossover lane should extend back through the proposed site driveway.
- 11) Provide additional improvements at crossovers along M-59 east and west of Fenton Road / Pleasant Valley Road to accommodate a WB-65 and passenger car.
- 12) Provide dual right turn lanes for the proposed site driveways to EB and WB M-59.
- 13) Provide signage and pavement markings along the site driveway approaches indicating proper lane assignments.
- 14) Provide staggered stop lines on the driveway approaches to M-59 on a lane by lane basis.
- 15) Provide 250 and 125 feet of storage for the NB and SB right turn lanes at the intersection of M-59 & Fenton Road / Pleasant Valley Road.

The TIS is considered approved by MDOT with the proposed mitigations going in as stated above. All proposed improvements slated for 2018 and beyond will be based on current MDOT geometric standards.

The phasing of the proposed improvements that are slated to go in after opening year 2018, will be worked out during the preliminary design phase of this project. Please note that a formal agreement will be necessary from the developer to ensure that the proposed improvements from year 2019 and beyond are accounted for.

If you have any further questions, please feel free to contact me at 810-225-2626.

Sincerely,

Wendy Ramirez
Traffic and Safety Engineer
MDOT-Brighton TSC

Livingston County Road Commission (LCRC) Review Comments
February 15, 2017

Newberry Place Traffic Impact Study
M-59 / Pleasant Valley Road / Fenton Road

The LCRC has reviewed the updated traffic impact study, dated January 11, 2017, for the proposed Newberry Place planned development located at the intersection of M-59 (Highland Road) and Pleasant Valley Road / Fenton Road. The LCRC has also reviewed the Michigan Department of Transportation (MDOT) review letter dated February 14, 2017.

The LCRC accepts the traffic study prepared by Fleis & VandenBrink and concurs with the comments and recommendations by MDOT in their review letter. Below are comments and recommendations by our office that pertain to roadways/intersections in the study that directly affect the county road system.

Pleasant Valley Road Impacts

The LCRC concurs with the report findings that the gravel road portion of Pleasant Valley Road should be improved to a hard surface roadway. The LCRC recommends that the PUD agreement negotiated between Hartland Township and the developer, Mayberry Homes, include a contribution toward future construction and paving of Pleasant Valley Road. In our opinion traffic volumes may be the best factor in determining percentage of contribution. Engineering would be needed to determine construction costs.

M-59 & Pleasant Valley / Fenton Intersection

The LCRC recommends that the M-59 and Pleasant Valley Road / Fenton Road intersection be signalized as a condition of this development's opening year traffic. This recommendation is based on the analysis of operations in the traffic study as well as comments by MDOT.

The LCRC recommends that a right-turn lane on northbound Pleasant Valley Road be constructed as a condition of opening year traffic, with 250 feet of storage to provide for traffic through the buildout year. Further, the LCRC recommends that a right-turn lane on southbound Fenton Road be constructed as a condition of opening year traffic, with 125 feet of storage to provide for traffic through the buildout year.

October 21, 2020

Attn: Hartland Township

Following is signed authorization to proceed with Preliminary PD approval from all property owners to be part of Newberry Place. All owners are aware of and in agreement with the request.

4708-23-400-036

Bazco Holdings LLC
30825 26 Mile Rd
New Haven, MI 48046

DocuSigned by:

Ally Barzgi

11A40F4FD3854DB...
Ally Barzgi

4708-26-200-006

Bazco Holdings LLC
30825 26 Mile Rd
New Haven, MI 48046

DocuSigned by:

Ally Barzgi

11A40F4FD3854DB...
Ally Barzgi

4708-23-400-037

Hartland North and South Land Investment LLC
Robert Schroeder
1650 Kendale Blvd, Ste 200
East Lansing, MI 48823

DocuSigned by:

Robert Schroeder

CA1A15B7D5D3406...er

4708-26-200-007

Hartland North and South Land Investment LLC
Robert Schroeder
1650 Kendale Blvd, Ste 200
East Lansing, MI 48823

DocuSigned by:

Robert Schroeder

CA1A15B7D5D3406...er

newberry PLACE

Pattern Book

Hartland Township, Michigan



Table of Contents

Introduction..... 01

Section One – Regulating Plan

Purpose and Overview 02
Permitted Principal Uses..... 03

Section Two – Site Regulations

Purpose and Overview 04
Residential Lot Regulation 05
Commercial District Lot Regulation 06
Mixed-Use Lot Regulation 07-09
Open Space Guidelines 10
Open Space Diagram 11
Street Type Guidelines 12-14
Street Light Guidelines 15
Site Furnishing Guidelines 16

Section Three – Architectural Guidelines

Purpose and Overview 17
Residential – Single Family Detached 18-19
Residential – Attached Style Condominium 20-21
Residential – Motor Court..... 22-23
Commercial and Mixed Use 24-27
Mixed-Use Multiple Family..... 28-31
Walls and Fences 32-36

Section Four – Landscape and Sign Regulation

Landscape Regulations..... 37-46
Sign Regulations..... 47-49



Introduction

Pattern Book Purpose

The Pleasant Valley Special Planning Area in Hartland Township, Michigan is envisioned to be a mixed-use, walkable, planned development that will enhance the surrounding township without taking on the appearance of a separate municipality. This new community, Newberry Place, is designed in the style of traditional town values.

The proposed community plans to incorporate a mixture of land uses that could include retail uses, office uses, single and multiple family housing alternatives, senior living facilities, medical services, other goods and services and a network of parks and open space. Because the development will be mixed and varied, it will also need to be cohesive in both the private and community realms. The design features of this proposed mixed-use community cannot be fully accomplished within the regulations of Hartland Township's Zoning Ordinance. Therefore, this Pattern Book, through its design guidelines, will serve as the guide to create this cohesion by defining deviations from the most current Hartland Township Zoning Ordinance.

Approval Process and Submittals

The Hartland Township Planning Commission and Township Board have approved the Newberry Place Planned Development Site Plans and Pattern Book. Each phase of development will require a Final Site Plan approval by the Township before permits will be issued. An internal review board herein referred to as the Architectural Review Board has been established to regulate development at Newberry Place. Prior to any phase being submitted to the Township for Final Site Plan review, the proposed plans must be submitted to the Architectural Review Board and must receive their approval. Architectural Review Board approval does not waive, exempt, modify, or assure any discretionary approval from the Township.

The Architectural Review Board and the Township Planning Commission will use both the Township Ordinance and the Pattern Book as the regulations for their review ("Regulations"). Where the Pattern Book deviates from the Township Ordinance, the Pattern Book will govern, as the Township has already approved the deviation. The Township Ordinance will govern issues not addressed in the Pattern Book.

When an application deviates from the Regulations, the applicant must get approval both from the Architectural Review Board and from the Township Planning Commission if the deviation requires Final Site Plan approval. For example, if an applicant wants to deviate from a required setback, or parking or loading requirements set forth herein, these issues need to be addressed both with the Architectural Review Board and the Township Planning Commission as these are issues that require a site plan be submitted to the Township.

Ownership of the property regulated by this Pattern Book is as follows:
Hartland North and South Land Investment LLC


Pattern Book Overview

The Pattern Book describes the design features that will define the character of the community. The following summarizes the main sections of this Pattern Book.

- I. Regulating Plan establishes the overall organization of Newberry Place with a diagram that identifies the general types of land uses and the permitted uses in those areas.
- II. Site Regulations pertain to those guidelines that govern building placement including setbacks and projections; parking requirements; public spaces; street and bike plan; lighting; site furnishings; and waste enclosures. These site regulations will ensure a cohesive village design for the community.
- III. Architectural Regulations address the architectural character of the neighborhoods within the community. These guidelines provide general features and materials for the various building types. Conceptual elevations and sketches are also included to better define the design features of the community, while still permitting creativity.
- IV. Landscape Regulations provide the guidelines for landscaping throughout Newberry Place. The regulations are intended to enhance the visual appeal of Newberry Place and enhance the cohesion between the various uses, while still permitting creativity.
- V. Sign Regulations define the styles, size, location, and design intent of signage within Newberry Place. The guidelines herein are intended to meet the needs of this project and to meet or exceed the Township standards, while still permitting creativity.



I. Regulating Plan



Purpose and Overview

The key to the long-term success of this type of traditional mixed-use community is the adherence to a “simple” planning principal: deliver a network of streets, sidewalks, open space and infrastructure that will not only provide aesthetically pleasing environments, but will also promote and support a wide variant of market driven land uses for many years into the future. The Regulating Plan establishes the infrastructure network and controls the planned land uses of the overall community. As noted on the plan, this community consists of single family residential, multiple family residential, mixed use, and commercial districts. The permitted uses in each district are described below.

General Use Type

As shown on the Regulating Plan, the community consists of four districts:

- Single Family Residential District
- Single Family Detached Only Residential District
- Mixed Use District
- Commercial District
- 8' Bituminous Bike/Safety Path

Residential Unit Chart (Unit, 3.54 DU/AC)

| | | | | | Total |
|--------------|--|--|--|--|------------|
| North Parcel | 90 | 19 | - | - | 109 |
| South Parcel | 242 | - | - | - | 308 |
| Total | 332 | 19 | 66 | - | 417 |

Commercial Space Chart (sq. ft.)

| | | | | | Total |
|--------------|--|--|--|--|----------------|
| North Parcel | - | - | 45,213 | 4,836 | 50,049 |
| South Parcel | - | - | 39,861 | 44,040 | 83,901 |
| Total | - | - | 85,074 | - | 133,950 |

This is a conceptual illustration of the overall site plan. The actual site plan may vary and will require approval by the Architectural Review Board and Hartland Township, subject to the regulations set forth in the Newberry Place Pattern Book.

Residential District

A. Permitted Principal Uses

1. Single family detached dwellings
2. Attached Style Condominium up to five (5) units per building
3. Duplex Motorcourt Condominiums
4. 4-6 Plex Motorcourt Condominiums
5. Garages will be attached
6. Public park and recreation areas

B. Variety of Design and Color

1. In order to ensure variety and diversity, a mix of elevations and color palettes will be required. To this end, the same elevation or color combination shall not be duplicated on the two homes either side of the house in questions. Homes across any street in any direction shall not be considered.

Single Family Detached Only Residential District

A. Permitted Principal Uses

1. Single family detached dwellings
2. Garages will be attached
3. Public park and recreation areas

B. Variety of Design and Color

1. In order to ensure variety and diversity, a mix of elevations and color palettes will be required. To this end, the same elevation or color combination shall not be duplicated on the two homes either side of the house in questions. Homes across any street in any direction shall not be considered.

Mixed Use District

A. Permitted Principal Uses

1. Single Family Detached Dwellings
2. Attached Style Condominium (up to five (5) units per building).
3. Duplex motorcourt condominiums
4. 4-6 Plex motorcourt condominiums
5. Garages will be attached for attached style condominium and single family detached homes located in the Mixed-Use District.
6. Multiple family (up to 14 units per building)
7. In a live-work unit, retail uses must be on the ground floor. Residential and office uses may be located on any floor.
8. Commercial use buildings shall conform to the uses permitted in the Township General Commercial Zoning District.

Commercial Use District

A. Permitted Principal Uses

1. Commercial District buildings shall conform to the uses permitted in the Township General Commercial Zoning District.



II. Site Regulation

Purpose and Overview


Site Regulations seek to produce a community in which the roads, streetscapes, useable open spaces and buildings work together to create a cohesive and complimentary development. This section provides conceptual illustrations and descriptions for building placement and public components of Newberry Place. Included herein are those guidelines that govern building placement including setbacks and projections; parking requirements; public spaces; street and bike/safety path plan; lighting; site furnishings; and waste enclosures. These site regulations will ensure a unified village design for Newberry Place.

Building Placement

The following drawings illustrate the site regulations for each of the five building types permitted in Newberry Place, including building placement, permitted projections, and anticipated number of stories, etc. The six permitted building types are:

- Single Family Detached
- Attached Style Condominium (single family attached)
- Duplex Motorcourt Condominiums
- 4-6 Plex Motorcourt Condominiums
- Mixed Use
- Commercial





This is a conceptual illustration of the single family lot regulations and home elevations. Actual lot layout and home elevations may vary and will require approval by the Architectural Review Board.



Projections – the following are permitted as indicated for both single family detached and single family attached:

- A front porch may encroach up to eight feet (8') into the required front yard setback. Porch steps up to four feet (4') wide may encroach an additional two- and one-half feet (2.5') for a total maximum encroachment of ten- and one-half feet (10.5') into the required front yard set back.
- Driveways are permitted to cross the front yard, side yard, or rear yard (alley load). Driveways for side entry garages may be located no closer than one foot (1') to a side yard lot line.
- Arbors & trellises are permitted with review and approval by the Architectural Review Board.
- Eaves are permitted to encroach up to two feet (2') in all setbacks.
- Fences are permitted in the rear yard or side yard, but not forward of the rear façade of the principal structure. Fences are not permitted in front or corner side yards. Fences may not exceed six feet (6') in height (See Walls and Fences – Architectural Regulations)

Single Family Lot Regulation

Single Family Detached Lots

| | |
|---|----------|
| Minimum lot area | 5,500 sf |
| Maximum lot coverage (Including paved areas) | 60% |
| Front yard setback | 15' |
| Side yard setback (Minimum 10' between buildings) | 5' |
| Corner side yard setback | 15' |
| Rear yard setback | 15' |
| Alley Setback | 10' |

Attached Style Townhome Condominiums (up to 5 units per building)

| | |
|---|------|
| Minimum lot area | None |
| Front yard setback | 15' |
| Side yard setback (Minimum 20' between buildings) | 10' |
| Corner side yard setback | 15' |
| Rear yard setback | 15' |
| Alley Setback | 10' |

Duplex Motor Court Condominiums

| | |
|---|------|
| Minimum lot area | None |
| Front yard setback | 15' |
| Side yard setback (Minimum 15' between buildings) | 7.5' |
| Corner side yard setback | 15' |
| Rear yard setback | 15' |


4-6 Plex Motor Court Condominiums

| | |
|---|------|
| Minimum lot area | None |
| Front yard setback | 15' |
| Side yard setback (Minimum 10' between buildings) | 5' |
| Corner side yard setback | 15' |
| Rear yard setback | 10' |

- Garages – Minimum 2 car (440 sq. ft.)
- Landscaping is permitted in all yards. Gardens cultivated for the production of food may not encroach in front, side, or corner side yards forward of the rear façade of the primary structure.
- Patio, terrace, or deck areas are permitted and may encroach into the rear yard setback up to ten feet (10')
- Pedestrian paving is permitted in any yard, providing that the pavement is at grade.
- Pools and hot tubs are permitted with review and approval of the Architectural Review Board.
- Parking for two vehicles is to be accommodated within the lot in either the garage, driveway, or some combination thereof.



Commercial District Diagram



Commercial District Lot Regulation

| | |
|--------------------|-----|
| Minimum lot width | N/A |
| Minimum lot area | N/A |
| Front Yard Setback | 0' |

Buildings with frontage along M-59 shall be set back eighty feet (80') from the right-of-way.

Buildings with frontage along Fenton Road or Pleasant Valley Road shall have a setback requirement of fifty feet (50') from the right-of-way.

| | |
|-------------------|----|
| Side Yard Setback | 0' |
| Rear Yard Setback | 0' |

The rear yard setback may be 0' when the building is adjacent to another commercial use. When adjacent to a residential use, a 50' minimum setback must be observed, unless a greenbelt screen is provided, then the minimum permitted setback is 30'.

Accessory structures – other than dumpster enclosures, are not permitted.


Projections – the following are permitted as indicated:

- Access drives are permitted at the front, side, and rear of the building.
- Arbors & trellises are permitted with review and approval by the Architectural Review Board.
- Awnings are permitted to encroach up to four feet (4') in all Newberry Place rights-of-ways.
- Fences are permitted with review and approval by the Architectural Review Board.
- Landscaping is permitted in all yards. Gardens cultivated for the production of food are not permitted.
- Decks and raised patios are permitted but must be located within the building envelope.
- Outdoor Seating for dining is permitted and shall comply with the most current Township Zoning Ordinance.
- Pedestrian paving, patios, and terraces are permitted in any yard, providing that the pavement is at grade.
- Play equipment is not permitted.
- Pools and hot tubs are not permitted.
- Signs are permitted in accordance with the Sign Regulations set forth in this Pattern Book.
- Parking is required as set forth in this Pattern Book.



This is a conceptual illustration of the commercial district site layout and building elevations. Actual site layout and building design may vary and will require approval by the Architectural Review Board.





Mixed Use Lot Regulations

| | |
|--|--------|
| Minimum lot width | N/A |
| Minimum lot area | N/A |
| Front Yard Setback | 0' min |
| <ul style="list-style-type: none"> • Exceptions to the setback requirement may be made for entry and architectural features with review and approval by the Architectural Review Board and the Township. • Buildings with frontage along M-59 shall be setback eighty feet (80') from the right-of-way. • Buildings with frontage along Fenton Road shall have a setback requirement of fifty feet (50') from the right-of-way. At the corner of Pleasant Valley and Fenton Road the setback shall be 50' from the existing right-of-way. | |
| Side Yard Setback | 0' min |
| Rear Yard Setback | 0' min |

The rear yard setback may be 0' when the building is adjacent to another commercial use. When adjacent to a residential use, a 50' minimum setback must be observed unless a green belt screen is provided, then the minimum permitted setback is 30'.

Single Family Detached and Attached Style Condominiums in the Mixed-Use District shall comply with the Lot Regulations as indicated on page 5.

Projections – the following are permitted as indicated:


- Access Drives are permitted at the front, side, and rear of the building.
- Arbors or trellises are permitted with review and approval by the Architectural Review Board.
- Awnings are permitted to encroach up to four feet (4') in all Newberry Place right-of-ways.
- Eaves and cornices may encroach up to two feet (2') in all setbacks.
- Fences for residential uses must comply with the residential fence regulations (see page 32).
- Fences for commercial uses must comply with the commercial fence regulations (see page 33).
- Landscaping is permitted in all yards. Gardens cultivated for the production of food are not permitted.
- At grade patios are permitted.
- Parking is required as set forth in this Pattern Book.
- Signs are permitted in accordance with the sign regulations set forth in this pattern book.



This is a conceptual illustration of the mixed use site layout and building elevations. Actual site layout and building design may vary and will require approval by the Architectural Review Board.



Mixed Use District Multiple Family Lot Regulations (Up to 14 Units Per Building)



| | |
|---|------|
| Minimum lot width | none |
| Minimum lot area | none |
| Front Yard Setback (Measured from the front of the building to the back of curb) | 30' |
| Side Yard Setback (Measured from the side of the building to the back of curb) | 30' |

Accessory structures are permitted with review and approval by the Architectural Review Board.

| | |
|------------------------------------|-----|
| Minimum distance between buildings | 20' |
|------------------------------------|-----|

| | |
|--|-----|
| Minimum distance between garages of opposing buildings when located on an alley access drive | 60' |
|--|-----|


Projections – the following are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner, in case of rental units) as indicated:

- Access Drives are permitted to cross the side yard when located on an alley.
- Arbors & trellises are permitted with review and approval by the Architectural Review Board.
- Awnings are not permitted.
- Eaves are permitted to encroach up to two feet (2') in all setbacks.
- Fences are permitted to screen patios.
- Pedestrian paving is permitted in any yard, providing that the pavement is at grade.
- Play equipment is not permitted.
- Pools and hot tubs are not permitted.
- Parking for two vehicles per dwelling unit are to be accommodated within the lot in either the garage, driveway, accessory building, auxiliary parking spaces, or some combination thereof.
- Accessory buildings (detached garages) may accommodate up to five (5) vehicles.



This is a conceptual illustration of the mixed-use district multiple family lot regulations and building elevations. Actual site layout and building design may vary and will require approval by the Architectural Review Board.





This is a conceptual illustration only.



Open Space Guidelines

Open space is comprised of flexible areas that provide Newberry Place with undeveloped land, recreation opportunities, and landscape screens. The open space situated throughout the development would include wetlands, woodlands, open fields, and other like areas, useable open space, and greenbelts.

- A. Residential Districts
Residential Districts shall provide a minimum of twenty five percent (25%) open space overall, which includes any greenbelts, and a minimum of ten percent (10%) useable open space overall.
- B. Commercial/Mixed Use Districts
The Commercial/Mixed Use districts shall provide a minimum of fifteen (15%) open space and a minimum of two percent (2%) useable open space overall.

** Regardless of the phases, the guidelines are meant for the overall development.

Usable Open Space Guidelines

Usable open space provides opportunities for both passive and active recreation.

- A. Residential
The Residential district shall provide a minimum of ten percent (10%) useable open space throughout the district.
- B. Commercial/Mixed use
The Commercial/Mixed use districts shall provide a minimum of two percent (2%) of useable open space.

Open Space Character

It is envisioned that usable open space found in Newberry Place will be developed in a variety of ways, including, but not limited to, the following:

- A. Natural Areas
Natural areas preserve the beauty of the site and provide an opportunity for passive uses such as, walking and nature observations. These areas should typically have some street frontage for access and primarily contained adjacent to and behind residential lots.

- B. Residential Open Space
Flexible park areas located throughout the Residential and Mixed Use (where residential uses predominate) districts can accommodate both passive and active uses. They should be located with street frontage and preferably face the front and/or sides of residences. The parks should help to organize the living spaces and act as outdoor "rooms" surround by residential uses. Occasionally, the parks could act as permeable buffers between residential areas and other uses.
- C. Urban Plazas
Usable open space in the Commercial district and adjacent to commercial uses in the Mixed Use district is envisioned as urban plazas, places where people gather, meet, rest, and enjoy the outdoors. Special attention is to be paid to the design, materials, furnishings, landscaping, and the intended use of these areas in order that they become vibrant space in the Commercial and Mixed Use districts.

The following enlargements illustrate the intent of various usable open spaces envisioned for Newberry Place.

Illustrative Open Space Diagrams

- Large Residential Park
- Urban Plaza Landscape
- Pocket Parks

Parking and Zoning Requirement


Parking and Loading requirements will comply with the most current Township Zoning Ordinance.



Urban Plaza Landscape

These are conceptual illustrations only. Actual open space and park design may differ and will require approval by the Architectural Review Board.






Central Park in Residential District

These is a conceptual illustration only. Actual open space and park design may differ and will require approval by the Architectural Review Board.





Legend

- 66' Entrance Street ROW
- Newberry Street ROW (60' Wide)
- Residential Street ROW (60' Wide)
- 16' Alley ROW
- 8' Bituminous Bike/Safety Path

This is a conceptual illustration of the street type guidelines. Actual street types may vary and will require approval by the Architectural Review Board.

Street Type Guidelines




Street Type Guidelines address road design and illustrate such features as on-street parking, lawn terraces, and sidewalks. Streets in Newberry Place have been categorized into five main street types as illustrated on the Street Types Map. Detailed elevations of each street type depicting the dimensions, right-of-way lines, and placement of buildings, pedestrian walks, lighting, landscaping, and parking can be referenced in this pattern book.



Sidewalk and Bike/Safety Path Guidelines

Connections to the regional bike path located in the M-59, Pleasant Valley, and Fenton Road right-of-ways are planned throughout Newberry Place. Within Newberry Place, young riders will be encouraged to use the sidewalks and more experienced riders to share the street with vehicular traffic.

- A. Sidewalks
Sidewalks shall be provided throughout Newberry Place.
- B. Sidewalk and Bike/Safety Path on M-59, Pleasant Valley, and Fenton Road
 1. All required bike paths along the north side of M-59, Pleasant Valley Road, and Fenton Road shall be bituminous, a minimum of eight feet (8') in width and shall be located one foot (1') off the property line in the road right-of-way.
 2. All required sidewalks along the south side of M-59 shall be concrete, a minimum of five feet (5') in width and shall be located one foot (1') off the property line in the road right-of-way.







Site Lighting Guidelines

Site Lighting is important to the ambiance of Newberry Place. Careful selection of light fixtures and levels of illumination are important in providing for the safety and comfort of residents and visitors. Pedestrian height street lighting is envisioned adjacent to streets in all Commercial and Mixed Use districts, as well as along the boulevards and Newberry street right-of-ways, including around the perimeter of parking lots while taller fixtures shall be used in the interior portions of the parking lots.

The following photos illustrate the types of fixtures that could be used at Newberry Place. Once a fixture is selected for the first phase, a fixture of similar design will be required for each subsequent phase.

The general lighting regulations will comply with the most current Township Zoning Ordinance.



Exterior Sconces



Building Sign Lighting



Street Lighting

These are conceptual illustrations only.





Bench Guidelines

Slats: 5/8" diameter steel bar
 Supports: Cast iron
 Fasteners: Stainless Steel
 Finish: Black, powdercoat



Planter Guidelines

Materials: Terra Cotta, durable simulated Terra Cotta
 Size: varies

Site Furnishing Guidelines

Site furnishings throughout the development are envisioned as a coordinated system that further develops the character and cohesion of the Newberry Place community. The style, materials and finishes of the site furnishings have been selected to complement the scale, style, and materials of the architecture envisioned for Newberry Place. Site furnishings include by way of example, items such as: pedestrian waste receptacles, benches, planters, and bike hoops. To the extent these furnishings could be used in street right of ways, community buildings, throughout the Commercial, Mixed Use, and Residential district and useable open spaces, they shall be consistent with these guidelines. Once furnishings have been selected in the first phase of development, furnishings of similar design will be required for each subsequent phase. The following photos illustrate the general types of furnishings for use at Newberry Place.



Waste Receptacle Guidelines

Slats: 5/8" diameter steel bar
 Reveal Strip: 1/4" x 3" steel bar
 Cover: 14-gauge spun steel with 10" diameter opening secured with vinyl-coated cable
 Liner: 22 or 32 gallon plastic
 Finish: Black, powdercoat



Bike Hoop Guidelines

Frame: 2 3/8" x 11-gauge galvanized steel tube bar
 Finish: Black, powdercoat

Ponds and Dumpster Enclosure Guidelines

Ponds and Dumpster Enclosure guidelines will comply with the most current Township Zoning Ordinance.

These are conceptual illustrations only.



III. Architectural Guidelines

Purpose and Overview

Architectural Regulations pertain to those guidelines that govern building design and details, thereby ensuring attractive and cohesive structure. Buildings in Newberry Place have been categorized into two main types: residential and commercial. There are five (5) types of residential buildings: single family detached, attached style condominiums, duplex motor court condominiums, 4-6 plex motor court condominiums, and multiple family dwellings. Commercial and mixed-use commercial buildings shall comply with Group #1 commercial architectural standards in the most current Township Zoning Ordinance. Any deviations from the Group #1 architectural standards shall comply with the Newberry Place Pattern Book.

Residential - Single Family Detached

The conceptual building elevations for the Single Family detached homes, which were prepared by Mayberry Homes, are contained in this section. These elevations are intended to illustrate the proposed architectural style envisioned for Newberry Place. The following descriptions are intended to point out features for these buildings, which may not be apparent from the conceptual building elevations. Should there be a conflict between the drawing and the following the descriptions, the written description is to be adhered to.

Height

Maximum building height: 3 stories or 35', whichever is less. Height measured to the eave of the roof.

Minimum ceiling heights:

- 1st floor – eight feet (8')
- 2nd floor – eight feet (8')

Roofs

Roofline

- Gabled or hipped with the main roof at five (5) in twelve (12) minimum pitch and twelve (12) in twelve (12) maximum pitch
- Flat or lower pitches may be used as accents and/or over bays, stoops, or porches.

Roof Material

- Dimensional shingle
- Cedar shakes, copper, earth tone painted standing seam can be used as accents over bays, stoops, or porches
- Flat glass skylights are permitted where they are not visible from the street on which the dwelling fronts

Doors

Front Doors (or entrances that are visible to the street on which the dwelling fronts)

- Stained or painted wood
- Fiberglass, stained, or painted
- Wood screen doors (dark metal or plastic screening)
- Glass or decorative moldings consistent with elevations
- Aluminum

Other Doors

Material acceptable for front doors

- Flush or embossed steel door
- Wood or aluminum screen door (dark metal or plastic screening)

Garage Doors

- Embossed steel sectional doors or equivalent approved by the Architectural Review Board
- Wood paneled doors
- Glass or decorative moldings consistent with elevation.

Windows

Framing

- Aluminum clad wood
- Vinyl or vinyl clad

Glass

- Clear Glass
- Muntins as accents (either true divided, inside or behind glass in white or color of frame)
- Stained or leaded glass as accents
- Window screens matching frame color with dark metal or plastic screening may be added
- Frosted or obscure glass for privacy areas

Building Walls

1. Horizontal/Vertical vinyl, cementitious, or wood siding – Max. 100%
 2. Brick - Max. 100%
 3. Shake (vinyl, wood, or simulated wood) – Max. 25%
 4. Stone – Max. 100%
- * Siding, brick, shake and stone material % excludes door and windows

Decks and Porches

- Wood or composite decking
- Wood, vinyl, aluminum, or wrought iron railings appropriate to the elevation

Walls and Fences

- Wood or vinyl posts, pickets, lattice, and boards
 - Wrought iron
- (see page 26 for Wall and Fence Guidelines)

Architectural Features

- The open undercroft of all front porches shall be enclosed.
- Trim, on frame walls, shall be boards 3-1/2" minimum at openings and four inches (4") minimum at corners

- Foundation walls, which are exposed greater than twelve inches (12"), shall be brick, stone, decorative block, or sided with permanent siding.

Chimneys:

- Brick, stone, or siding material that matches the main building. (Panel brick or thin cut veneer stone are acceptable chimney materials).
 - Shall include a decorative top
- A metal flue or vent up to twelve-inch (12") diameter on the rear portion of a roof is permitted and shall not be considered a chimney. The maximum height of such flue shall not exceed the minimum height required by the applicable building code or Township ordinance.

Driveways

- Acceptable materials include concrete, brick, and paving stone
- Parking pads visible from the street on which the residence is located are not to be wider than the garage door opening plus two feet (2') total

Parking Requirements

The Single Family detached Lot Diagram identifies locations permitted for parking on Single Family detached lots.

Private Walks/Patios

- Acceptable materials include concrete, brick, and paving stone
- Private walk's maximum width is six feet (6'), however, a minimum three-foot (3') walk is encouraged.





MABEL



MARCEL



MANSFIELD



TRENTON



Inspiration (Alley Load)

These are conceptual illustrations only. Actual home designs may vary and will require approval by the Architectural Review Board.






WINDSOR



MAPLEWOOD



These are conceptual illustrations only. Actual home designs may vary and will require approval by the Architectural Review Board.



Residential – Attached Condominium

Attached style condominiums, which were prepared by Mayberry Homes, are contained in this section. These elevations are intended to illustrate the proposed architectural style envisioned for Newberry Place. The following descriptions are intended to point out features for these buildings, which may not be apparent from the conceptual building elevations. Should there be a conflict between the drawing and the following and the descriptions, the written description is to be adhered to.

Height

Maximum building height: 3 stories or 35', whichever is less. Height measured to the eave of the roof.

Minimum ceiling heights:

- 1st floor (main living floor) – eight feet (8')
- 2nd floor eight feet (8').

Roofs

Roofline

- Gabled or hipped with the main roof at five (5) in twelve (12) minimum pitch and twelve (12) in twelve (12) maximum pitch.
- Flat or lower pitches may be used as accents and/or over bays, stoops, or porches.

Roof Material

- Dimensional shingle
- Cedar shakes, copper, earth tone painted, or standing seam can be used as accents over bays, stoops, or porches.
- Flat glass skylights are permitted where they are not visible from the street on which the dwelling fronts.

Doors

Front Doors

- Stained or painted wood.
- Fiberglass or other wood-like material, stained, or painted.
- Wood screen doors (dark metal or plastic screening).
- Glass or decorative moldings consistent with elevations
- Aluminum

Other Doors

- Materials acceptable for front doors
- Flush or embossed steel doors
- Wood or aluminum screen door (dark metal or plastic screening)

Garage Doors

- Embossed steel sectional doors or equivalent approved by the Architectural Review Board
- Wood paneled doors
- Glass or decorative moldings

Windows

Framing

- Aluminum clad wood
- Vinyl or vinyl clad

Glass

- Clear glass
- Muntins as accents (either true divided, inside or behind glass in white or color of frame).
- Stained or leaded glass as accents.
- Window screens matching frame color with dark metal or plastic screening may be added.

Building Walls

Single Family Residential District Facades:

- Same as Residential – Single Family Detached

Mixed-Use Single Family Attached and Single Family Detached

Facades facing a public or private right-of-way, excluding alleys:

- Horizontal/Vertical vinyl, cementitious, or wood siding – Max. 70%
- Brick or stone – Min. 20% (Maximum 100%)
- Shake (vinyl, wood, or simulated wood) – Max. 30%

All other facades:

- Same as Residential – Single Family Detached

Decks and Porches

Decks and porches are permitted provided they are not part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- Wood or composite decking
- Wood, vinyl, aluminum, or wrought iron railings appropriate to the elevation

Walls and Fences

Walls and fences are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- Wood or vinyl posts, pickets, lattice, and boards.
- Metal and brick as accents.

(see page 26 for Walls and Fence Guidelines)

Architectural Features

Architectural features are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- The open undercroft of all front porches shall be enclosed.
- Trim, on frame walls, shall be boards four inches (4") minimum at openings and six inch (6") minimum at corners.
- Foundation walls, which are exposed greater than twelve inches (12"), shall be brick, stone, decorative block, or sided with permanent siding.

Chimneys

- Brick, stone, or vinyl material that matches the main building (panel brick or thin cut veneer stone are acceptable chimney materials)
- Shall include a decorative top.
- A metal flue or vent up to twelve-inch (12") diameter on the rear portion of a roof is permitted and shall not be considered a chimney. The maximum height of such flue shall not exceed the minimum height required by the applicable building code or the most current Township Ordinance.

Driveways

- Acceptable materials include bituminous, concrete, brick, and paving stone.
- Parking pads visible from the street on which the residence is located are not to be wider than the garage door opening plus two feet (2') total.

Private Walks/Patios

- Acceptable materials include concrete, brick, and paving stone.
- Maximum width is six foot (6'), however, a minimum three-foot (3') walk is encouraged.



Attached Style Condominium (Up to 5 Units Only)



Front Elevation

Front Elevation

Horizontal/vertical siding – 30%
 Shake siding - 12%
 Manufactured stone – 21%
 Windows – 31%
 Doors – 6%

Left Elevation

Horizontal/vertical siding – 96%
 Windows – 4%



Left Elevation



Right Elevation

Right Elevation

Horizontal/vertical siding – 91%
 Windows – 4%
 Doors – 5%



Rear Elevation

Rear Elevation


Horizontal/vertical siding – 62%
 Windows – 11%
 Doors – 27%

- This is a conceptual illustration of a townhouse residence. Actual building design may differ and will require approval by the Architectural Review Board.
- Manufactured stone illustrates mixed-use district facades facing a public or private right of way.

Duplex Motor Court Homes



Front Elevation





• This is a conceptual illustration of a duplex quad motor court residence. Actual building design may differ and will require approval by the Architectural Review Board.

4-6 Plex Motor Court



Front Elevation



- This is a conceptual illustration of a duplex quad motor court residence. Actual building design may differ and will require approval by the Architectural Review Board.

Commercial & Mixed Use Commercial

The conceptual building elevations for the Commercial buildings, which were prepared by Mayberry Homes, are contained in this section. These elevations are intended to illustrate the proposed architectural style envisioned for Newberry Place. The following descriptions are intended to point out features for Commercial buildings and Senior Care buildings in both the Mixed Use and Commercial areas, which may not be apparent from the conceptual building elevations and areas where proposed buildings may differ from the conceptual building elevations. Should there be a conflict between the drawing and the following the descriptions, the written description is to be adhered to.

Height

Maximum building height: 3 stories or 35', whichever is less. Height measured to the eave of the roof.

Minimum ceiling heights:

- 1st floor – nine feet (9') to the underside of the roof truss (or second floor truss).
- 2nd floor – eight feet (8') to the underside of the roof truss

First Floor Elevation: should be at grade in areas of public ingress and egress.

Roofs

Roofline

- Gabled or hipped with the main roof at six (6) in twelve (12) minimum pitch and twelve (12) in twelve (12) maximum pitch.
- Flat with parapet walls and/or sloped decorative elements on gabled or hipped roofs designed to hide rooftop mechanical units

Roof Material

- Dimensional shingles on gable or hipped roofs
- Copper or earth tone painted standing seam can be used as accents over bays, stoops, or porches
- Other accent colors or finishes such as galvanized steel, black, or gray tones may be used subject to approval of the Architectural Review Board.
- Colors of roof will be per the most current Township Zoning Ordinance.

Doors

Front Doors (or other entrances used by customers or that are visible from the street on which the building fronts)

- Metal and glass commercial glazing system
- Entry doors may be stained or painted wood (or wood like material) with or without glass

Other Doors

- Materials acceptable for front doors
- Flush or embossed steel doors, painted

Windows

Framing

- Metal and glass commercial glazing system
- Aluminum or vinyl "residential" style windows permitted on the second floor, in dormers, or other architectural elements on or above the second floor

Glass

- Commercial glazing
- Clear or lightly tinted glass
- Reflective glass is not permitted
- Residential style windows
- Clear glass
- Muntins as accents (either true divided, inside or behind the glass in white or color of the frame)
- Window screens matching frame color with dark metal or plastic screening may be added

Building Walls

1. Brick (natural clay) min. 40% - max. 100%
 2. Stone (natural or cast) max. 50%
 3. Siding (wood, vinyl, cementitious, or shake) max 10%
- * Any façade material not listed shall comply with the Group #1 commercial architectural standards of the most current Township Zoning Ordinance.

Walls and Fences

- Metal, brick, masonry, stone, or combination as reviewed and approved by the Architectural Review Board (see page 27 for Wall and Fence Guidelines)

Architectural Features

- Awnings and projections over doors or windows made primarily of metal
- Molding details of wood, metal, or EIFS
- Ornamental details of wood, brick, stone, metal, or EIFS on wall of buildings
- All architectural features shall comply with the Group #1 commercial architectural standards of the most current Township Zoning Ordinance

Parking Requirements

Parking requirements shall comply with the most current Township Zoning Ordinance

Sidewalks

- Acceptable materials include concrete, brick, and paving stone.
- Minimum width of five feet (5') unless adjacent to a parking area, in which case the minimum width of the sidewalk shall be seven feet (7')



Commercial – Office / Residential (Mixed Use)



Front Elevation

Front Elevation
 Brick/Decorative Block - 45%
 Panel System – 9%
 Horizontal Siding – 7%
 Windows – 30%
 Doors – 9%



Left Elevation
 Brick/Decorative Block - 43%
 Panel System – 10%
 Horizontal Siding – 16%
 Windows – 32%
 Doors – 0%

Right Elevation
 Brick/Decorative Block - 43%
 Panel System – 10%
 Horizontal Siding – 16%
 Windows – 32%
 Doors – 0%

Left Elevation

Right Elevation



Rear Elevation

Rear Elevation
 Brick/Decorative Block - 40%
 Panel System – 2%
 Horizontal Siding – 11%
 Windows – 32%
 Doors – 14%

This is a conceptual illustration of a commercial building, actual building design may differ, and will require approval by the Architectural Review Board.

Commercial (Mixed Use)



Front Elevation

Front Elevation

Brick/Decorative Block - 46%
 Panel System - 10%
 Horizontal Siding - 0%
 Windows - 37%
 Doors - 7%



Left Elevation

Left Elevation

Brick/Decorative Block - 56%
 Panel System - 9%
 Horizontal Siding - 11%
 Windows - 23%
 Doors - 2%



Right Elevation

Right Elevation

Brick/Decorative Block - 56%
 Panel System - 9%
 Horizontal Siding - 11%
 Windows - 23%
 Doors - 2%



Rear Elevation

Rear Elevation

Brick/Decorative Block - 57%
 Panel System - 1%
 Horizontal Siding - 0%
 Windows - 35%
 Doors - 7%

This is a conceptual illustration of a commercial building, actual building design may differ, and will require approval by the Architectural Review Board.

Commercial (Commercial District)



Front Elevation

Front Elevation
 Brick/Decorative Block - 47%
 Panel System - 9%
 Horizontal Siding - 0%
 Windows - 39%
 Doors - 6%

Right Elevation
 Brick/Decorative Block - 55%
 Panel System - 9%
 Horizontal Siding - 0%
 Windows - 33%
 Doors - 2%



Left Elevation

Left Elevation
 Brick/Decorative Block - 55%
 Panel System - 9%
 Horizontal Siding - 0%
 Windows - 33%
 Doors - 2%



Right Elevation



Rear Elevation

Rear Elevation
 Brick/Decorative Block - 46%
 Panel System - 6%
 Horizontal Siding - 0%
 Windows - 42%
 Doors - 7%



This is a conceptual illustration of a commercial building, actual building design may differ, and will require approval by the Architectural Review Board.
 Architectural Guidelines – Commercial and Mixed Use

Mixed Use – Multiple Family

The conceptual building elevations for the Multiple Family residential units, which were prepared by Mayberry Homes, are contained in this section. These elevations are intended to illustrate the proposed architectural style envisioned for Newberry Place. The following descriptions are intended to point out features for these buildings, which may not be apparent from the conceptual building elevations. Should there be a conflict between the drawing and the following descriptions, the written description is to be adhered to.

Height

Maximum building height: 3 stories or 35', whichever is less. Height measured to the eave of the roof.

Minimum ceiling heights:

- 1st floor (main living floor) – eight feet (8')
- 2nd floor eight feet (8').

Accessory structures shall not exceed fifteen feet (15') to the midpoint of the gable.

Roofs

Roofline

- Gabled or hipped with the main roof at five (5) in twelve (12) minimum pitch and twelve (12) in twelve (12) maximum pitch.
- Flat or lower pitches may be used as accents and/or over bays, stoops, or porches.

Roof Material

- Dimensional shingle
- Cedar shakes, copper, earth tone painted, or standing seam can be used as accents over bays, stoops, or porches.
- Flat glass skylights are permitted where they are not visible from the street on which the dwelling fronts.

Doors

Front Doors (or otherwise visible from the street)

- Stained or painted wood.
- Fiberglass or other wood-like material, stained, or painted.
- Wood screen doors (dark metal or plastic screening).
- Glass or decorative moldings.

Other Doors

- Materials acceptable for front doors.
- Flush or embossed steel door.
- Wood or aluminum screen door (dark metal or plastic screening).

Garage Doors

- Embossed steel sectional doors or equivalent approved by the Architectural Review Board.
- Wood paneled doors.
- Glass or decorative moldings consistent with the elevation.

Windows

Framing

- Aluminum clad wood
- Vinyl or vinyl clad

Glass

- Clear glass
- Muntins as accents (either true divided, inside or behind glass in white or color of frame).
- Stained or leaded glass as accents.
- Window screens matching frame color with dark metal or plastic screening may be added.

Building Walls

1. Horizontal/Vertical vinyl, cementitious, or wood siding – Max. 70%
2. Brick or stone – Max. 100%
 - Front elevation - Min. 20%
 - Side elevation – Min. 10%
 - Rear elevation – Min. 5%
3. Shake (vinyl, wood, or simulated wood) – Max. 30%

All other facades:

- Items not listed are subject to the Group #1 Commercial Architectural Standards of the most current Township Zoning Ordinance.

Decks and Porches

Decks and porches are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- Wood or composite decking.
- Wood, vinyl, aluminum, or wrought iron railings appropriate to the elevation.

Walls and Fences

Walls and fences are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- Wood or vinyl posts, pickets, lattice, and boards.
- Metal and brick as accents.
- Wrought iron

(see page 29 for Wall and Fence Guidelines)

Architectural Features

Architectural features are permitted provided they are part of the original design or a renovation plan proposed by the condominium association (or owner in the case of a rental unit).

- The open undercroft of all front porches shall be enclosed.
- Trim, on frame walls, shall be boards four inches (4") minimum at openings and six inch (6") minimum at corners.
- Foundation walls, which are exposed greater than twelve inches (12"), shall be brick, stone, decorative block, or sided with permanent siding.

Chimneys

- Brick, stone, or siding material that matches the main building (panel brick or thin cut veneer stone are acceptable chimney materials)
- Shall include a decorative top.
- A metal flue or vent up to twelve inch (12") diameter on the rear portion of a roof is permitted and shall not be considered a chimney. The maximum height of such flue shall not exceed the minimum height required by the applicable building code or the most current Township Ordinance.

Accessory Buildings

(only allowed in Multiple Family Residential District up to 14 Units per building only)

- Accessory buildings must match the architecture and be built of materials similar to the principal building. They shall have roof breaks a minimum of every forty feet (40').

Driveways

- Acceptable materials include bituminous, concrete, brick, and paving stone.
- Parking pads visible from the street on which the residence is located are not to be wider than the garage door opening plus two feet (2') total.

Parking Requirements

The Multiple Family Lot Diagram identifies locations permitted for parking on Multiple Family lots.

Private Walks/Patios

- Acceptable materials include concrete, brick, and paving stone.
- Maximum width is six foot (6'), however, a minimum three-foot (3') walk is encouraged.



Three Unit Apartment Building – Mixed-Use Multiple Family Residential



Front Elevation
 Horizontal siding – 33%
 Manufactured stone – 20%
 Windows – 32%
 Doors – 15%



Left Elevation
 Horizontal siding – 65%
 Manufactured stone – 15%
 Windows – 14%
 Doors – 6%

Left Elevation



Right Elevation
 Horizontal siding – 53%
 Manufactured stone – 17%
 Windows – 22%
 Doors – 8%

Right Elevation



Rear Elevation
 Horizontal siding – 35%
 Manufactured stone – 8%
 Windows – 11%
 Doors – 46%

Rear Elevation

This is a conceptual illustration of a multiple family residence, actual building design may differ, and will require approval by the Architectural Review Board.



Five Unit Apartment Building – Mixed-Use Multiple Family Residential



Front Elevation

Front Elevation

Horizontal siding – 39%
Manufactured stone – 20%
Windows – 32%
Doors – 10%



Left Elevation

Left Elevation

Horizontal siding – 65%
Manufactured stone – 15%
Windows – 14%
Doors – 6%



Right Elevation

Right Elevation

Horizontal siding – 40%
Manufactured stone – 26%
Windows – 14%
Doors – 12%



Rear Elevation

Rear Elevation

Horizontal siding – 38%
Manufactured stone – 7%
Windows – 14%
Doors – 40%

This is a conceptual illustration of a multiple family residence, actual building design may differ, and will require approval by the Architectural Review Board.

Ten Unit Apartment Building – Mixed-Use Residential



Front Elevation

Front Elevation

Horizontal/vertical siding – 34%
 Shake siding – 8%
 Manufactured stone – 23%
 Windows – 22%
 Doors – 13%



Left Elevation

Left Elevation

Horizontal/vertical siding – 52%
 Manufactured stone – 23%
 Windows – 14%
 Doors – 12%



Right Elevation

Right Elevation

Horizontal/vertical siding – 52%
 Manufactured stone – 23%
 Windows – 14%
 Doors – 12%



Rear Elevation

Rear Elevation

Horizontal/vertical siding – 31%
 Shake siding – 7%
 Manufactured stone – 13%
 Windows – 14%
 Doors – 35%

This is a conceptual illustration of a multiple family residence, actual building design may differ, and will require approval by the Architectural Review Board.

Walls & Fences

Newberry Place is envisioned as an open community with few walls or fences. Where permitted or required by this Pattern Book, walls and fences shall be subject to the requirements in this section. An obscuring wall or fence is one where more than seventy-five (75%) percent of the vertical surface is opaque so as to obstruct vision or prevent observation of activities enclosed in the fence.

General Wall and Fence Specifications

A. Landscape Screen

Wherever possible, a landscape screen, comprised of living plant material (such as closely spaced evergreens), should be used rather than a wall or fence. As a substitute for a required landscape screen, with review and approval of the Architectural Review Board the use of an obscuring wall or fence may be used provided that it would produce substantially the same result in terms of screening.

B. Height

The height of a wall or fence shall be measured from ground level adjacent to the wall or fence, provided that fill shall not be permitted for the purpose of achieving a higher fence than otherwise would be permitted.

C. Visibility

Walls and fences shall not obstruct visibility of pedestrian and vehicular circulation.

D. Wall Materials

Walls shall be constructed of durable materials that are architecturally compatible with the materials used on the façade of the principal structure on the site, such as face brick, decorative blocks, or stone. No grey cinder block will be permitted.

E. Fences shall consist of materials commonly used in conventional fence construction, such as vinyl or metal, as approved by the Architectural Review Board. Chain link fences and razor wire shall not be permitted.

F. Within 2' of Property Line

If a fence or wall is located on a property line or within two feet (2') of a property line, then both sides of the fence shall have a finished appearance, or the finished side of the fence shall face the exterior of the lot.

Residential Areas and Residential Components of Mixed Use Areas

A. Fences are permitted in residential areas as follows:

1. Single Family Detached

- Fences may be located in a required rear yard.
- Fences may be located in a side yard, but not forward of the rear façade of the principal structure, unless approved by the Architectural Review Board.
- Fences may not be located in front or corner side yards, unless approved by the Architectural Review Board.

2. Attached Style Condominiums

- Fences may be located in a required rear yard.
- Fences may be located in a side yard, but not forward of the rear façade of the principal structure, unless approved by the Architectural Review Board.
- Fences may not be located in front yards or corner lot side yards, unless approved by the Architectural Review Board.

3. Multiple Family

- Fences to screen patios, must be located within the building area.

B. Fence Height

Obscuring fences may not exceed four feet (4') in height and are permitted upon the review and approval of the Architectural Review Board.

C. Wall Height

Walls not exceeding four feet (4') in height are permitted upon the review and approval of the Architectural Review Board.

D. Front & Side Yard Fence Height

Any fence permitted by the Architectural Review Board in the front yard, corner lot, or side yard (forward of the rear façade of the principal structure), may not exceed three feet (3') in height.

The following illustrations have been developed to guide the design of walls and fences in Newberry Place:



Wrought Iron Fence



Vinyl Fence

These are conceptual images only. Actual Wall and Fence Design may differ and will require approval by the Architectural Review Board.



Commercial Areas

A. Screen Walls

Walls are required to screen waste enclosures and loading areas, and shall be designed to meet the current Township Standards.

1. Six foot (6') high screen walls are required to screen all exterior trash enclosures and may be used in place of a landscape screen in a required greenbelt screen. All walls shall be masonry material compatible with the building, finished on both sides, and must meet the standards of the most current Township Zoning Ordinance.

B. Fences

Fences may be permitted as an accessory element for mixed use and commercial buildings subject to review and approval of the Architectural Review Board.

1. Fences shall be metal fences of simple picket style, maximum thirty-six-inch (36") height with wrought iron or a black powder coat finish.
2. Fences may be used for enclosing outdoor dining areas, outdoor/open air displays and sales areas, or as decorative enclosures of urban plazas.

C. Right of Way

Fences and walls are not envisioned within the right-of-ways in Newberry Place. However, if a fence or wall is integral to the desired use, a fence or wall may be permitted with the review and approval of the Architectural Review Board.

1. Walls and fences in public areas may not exceed three feet (3') in height.

D. Entrances to Newberry Place

Entrance structures, such as walls, columns, or gates which mark the entrance to Newberry Place, shall be permitted in the required setback area, provided that:

1. Entranceway structures shall not exceed twelve feet (12') in height.
2. Entranceway structures shall not be located in the existing right-of-way of M-59, Fenton Road or Pleasant Valley and shall be setback on foot (1') from the right-of-way.

3. Such structures shall not restrict emergency vehicle access.

*See illustrations on pages 28 and 29.

E. Park Urban Plazas

Walls and fences may be permitted in parks/urban plazas with review and approval of the Architectural Review Board.

1. Fences, poured concrete/masonry seat walls or masonry garden walls may be used in Urban Plazas. Seat walls shall be a maximum of twenty inches (20") in height. Garden walls shall be a maximum of thirty-six inches (36") in height. Fences shall be wrought iron or black powder coat finish metal fences of simple picket style, maximum thirty-six inches (36") in height.

The following illustrations have been developed to guide the design of walls and fences in Newberry Place.

- Commercial and Mixed-Use Walls and Fences
- Landmark Corner Design
- Entry Wall and Pier Design



Commercial and Mixed Use Fence



Commercial and Mixed Use Wall

These are conceptual images only. Actual Wall and Fence Design may differ and will require approval by the Architectural Review Board.




Landmark Corner Sign




These are conceptual illustrations only. The actual design may differ and will require approval by the Architectural Review Board.





HARTLAND, MI
DEVELOPMENT PROPOSAL


NEWBERRY PLACE • ENTRY WALL & PIER DESIGN - FRONT VIEW
Main Street Facade



NEWBERRY PLACE • ENTRY WALL & PIER DESIGN - SIDE VIEW

NOTE:
These signs and wall signs shall comply with the most current zoning ordinance and sign regulations.

These are conceptual illustrations only. Actual Entry Wall and Pier Design may differ and will require approval by the Architectural Review Board.



Plan View



NEWBERRY PLACE · ENTRY WALL & PIER DESIGN
Main Street Facade



These are conceptual illustrations only. Actual Entry Wall and Pier Design may differ and will require approval by the Architectural Review Board.



IV. Landscape Regulations

Landscaping enhances the visual image of Newberry Place. The landscape regulations provide guidance for landscaping of Commercial, Mixed Use, and Residential areas, landscaping adjacent to public roads, landscaping of private road right-of-ways, and greenbelt screens. Some benefits of landscaping include the preservation of natural features, improved property values, the alleviation of the negative impacts of noise and traffic, and visual distractions associated with certain uses. Screening is used occasionally to protect residential uses from incongruent, more intensive non-residential uses. Following are the minimum regulations for the design and use of landscaping throughout the district. The Architectural Review Board/Hartland Township Planning Commission may require additional plantings to address site specific issues such as screening and buffering, when the minimum requirement is not adequate to address the concern.

General Landscape Regulations

The following are general landscape regulations that at minimum must be adhered to throughout Newberry Place.

- A. All landscaping shall meet or exceed Hartland Township's current zoning ordinance requirements unless described otherwise within this document.
- B. All plant material must meet or exceed Hartland Township's current zoning ordinance.
- C. All unpaved portions of the site shall be planted with grass (hydro-seed or sod), ground cover, shrubbery, or other suitable live plant material, which shall extend to any abutting pavement edge.
- D. Any fractional plant requirements shall be rounded up.
- E. All shrub, perennial, and groundcover beds shall be planted with minimum size plants as specified and with spacing to achieve a full mass without voids within two growing seasons. Annual beds shall be planted with a spacing to achieve a full mass without voids by mid-season.

- F. An in-ground irrigation/sprinkler system is required in the Commercial and Mixed Use Districts.
- G. Landscaping adjacent to public right of ways and greenbelts shall be planted, as outlined below and shall be maintained by the owner or occupant of the adjacent property as if the right-of-ways or greenbelts were part of the required landscaped area.
- H. Corner Landmark Landscape (at the intersection of M-59 and Pleasant Valley/Fenton Road). Landmark Corner requirements extend a minimum of one hundred and eighty-five feet (185') from the back of curb in each direction from the corner.

Residential Landscape (includes single family detached, attached style condominiums, and multiple family)

Unless otherwise specified, required landscaping elsewhere in these districts shall not be counted in meeting these requirements.

- A. Unless otherwise specified, required landscaping elsewhere in these districts shall not be counted in meeting these requirements.
- B. Live/Work Units are subject to the same requirements as the attached style condominiums and multi-family landscape requirements when this building type is used for a Live/Work Unit.
- C. A minimum of two (2) deciduous or evergreen trees plus four (4) shrubs shall be planted per dwelling unit in the Townhouse Style Condominium (Single Family Attached) dwellings.

Commercial Landscape (includes mixed use and commercial)

- A. A mixture of evergreen and deciduous trees shall be planted in Commercial and Mixed Use districts at the minimum rate of one (1) tree per 3,000 square feet or portion thereof of any unpaved open area for which there are no other specific landscaping requirements. Required trees may be planted at uniform intervals, at random, or in groupings.
- B. All landscaping shall meet or exceed Hartland Township's current zoning ordinance unless described otherwise within this document.

Public Realm

The public realm is comprised of those areas within Newberry Place that are accessible to all. They include (but are not limited to) the private road right-of-ways, landscape adjacent to public roads, and open space, including greenbelts.

- A. Private Right of Way
Landscaping within the private road right of ways shall be in accordance with the regulations set forth on the following drawings.
 - 110' Boulevard Landscape
 - 100' Boulevard Landscape
 - Newberry Street Landscape
 - Residential Street Landscape

Please refer to the Street Type Guidelines plan for these categories.



Site Landscape Plan



- Greenbelt Landscape Buffers
- Parking Buffer/Screening
- Lots
- Open Space
- Detention Pond
- Wetland
- Usable Open Space
- Tri Plex
- Commercial Buildings

PLANT GUIDE

TREES


- | | | | |
|--|---|--|---|
| | Weeping Alaskan Cedar - <i>Chamaecyparis nootkatensis</i> 'Pendula' | | Royal Raindrops Crab - Malus 'Royal Raindrops' |
| | Weeping Hemlock - <i>Tsuga canadensis</i> 'Pendula' | | Cleveland Select Pear - <i>Pyrus calleryana</i> 'Cleveland Select' |
| | Norway Spruce - <i>Picea abies</i> | | Frans Fontaine Hornbeam - <i>Carpinus betulus</i> 'Frans Fontaine' |
| | Black Hills Spruce - <i>Picea glauca</i> 'Densa' | | Skyline Honeylocust - <i>Gleditsia tricanthos inermis</i> 'Skycole' |
| | Lavender Twist Red Bud - <i>Cercis canadensis</i> 'Covey' | | Autumn Blaze Maple - <i>Acer freemanii</i> 'Autumn Blaze' |
| | Crimson Queen Laceleaf Japanese Maple - <i>Acer palm. diss.</i> 'Crimson Queen' | | |

SHRUBS

- | | | | |
|--|--|--|--|
| | Arrowwood Viburnum - <i>Viburnum dentatum</i> | | Green Velvet Boxwood - <i>Buxus</i> x 'Green Velvet' |
| | Lynwood Gold Forsythia - <i>Forsythia</i> x <i>intermedia</i> 'Lynwood Gold' | | Wine & Roses Weigela - <i>Weigela florida</i> 'Alexandra' |
| | Bridal Wreath Spirea - <i>Spirea</i> x <i>vanhouttei</i> | | Dwarf Burning Bush - <i>Euonymus alatus</i> 'Compactus' |
| | Sea Green Spreading Juniper - <i>Juniperus chinensis</i> 'Sea Green' | | Skyrocket Upright Juniper - <i>Juniperus virginiana</i> 'Skyrocket' |
| | Goldflame Spirea - <i>Spirea japonica</i> 'Goldflame' | | Rosy Glow Barberry - <i>Berberis thunbergii</i> 'Rosy Glow' |
| | Woodward Globe Arborvitae - <i>Thuja occidentalis</i> 'Woodward' | | Little Devil Ninebark - <i>Physocarpus opulifolius</i> 'Little Devil' |
| | Yellow Ribbon Arborvitae - <i>Thuja occidentalis</i> 'Yellow Ribbon' | | Hetz Midget Globe Arborvitae - <i>Thuja occidentalis</i> 'Hetz Midget' |
| | Koreanspice Viburnum - <i>Viburnum carlesii</i> | | Blue Star Juniper - <i>Juniperus squamata</i> 'Blue Star' |
| | Compact Inkberry Holly - <i>Ilex glabra</i> 'Compacta' | | Fine Line Buckthorn - <i>Rhamnus frangula</i> 'Ron Willians' |

PERENNIALS

- | | |
|--|--|
| | Grosse Fontaine Maiden Grass - <i>Miscanthus sinensis</i> 'Grosse Fontaine' |
| | Heavy Metal Switch Grass - <i>Panicum virgatum</i> 'Heavy Metal' |
| | Shasta Daisy Snow Cap - <i>Leucanthemum superbum</i> 'Snow Cap' |
| | Autumn Joy Sedum - <i>Sedum spectabile</i> 'Autumn Joy' |
| | Daisy Assorted Colors - <i>Hemerocallis</i> spp. |
| | Lily Turf Big Blue - <i>Liligo muscari</i> 'Big Blue' |
| | Hosta Patriot - <i>Hosta</i> x <i>Patriot</i> |
| | Bowles Vinca - <i>Vinca minor</i> 'Bowles' |
| | Red Carpet Sedum - <i>Sedum spurium</i> 'Red Carpet' |
| | Little Bunny Dwarf Fountain Grass - <i>Pennisetum alopecuroides</i> 'Little Bunny' |



Detention pond plantings to meet or exceed Hartland Township's current zoning ordinance requirement.
 Greenbelts along public roads to meet or exceed Hartland Township's current zoning ordinances requirements unless described otherwise within this document.
 These are conceptual illustrations only. Actual Landscape may differ and will require approval by the Architectural Review Board.




Site Landscape Plan



Detention pond plantings to meet or exceed Hartland Township's current zoning ordinance requirement.
Greenbelts along public roads to meet or exceed Hartland Township's current zoning ordinance requirements unless described otherwise within this document.
These are conceptual illustrations only. Actual Landscape may differ and will require approval by the Architectural Review Board.



110' Boulevard Landscape










| LEGEND | Element | Landscape Requirements | Landscape Character | |
|--------|----------------------|-----------------------------|--|---|
| | Canopy Tree | Deciduous Street Trees | Two (2) canopy trees per planting cutout as conceptually shown. | See plan notes above. |
| | Ornamental Tree | Ornamental Street Trees | A symmetrical double row, planted fifteen (15') feet on center in the boulevard island and shall extend the full length of the island. | Blocks of same species, matched, flowering, multi-stemmed trees of rounded habit. |
| | Landscape Bed | Shrubs/ Perennials/ Annuals | Planting beds at the noses of the boulevard island shall extend a minimum of forty feet (40') and shall be bordered by six foot (6') wide lawn edge. | A combination of spring bulbs, perennials, annuals, shrubs, and grasses may be used to achieve a display of seasonal interest. However, each landscape bed shall have a maximum of three (3) different species (i.e.: background, mid-ground, and border plants). |
| | Lawn Panel | | | |
| | Entry Column | | | |
| | Crosswalk & Stop Bar | | Planting cutouts shall be a minimum of six feet (6') wide and have a one- and one-half foot (1 1/2') wide pavement band adjacent to the curb. | |

These are conceptual illustrations only. Actual Landscape and Sign Design may differ and will require approval by the Architectural Review Board.



100' Boulevard Landscape











| LEGEND | Element | Landscape Requirements | Landscape Character | |
|---|----------------------|-----------------------------|---|---|
|  | Canopy Tree | Deciduous Street Trees | One (1) deciduous street tree per thirty linear feet (30') of road frontage. | Broad shade tree. One species per street. |
|  | Ornamental Tree | Ornamental Street Trees | A single row, planted fifteen feet (15') on center in the boulevard island and shall extend the full length of the island. | Trees of same species, matched, flowering, multi-stemmed trees of rounded habit. |
|  | Landscape Bed | Shrubs/ Perennials/ Annuals | Planting beds at the noses of the boulevard island shall extend a minimum of forty feet (40') and shall be bordered by six foot (6') wide lawn edge. | A combination of spring bulbs, perennials, annuals, shrubs, and grasses may be used to achieve a display of seasonal interest. However, each landscape bed shall have a maximum of three (3) different species (i.e.: background, mid-ground, and border plants). |
|  | Lawn Panel | | | |
|  | Entry Column | | | |
|  | Crosswalk & Stop Bar | | Planting cutouts shall be a minimum of six feet (6') wide and have a one- and one-half foot (1 1/2') wide pavement band adjacent to the curb (where boulevard has on-street parking). | |

These are conceptual illustrations only. Actual Landscape and Sign Design may differ and will require approval by the Architectural Review Board.




66' Entrance Street Landscape






| LEGEND | Element | Landscape Requirements | Landscape Character |
|---|-----------------------|-----------------------------|---|
|  | Canopy Tree | Deciduous Street Trees | Two (2) canopy trees per planting cutout along the street edge as conceptually shown. |
|  | Large Ornamental Tree | Shrubs/ Perennials/ Annuals | Planting cutouts on the street shall be a minimum of five feet (5') wide. |
|  | Landscape Bed | | |
|  | Lawn Panel | | |
|  | Bench | | |
|  | Canopy Tree | | |
|  | Crosswalk & Stop Bar | | |

These are conceptual illustrations only. Actual Landscape and Sign Design may differ and will require approval by the Architectural Review Board.

Residential Street Landscape




| LEGEND | Element | Landscape Requirements | Landscape Character |
|---|----------------------|--|--|
|  | Canopy Tree | Street Frontage: One (1) deciduous street tree per lot to allow for driveways. Side Street Frontage: Two (2) deciduous street trees per lot to allow for driveways. Park Frontage: One (1) deciduous street tree per fifty linear feet (50') of road frontage. | Broad shade tree. One species per street. Street trees at park frontage may change to a different species to distinguish park areas. |
|  | Lawn Panel | | |
|  | Crosswalk & Stop Bar | | |

These are conceptual illustrations only. Actual Landscape and Sign Design may differ and will require approval by the Architectural Review Board.



Corner Landmark



LEGEND

| | | | |
|---|----------------------|---|--|
|  | Canopy Tree |  | Decorative Wall/Fence/Building Wall with integrated community sign |
|  | Lawn Panel | | |
|  | Crosswalk & Stop Bar | | |
| | | LAR | Landscape Along Road |

| Element | Landscape Requirements | Landscape Character |
|-----------------------------------|--|---|
| Trees | 9 Deciduous/Evergreen Trees* (Minimum 4' to right-of-way line or sidewalk) | Broad shade trees with rounded form and notable fall color. |
| Ornamental Trees | 2 Ornamental Trees* (Minimum 4' to right-of-way line or sidewalk) | Flowering trees with horizontal spreading habit. |
| Shrubs/Perennials/Annuals/Grasses | 74 Shrubs *8 additional shrubs may be used in lieu of a tree (landscape bed may encroach into the Public ROW provided that safe sight distances are maintained and all structures are contained within the property). | Deciduous and evergreen shrubs. Supplement with bulbs, perennials, annuals, and grasses to achieve a display of seasonal interest. Species shall be used in masses vs. a spotty effect. |
| Lawn | All non-paved areas, other than landscape beds and mulched trees, shall be planted with sod or hydro-seed. | Maintained lawn |
| Walls | Decorative walls/fence, or wall of building, with integrated community sign. | |

These are conceptual illustrations only. Actual Landscape and Sign Design may differ and will require approval by the Architectural Review Board.



B. Greenbelt


1. A greenbelt shall be planted along the public right-of-way of M-59, Fenton Road, and Pleasant Valley Road.
 - a. The greenbelt shall be within the first thirty (30) feet of the property, unless conflicts occur with utilities, site lines, or other encumbrances.
 - b. The green belt shall be a minimum of twenty (20) feet wide and shall generally run parallel to the public right-of-way.
 - c. Any greenbelt screen less than twenty feet (20') in depth provided that it shall include an obscuring fence/wall with a height of six feet (6'). This would require review and approval by the Architectural Review Board and Hartland Township.
 - d. All landscaping within the greenbelt shall meet or exceed Hartland Township's current zoning ordinance requirements unless described otherwise within this document.

C. Buffering or Screening Requirements

1. All buffering or screening shall meet or exceed Hartland Township's current zoning ordinance requirements unless described otherwise in within this document.



Greenbelt



M-59



PLANT GUIDE

| TREES | |
|------------|--|
| | Weeping Alaskan Cedar - <i>Chamaecyparis nootkatensis 'Pendula'</i> |
| | Weeping Hemlock - <i>Tsuga canadensis 'Pendula'</i> |
| | Norway Spruce - <i>Picea abies</i> |
| | Black Hills Spruce - <i>Picea glauca 'Densa'</i> |
| | Levander Twist Red Bud - <i>Cercis canadensis 'Covyi'</i> |
| | Crinson Queen Laceleaf Japanese Maple - <i>Acer palm. diss. 'Crinson Queen'</i> |
| | Royal Raindrops Crab - <i>Malus 'Royal Raindrops'</i> |
| | Dineland Select Pear - <i>Pyrus calleryana 'Dineland Select'</i> |
| | Trans Fontaine Hornbeam - <i>Carpinus betulus 'Trans Fontaine'</i> |
| | Skyline Honeylocust - <i>Gleditsia triacanthos 'Inermis 'Skyline'</i> |
| | Autumn Blaze Maple - <i>Acer freemanii 'Autumn Blaze'</i> |
| SHRUBS | |
| | Arrowwood Viburnum - <i>Viburnum dentatum</i> |
| | Lynwood Gold Forsythia - <i>Forsythia x intermedia 'Lynwood Gold'</i> |
| | Bridal Wreath Spirea - <i>Spirea x vanhouttei</i> |
| | Sea Green Spreading Juniper - <i>Juniperus chinensis 'Sea Green'</i> |
| | Goldflame Spirea - <i>Spirea japonica 'Goldflame'</i> |
| | Woodward Globe Arborvitae - <i>Thuja occidentalis 'Woodward'</i> |
| | Yellow Ribbon Arborvitae - <i>Thuja occidentalis 'Yellow Ribbon'</i> |
| | Koreanopicea Viburnum - <i>Viburnum carlesii</i> |
| | Compact Inkberry Holly - <i>Ilex glabra 'Compacta'</i> |
| | Green Velvet Boxwood - <i>Buxus x 'Green Velvet'</i> |
| | Wine & Roses Weigela - <i>Weigela florida 'Alexandra'</i> |
| | Dwarf Burning Bush - <i>Euonymus alatus 'Compactus'</i> |
| | Skyrocket Upright Juniper - <i>Juniperus virginiana 'Skyrocket'</i> |
| | Rosy Glow Barberry - <i>Berberis thunbergii 'Rosy Glow'</i> |
| | Little Devil Honeysuckle - <i>Physocarpus opulifolius 'Little Devil'</i> |
| | Hetz Magnet Globe Arborvitae - <i>Thuja occidentalis 'Hetz Magnet'</i> |
| | Blue Star Juniper - <i>Juniperus squamata 'Blue Star'</i> |
| | Fine Line Buckthorn - <i>Rhamnus frangula 'Bon Villain'</i> |
| PERENNIALS | |
| | Grosse Fontaine Maiden Grass - <i>Miscanthus sinensis 'Grosse Fontaine'</i> |
| | Heavy Metal Switch Grass - <i>Panicum virgatum 'Heavy Metal'</i> |
| | Wanda Lady Snow Cap - <i>Leucanthemum superbum 'Snow Cap'</i> |
| | Autumn Joy Sedum - <i>Sedum spectabile 'Autumn Joy'</i> |
| | Heavenly Angelica Coloss - <i>Hemerocallis sp.</i> |
| | Lily Leaf Big Blue - <i>Liriodieum sp.</i> |
| | Holla Patriot - <i>Rosa x 'Patriot'</i> |
| | Bowles Vinca - <i>Vinca minor 'Bowles'</i> |
| | Red Carpet Sedum - <i>Sedum spurium 'Red Carpet'</i> |
| | Little Bunny Dwarf Fountain Grass - <i>Pennisetum alopecuroides 'Little Bunny'</i> |




V. Sign Regulations

The Newberry Place sign regulations will comply with the most current Hartland Township Zoning Ordinance with the exception of the entry wall and pier design and monument signage regulations set forth on pages 43-45.



NOTE: These signs and wall signs shall comply with the most current zoning ordinance and sign regulations.

These are conceptual illustrations only. Actual monument sign design may differ and will require approval by the Architectural Review Board.



NOTE:
This ground sign can be located at the corners of M-59 and Pleasant Valley Road and M-59 and Fenton Road.

NOTE:
This ground sign can be located along M-59 between Pleasant Valley Road and the Newberry Entrance, and between Fenton Road and the Newberry Entrance.

NOTE:
This type of ground sign can be located along M-59 along the commercial frontage of the North and South parcels.

NOTE:
This type of ground sign can be located at the entrance to the residential districts.

1.a. COMMERCIAL BUSINESS MONUMENT SIGN

1.b. COMMERCIAL FUEL PRICE SIGN

2. COMBINED GROUND SIGN


3. GROUND SIGN TO RESIDENTIAL DEVELOPMENTS

4. COMMERCIAL TENANT GROUND SIGN



HARTLAND, MI
DEVELOPMENT PROPOSAL

NEWBERRY PLACE • GROUND SIGN DESIGNS - FRONT VIEW



1.a.
1.b.

2.
3.

4.

NEWBERRY PLACE • GROUND SIGN DESIGNS - SIDE VIEW

NOTE:
These signs and wall signs shall comply with the most current zoning ordinance and sign regulations.

These are conceptual illustrations only. Actual Entry Wall and Pier Design may differ and will require approval by the Architectural Review Board.

Monument Sign Locations



- Commercial Fuel Price Sign
- Combined Ground Sign
- Commercial Tenant Ground Sign
- Commercial Business Monument Sign
- Ground Sign to Residential Development
- Entry Wall and Pier Sign

This is a conceptual illustration only. Actual sign locations may differ and will require approval by the Architectural Review Board.


Newberry Place



Introduction –

The Pleasant Valley Special Planning Area in Hartland township, Michigan is envisioned to be a mixed-use, walkable, planned development that will enhance the surrounding township without taking on the appearance of a separate municipality. This new community, Newberry Place, is designed in the style of traditional town values.

The proposed community plans to incorporate a mixture of land uses that could include grocery store, retail uses, office uses, single and multiple family housing alternatives, senior living facility, medical services, other goods and services and a network of parks and open spaces.



History of Submittals -

- 2007 Pattern Book had 328 Residential Units and 280,103 sq. Ft of commercial space.
- 2016 Preliminary Plan had 499 Residential Units and 140,715 sq. Ft of commercial space.
(The 40 Acre West Parcel was not included in this submission)
- 2019 Conceptual Plan had 529 residential units and 133,950 sq. ft. of commercial space. The 40-acre west parcel was included with this plan.
- The current submission has 417 units and 133,950 sq. ft. of commercial space. The west 40 acres are no longer included.

ACERAGE SUMMARY

| | |
|--------------|----------------|
| North Parcel | – 30.25 Acres |
| South Parcel | – 78.44 Acres |
| Total Acres | – 108.69 Acres |

I. Regulating Plan



General Use Type

As shown on the Regulating Plan, the community consists of seven districts:

- Single Family Residential District
- Single Family Detached Only Residential District
- Mixed Use District
- Commercial District
- 5' Concrete Sidewalk

Residential Unit Chart (Unit)

| | | | | | Total |
|--------------|--|--|--|--|------------|
| North Parcel | 90 | 19 | - | - | 109 |
| South Parcel | 242 | - | - | - | 308 |
| Total | 332 | 19 | 66 | - | 417 |

Residential Unit Chart (Unit/Acre)

| | | | | | Total |
|--------------|--|--|--|--|------------|
| North Parcel | 4.5 | - | - | - | N/A |
| South Parcel | 4.5 | - | - | - | N/A |
| Total | 4.5 | - | - | - | N/A |

Commercial Space Chart (sq. ft.)

| | | | | | Total |
|--------------|--|--|--|--|----------------|
| North Parcel | - | - | 45,213 | 4,836 | 50,049 |
| South Parcel | - | - | 39,861 | 44,040 | 83,901 |
| Total | - | - | 85,074 | - | 133,950 |

SINGLE FAMILY DISTRICT

- The Single Family District permits a limited range of uses, including detached single family lots of varied sizes, attached style condominiums (up to five (5) units per building), duplex motor court condominiums, and 4-6 plex motor court condominiums.
- North parcel – 90 total residential units
- South Parcel – 242 total residential units
- Total – 332 residential units
- Total area of the district is 73.98 Acres
- Overall density cap of the District – 4.5 Units/ Acre
- Some of the products for this district are as follows









Attached Style Condominium (Up to 5 Units Only)



Front Elevation



Left Elevation



Right Elevation




Rear Elevation

Duplex Quad Motor Court Homes





Front Elevation



Quad Motor Court 4-6 Plex



Front Elevation



SINGLE FAMILY DETACHED ONLY DISTRICT

- This district allows only single family detached units.
- Total no. of units – 19
- Some of the products for this district are as follows:





MIXED USE DISTRICT

- The mixed use designation permits a variety of small scale retail, office and similar uses that provide goods and services to the local community as well as, live/work units, senior care, attached style condominiums (up to five (5) units per building), duplex motor court condominiums, 4-6 plex motor court condominiums and multiple family (up to 14 units per building).
- Some of the products for this district are as follows –



Mixed-Use Commercial / Office Residential



HARTLAND, MI
DEVELOPMENT PROPOSAL

COMMERCIAL • OFFICE • RESIDENTIAL
Main Street Facade | Mixed Use



Side Street Elevations

Attached Style Condominium (Up to 5 Units Only)



Front Elevation



Left Elevation



Right Elevation




Rear Elevation

Duplex Quad Motor Court Homes





Front Elevation



Quad Motor Court 4-6 Plex



Front Elevation





HARTLAND, MI
DEVELOPMENT PROPOSAL

TRI UNIT APARTMENT • RESIDENTIAL
Front Elevation | Multifamily Housing



Left Elevation



Right Elevation



Rear Elevation



HARTLAND, MI
DEVELOPMENT PROPOSAL

QUIN UNIT APARTMENT • RESIDENTIAL
Front Elevation | Multifamily Housing



Left Elevation



Right Elevation



Rear Elevation



HARTLAND, MI
DEVELOPMENT PROPOSAL

TEN UNIT APARTMENT • RESIDENTIAL

Front Elevation | Multifamily Housing



Rear Elevation



HARTLAND, MI
DEVELOPMENT PROPOSAL

COMMERCIAL • RETAIL
Front Facade



Left Elevation



Right Elevation



Rear Elevation



HARTLAND, MI
DEVELOPMENT PROPOSAL

COMMERCIAL
Main Street Facade | Mixed Use




Left Elevation

Right Elevation




Rear Elevation





Newberry Place - North Parcel
Aerial Overlay



Newberry Place - South Parcel
Aerial Overlay



NORTH NEWBERRY- BIRD'S EYE



jeffery a. scott architects p.c.
architects - engineers



NORTH NEWBERRY- EYE LEVEL



jeffery a. scott architects p.c.
architects - engineers



SOUTH NEWBERRY- BIRD'S EYE



jeffery a. scott architects p.c.
architects - engineers



SOUTH NEWBERRY- EYE LEVEL



jeffery a. scott architects p.c.
architects - engineers