



BOARD OF WATERWORKS COMMISSIONERS AGENDA

January 16, 2023 at 3:30 PM

Water Utility Admin Office, 72 Park Avenue, Sheboygan WI

Persons with disabilities who need accommodations to attend this meeting should contact the Sheboygan Water Utility, (920) 459-3805. Persons other than commission, committee, and board members who wish to participate remotely shall provide notice to the Utility at 920-459-3805 at least 24 hours before the meeting so that the person may be provided a remote link for that purpose.

OPENING OF MEETING

1. Pledge of Allegiance

MINUTES

2. Approve minutes from the Dec. 19, 2022 meeting

REPORTS

- [3.](#) Financial reports and approval of vouchers
- [4.](#) Superintendent's report including operations, construction-maintenance, and customer relations/fiscal

ITEMS FOR DISCUSSION AND POSSIBLE ACTION

- [5.](#) Review options for filter rehab/replacement.
- [6.](#) Request approval to purchase water meters
7. Review of Raw Water Improvements project
8. Request Board approval of 2022 4th Quarter report and transmittal to Council

PERSONNEL

9. Update on Distribution Tech recruitment

NEXT MEETING

10. Next meeting will take place on: February 20, 2023

ADJOURN

11. Motion to Adjourn

In compliance with Wisconsin's Open Meetings Law, this agenda was posted in the following locations more than 24 hours prior to the time of the meeting:

City Hall • Mead Public Library
Sheboygan County Administration Building • City's website



REPORT OF BILLING

DECEMBER 2022

	<u>2022</u>	<u>2021</u>	Increase or (Decrease)
<u>Quarterly Metered*</u>			
(Dist I - north of Superior Ave)			
Residential	236,256.33	216,085.89	20,170.44
Multi-Family	17,343.03	15,854.53	1,488.50
Commercial	14,220.73	11,977.26	2,243.47
Industrial	704.92	568.68	136.24
Public	5,352.96	4,058.69	1,294.27
Subtotal	273,877.97	248,545.05	25,332.92
Public Fire Protection	65,437.87	63,592.75	1,845.12
Flat Rate	32,212.55	31,522.67	689.88
Monthly Metered	<u>340,970.51</u>	<u>325,840.65</u>	<u>15,129.86</u>
Sheboygan Net	712,498.90	669,501.12	42,997.78
Sheboygan Falls	45,506.77	49,220.75	(3,713.98)
Kohler	<u>24,119.09</u>	<u>25,986.25</u>	<u>(1,867.16)</u>
Total	782,124.76	744,708.12	37,416.64

* Billing for scheduled district only for the three preceding months usage.

Total accumulative billing for 2022 is \$10,210,270.67. An increase of \$669,242.74 from 2021 accounted for as follows:

	<u>2022-Total Year to Date</u>
Sheboygan	695,524.27
Sheboygan Falls	(47,955.08)
Kohler	<u>21,673.55</u>
	669,242.74

Total bills mailed December, 2022: 6,937

Residential	6,206	Multi-Family	9	
Multi-Family	86	Commercial	20	
Commercial	208	Industrial	66	
Industrial	6	Public	9	Fire Protection 293
Public	34			
Quarterly	6,540	Monthly	104	Flat Rate 293



CASH RESERVE
December 31, 2022

Ending balance on report for November 30, 2022	<u>13,726,280.93</u>
Plus: Receipts	413,678.56
Misc Receipts	9,389.80
Direct Pay Receipts	398,052.03
Stop Loss Reimbursement	-
Money Market/CDARs Investment Interest	5,748.75
Minus:	
Disbursements - vendors and payroll	(568,297.91)
Bank Service Fees	(345.98)
Health & Dental Claims/Adm Costs	(78,960.82)
NSF Checks & Customer Refunds	(744.26)
Invoice Cloud/Paymentech Deposit Fees	(7,048.67)
Reallocate Sewer/Garbage - payments	(54.13)
Reallocate Sewer/Garbage - monthly	1,763.66
SDWL LSL Reimbursement	24,275.00
SDWL RWI Reimbursement	1,278,268.30
Automated Credit Card Payments	(2,775.51)
Postage	(5,000.00)
Utility Water Payments	(2,053.78)
Ending Balance December 31, 2022	<u>\$ 15,192,175.97</u>

Note: The above amount includes:	
Bond Reserve Fund	644,319.88
LSL Revolving Loan Fund	188,063.96
Money Market Investment	4,001,800.50
Health Insurance Restricted Reserve Defunded	-
ARPA Money Market Restricted - RWI	5,028,941.17
BAN Funds for Construction	-
Total	<u>\$ 9,863,125.51</u>
General Unrestricted Operating Cash	5,329,050.46



APPROVAL OF VOUCHERS
December 31, 2022

<u>Total Of The General Vouchers</u>	<u>\$ 395,200.05</u>
<u>Gross Payroll</u>	<u>\$ 186,966.35</u>
<u>Net Payroll</u>	<u>\$ 111,002.83</u>

BOARD OF WATER COMMISSIONERS

 PRESIDENT

 SECRETARY

 MEMBER

 SUPERINTENDENT

December 2022

OPERATIONS' DEPARTMENT MONTHLY REPORT

PUMPAGE	HIGH LIFT		LOW LIFT		2022 VS 2021
	2021	2022	2021	2022	HL
Total in MG	340.743	320.275	347.996	330.484	-6.01%
Daily Average (MG)	10.992	10.349	11.226	10.661	
Max. Day (MG)	13.155	12.942	13.636	13.350	
					2022 VS 2020
					HL
Gal/KwH	1,200	1,203	5,082	4,931	-3.77%
ELECTRICAL COSTS					
A. Pumping:	2021		2022		
	KwH	\$	KwH	\$	
High Lift	283,994	\$19,661.78	263,621	\$21,389.15	
Low Lift	68,481	\$4,884.04	66,474	\$5,393.43	
Wash Pump 1	3,500	\$192.53	4,200	\$340.77	
Georgia St. Bstr.	45,900	\$4,297.29	50,100	\$4,990.07	
Wilgus Ave. Bstr.	2,900	\$379.76	2,900	\$391.58	
EE Pit / Bstr.	5,693	\$413.28	5,612	\$719.77	
Erie Ave. Bstr.	0	\$2,144.10	15,200	\$2,313.56	
Sub Total	410,468	\$31,972.78	408,107	\$35,538.33	\$/KwH 11.8%
B. Treat./Fiscal/Misc.	2021		2022		
	KwH	\$	KwH	\$	
Office & Maint. Bldg.	5,150	\$630.74	4,643	\$607.71	
Filter Plant / Pump Station / 2nd Service	56,025	\$5,249.50	67,905	\$5,984.39	
Sub Total	61,175	\$5,880.24	72,548	\$6,592.10	\$/KwH -5.5%
C. Distribution:	2021		2022		
	KwH	\$	KwH	\$	
Taylor Hill Tank	1,746	\$182.92	2,767	\$366.99	
Kohler Meter Pit	0	\$0.00	0	\$0.00	
EE Tower	1,986	\$219.12	1,278	\$179.92	
Washington (PRV) Pit	923	\$89.89	428	\$75.17	
Sub Total	4,655	\$491.93	4,473	\$622.08	\$/KwH 9.5%
Total Electrical Costs	476,298	\$38,344.95	485,128	\$42,752.51	
Electrical Cost / MG		\$112.53		\$133.26	
NATURAL GAS COSTS					
	2021		2022		
	CCF Used	Cost	CCF Used	Cost	
Production Facility	1,266	\$1,034.50	2,241	\$2,465.78	
South Basin	3,313	\$2,599.44	3,750	\$4,171.68	
Georgia St. Bstr.	110	\$104.31	84	\$99.63	
Erie Ave. Bstr.	386	\$324.00			
Wilgus Ave. Bstr.	4	\$19.91	48	\$66.94	
Office & Maint. Bldg.	1,095	\$862.25	1,413	\$1,578.12	
Total Natural Gas Costs	6,174	\$4,944.41	7,536	\$8,382.15	\$/CCF 38.9%
Natural Gas Cost / MG		\$14.51		\$26.13	
CHEMICAL COSTS					
	2021		2022		
	Lbs. Used	Cost	Lbs. Used	Cost	
Alum	66,152	\$9,360.51	55,135	\$10,007.00	28.3%
Carbon	0	\$0.00	0	\$0.00	#DIV/0!
Chlorine	5,610	\$3,870.90	5,481	\$8,111.88	114.5%
Fluoride	1,789	\$1,944.64	1,571	\$2,183.69	27.9%
KMnO4	0	\$0.00	0	\$0.00	#DIV/0!
Cationic Polymer	0	\$0.00	0	\$0.00	#DIV/0!
Liquid Phosphate	2,988	\$3,850.14	3,742	\$5,904.88	22.5%
Total Chemical Costs		\$19,026.19		\$26,207.45	37.7%
Chemical Cost / MG		\$55.84		\$81.69	
Grand Total		\$62,315.55	\$77,342.11		24.11%
Total Cost / MG		\$182.88	\$241.07		31.82%

YTD HL 2022 vs 2021	-0.75%	YTD HL HIGH DAY PUMPAGE	17.388	July 19, 2022
YTD HL 2022 vs 2020	4.37%	YTD HL LOW DAY PUMPAGE	7.102	December 25, 2022

NOTE:

Electrical costs include an Alliant Energy 8.3% rate increase approved by PSC.
all WPS bills available.

Not

	YTD HL Ave Day
2022	12.253
2021	12.409
2020	11.642

COMPARATIVE SUMMARY OF PLANT OPERATIONS

December 2021

vs

December 2022

Pumping Record

High Lift

Low Lift

	2021	2022	Diff.		2021	2022	Diff.
Tot. Water in MG	340.743	320.275	-6.01%	Tot. Water in MG	347.996	330.484	-5.03%
Daily Average	10.992	10.349	-5.85%	Daily Average	11.226	10.661	-5.03%
Maximum Day	13.155	12.942	-1.62%	Maximum Day	13.636	13.350	-2.10%
Minimum Day	6.931	7.102	2.47%	Minimum Day	6.815	6.910	1.39%
By Natural Gas	0.000	3.795	#DIV/0!	By Natural Gas	0.000	2.705	#DIV/0!
Power in KWH	283,994	263,621	-7.17%	Power in KWH	68,481	66,474	-2.93%
Gals. per KWH	1,200	1,203	0.22%	Gals. per KWH	5,082	4,931	-2.97%
Power \$ / KWH	\$0.07346	\$0.08114	10.45%	Power \$ / KWH	----	----	----
Power \$ / MG	\$61.23	\$66.67	\$5.44	Power \$ / MG	\$14.46	\$16.32	\$1.86
Tot. Power \$/MG	\$110.04	\$134.52	\$24.48	Tot. Power \$/MG	----	----	----

Treatment Chem.

Lbs. Used

Cost

Total Lbs.	2021	2022	Diff.	Total Cost	2021	2022	Diff.
Alum	66,152	55,135	-16.65%	Alum	\$9,360.51	\$10,007.00	\$646.49
Carbon			#DIV/0!	Carbon	\$0.00	\$0.00	\$0.00
Chlorine	5,610	5,481	-2.30%	Chlorine	\$3,870.90	\$8,111.88	\$4,240.98
KMnO4	0	0	#DIV/0!	KMnO4	\$0.00	\$0.00	\$0.00
Polymer	0	0	#DIV/0!	Polymer	\$0.00	\$0.00	\$0.00
Liquid Phosphate	2,988	3,742	25.23%	Liquid Phosphate	\$3,950.14	\$5,904.88	\$1,954.74
Lb/ MG:				Cost / MG:			
Alum	190.1	166.8	-12.24%	Alum	\$26.90	\$30.28	\$3.38
Carbon	0.0	0.0	#DIV/0!	Carbon	#DIV/0!	#DIV/0!	#DIV/0!
Chlorine	16.1	16.6	2.88%	Chlorine	\$11.12	\$24.55	\$13.42
KMnO4	0.0	0.0	#DIV/0!	KMnO4	#DIV/0!	#DIV/0!	#DIV/0!
Liquid Phosphate	8.6	11.3	31.87%	Liquid Phosphate	\$11.35	\$17.87	\$6.52
Fluoride:	2021	2022		Fluoride:	2021	2022	
Total Lbs.	1,789	1,571	-12.19%	Cost	\$1,944.64	\$2,183.69	\$239.05
mg/l applied as F	0.69	0.72		Cost/MG	\$5.27	\$6.82	\$1.55
Av. Res. Plt. Tap	0.70	0.71					

Water Quality:

Raw

TAP

	2021	2022
Turbidity	9.90	8.00
pH	7.98	8.27
Alkalinity	115.9	112.4
MF (E-Coli)	5.5	2.5
Temperature	37.9	36.5
Wash-H2O % /LL	2.41	2.94
Av. Flt. Run/hrs	138.4	91.2
Av. ROF / MG	1.32	1.31

	2021	2022
Turbidity	0.050	0.033
pH	7.57	7.61
Alkalinity	102.6	102.1
Plate Count	0.20	0.00
Colilert	0	0
Temp.	39.4	38.4
CI Res.	0.90	0.90

Natural Gas:

	2021	2022		2021	2022	Diff.
Nat. Gas Heating	4,144	5,402	Plant & South Basin	\$3,278.08	\$5,988.83	\$2,710.75
Nat. Gas Pumping	435	590		\$355.88	\$648.63	\$292.75

	CCF	Cost	Natural Gas Cost	Natural Gas CCF
#3 Gas Pump	124.0	\$136.44	\$6,637.46	5,991
#4 Gas Pump	211.5	\$232.71		
#7 Gas Pump	120.0	\$132.04		
Electric Generator	134.0	\$147.44		
Pumping totals	589.5	\$648.63		

December 2022

		1/1/2023	12/1/2022			1/1/2023	12/1/2022
% Run	Elapsed Time:						
33.0%	No. 6 Pump	70,373.5	70,127.8	245.7	SLUDGE No. 1 Hour Meter	0.0	0.0
4.15%	Wash Pump Meter	5,616.86	5,585.98	30.88	SYSTEM No. 2 Mag Meter	6,794,079	6,720,960
0.6%	No. 7 Pump	791.1	786.3	4.8	Recycle Meter (Reset to zero each month)		73,119
0.0%	No. 8 Pump	59,540.3	59,540.3	0.0			
99.3%	No. 9 Pump	24,753.0	24,014.0	739.0			
1.1%	Wash Pump 2	75	67	8	Power Cost	\$0.0811360	Bill >>>> \$31,350.94
	No. 1 Prime Pump	1,047.1	1,046.2	0.9		0.39372	KWH >>> 386,400
	No. 2 Prime Pump	1,122.7	1,121.2	1.5	Init. Chg.	\$32,714.02	Low L. KWH 66,474
						\$	KWH
							L.L. Cost \$ 5,393.43
Kw/Hr run	Watt hour Meters:				Kohler Pit		High L. KWH 263,621
136.0	Wash Pump 1	1281.1	1275.1	4,200	Horizon	\$405.19	2,908
65.7	No. 9 Pump	5816.38	5767.83	48,554	Taylor	\$366.99	2,767
#DIV/0!	No. 8 Pump	6837.1	6837.1	0	ALT. 72 Park	\$393.72	1,000
72.9	No. 6 Pump	1353.2	1289.2	17,920	Geo. Ave.	\$4,990.07	50,100
125.1	Wash Pump 2	7.774	6.94	1,001	Wilgus Ave.	\$391.58	2,900
#DIV/0!	No. 1 Pump	9309.184	9309.184	0	EE Pit	\$719.77	5,612
239.0	No. 2 Pump	4838.949	4798.854	40,095	EE Tower	\$179.92	1,278
293.7	No. 3 Pump	384.038	272.831	111,207	Washington	\$75.17	428
#DIV/0!	No. 4 Pump			0	Office	\$607.71	4,643
479.8	No. 5 Pump	11,033.547	10,921.228	112,319	Erie Ave.	\$2,313.56	15,200
					Total	\$43,157.70	490,036
	Garage (MWatt/Hrs.)	1,079.47	1,076.13	3,340			
	Power Co. (Step #3)	38,882	38,546	403,200			
	Left Meter - OUTSIDE						
	Volume Used:				SUMMARY		
	Nat. Gas (Correct)	45,286,145	45,085,211	252,574			


HIGH LIFT DELIVERY		QUARTERLY REPORT		2022
I. FIRST QUARTER		Jan - Feb - Mar		
		GALLONS	COST \$	\$/MG
	2021	1,055,591,000	\$181,125.65	\$171.59
	2022	1,079,805,000	\$233,346.76	\$216.10
	Percent Difference	2.29%	28.83%	25.94%
II. SECOND QUARTER		Apr - May - Jun		
		GALLONS	COST \$	\$/MG
	2021	1,115,306,000	\$168,613.25	\$151.18
	2022	1,114,560,000	\$220,553.73	\$197.88
	Percent Difference	-0.07%	30.80%	30.89%
III. THIRD QUARTER		Jul - Aug - Sep		
		GALLONS	COST \$	\$/MG
	2021	1,275,383,000	\$191,262.23	\$149.96
	2022	1,253,674,000	\$258,395.90	\$206.11
	Percent Difference	-1.70%	35.10%	37.44%
IV. FOURTH QUARTER		Oct - Nov - Dec		
		GALLONS	COST \$	\$/MG
	2021	1,076,367,000	\$179,773.03	\$167.02
	2022	1,040,483,000	\$229,995.97	\$221.05
	Percent Difference	-3.33%	27.94%	32.35%
YEAR TO DATE : 2022				
		GALLONS	COST \$	\$/MG
ELECTRICITY CHEMICALS NATURAL GAS	2021	4,522,647,000	\$720,774.16	\$159.37
	2022	4,488,522,000	\$942,292.36	\$209.93
	Percent Difference	-0.75%	30.73%	31.73%
YEAR TO DATE : 2022				
SLUDGE DISPOSAL to WWTP		GALLONS	COST \$	
	2021	4,225,349	\$45,410.11	
	2022	4,203,119	\$35,328.38	
STORM WATER CHARGES	2022	NA	\$0.00	
HIGH LIFT SYSTEM DELIVERY :				
	Maximum Pumpage Day	17,388,000	July 19, 2022	
	Minimum Pumpage Day	7,102,000	December 25, 2022	

	MG	\$	\$/MG
2021	4,522,647,000	\$720,774.16	\$159.37
2022	4,488,522,000	\$942,292.36	\$209.93


NOTE: Monthly sludge disposal costs do not reflect the current actual monthly sludge discharge total to date.
 Filtrate discharges from Spring/Fall sludge disposal operations are included in treatment plant sludge disposal costs.
 Spring/Fall basin sludge/residual solids volumes and disposal costs are contract work.
 Sludge disposal costs are not included in \$/MG.

December 2022: Sheboygan Water Utility Plant Operations Summary

Item 4.



Plant Operations: Expense Report



Filter Plant Maintenance Completed For December 2022

Subject	StartDate	EndDate	Description
Filter 5 Grout/Epoxy	1-Dec-22		Apply epoxy and install grout on filter cap-ends.
South Basin Bathroom	2-Dec-22		Clean bathroom
South Alum Pump	2-Dec-22		Replace hose, flush/clean line, and repair roller.
Filter Upgrade	5-Dec-22		Participate in filter upgrade meeting.
East UVT% Meter	5-Dec-22		Diagnose East UVT% meter low lamp fault; needs new cell and cleaning.
Shop and Tools	5-Dec-22		Begin cleaning maintenance shop and tools used during Filter 5 maintenance.
Filter 5	5-Dec-22		Vacuum and check for missing hardware.
UV Quartz Sleeves	6-Dec-22		Receive new sleeves and check for imperfections; ok at this time.
Filter 5 Surface Sweeps	6-Dec-22		Repair filter 5 surface sweep angle iron and install landing shims.
Garbage	7-Dec-22		Remove plant garbage and recycling.
Filter 5	7-Dec-22		Fill with sand and gravel.
UV Reference Check	9-Dec-22		Perform UV reference check.
Filter Plant Tools	12-Dec-22		Organize tools/parts in maintenance shop and repair DeWalt grinder cord.
Garbage	12-Dec-22		Throw away filter 5 media bags and plant garbage.
Filter Hall	12-Dec-22		Clean filter hall, operations floor, and laboratory.
Filter 5 Gauge	12-Dec-22		Install new pressure gauge on filter 5 manifold.
Monday Meeting	12-Dec-22		Topics include filter 5, raw water improvement, pack flange by 1, UV sleeves, coverage, project cleanup, etc.
Valve #14	12-Dec-22		Snug packing flange; leaking by pump 1.
Dan 2nd shift for Glen	13-Dec-22	14-Dec-22	Dan covering 2nd shift for Glen
Georgia Ave.	13-Dec-22		Check doghouse, inspect off-smell (heater INOP), refill agents, and walk grounds; found generator batteries need filling.
EE Tower	13-Dec-22		Check heater, inspect lower level, and walk grounds.
Horizon	13-Dec-22		Fill reagents, calibrate hypo meter, walk grounds, and check heater.
Filter Strategy	14-Dec-22		Discuss filter diagnostic/monitoring strategy.
Dan Covering Laboratory	14-Dec-22	15-Dec-22	Dan covering for Eric's, afternoon reads.
Erie Ave.	14-Dec-22		Check reagents, walk grounds, inspect generator, and make sure heaters work correctly.
Taylor Hill	14-Dec-22		Refill reagents, drain dehumidifier, walk grounds, check heater, and run low level sump.
Wilqus Ave.	15-Dec-22		Check heater, inspect grounds, and collect laboratory sample.
Menards	15-Dec-22		Purchase stainless fitting, rubber gloves, carbon monoxide detector, and large gloves.
Filter 1	15-Dec-22		Drain, rinse, fill, and leak detect.
Filter 1	15-Dec-22		Tap new hole for sample pump and install new pressure gauge.
filter plant cleaning	16-Dec-22		Cleaned filter plant common areas
Self assessment paperwork	19-Dec-22		Dan & Josh completed self-assessment paperwork and sent to supervisor
Dakota supply group	20-Dec-22		Picked up venter motor for Georgia pump station heater
#4 filter tap and pressure guage	20-Dec-22		Taped new line and installed pressure gauge on filter #4
Hall Map	20-Dec-22		Remove pegboard and install temporary system map.
West Basin Valve	20-Dec-22		Tighten packing nuts on West Basin valve in pipe gallery.
Pressure Gauges	21-Dec-22		Deep dive research on quality pressure gauges for plant filters; attempting to receive quotes from Blue Ribbon.
Office and Laboratory	21-Dec-22		Clean floors and counters in office, lunch room, and laboratory.
UV Sleeves	21-Dec-22		Final inspect and organize UV reactor sleeves.
Garbage's	21-Dec-22		Throw out garbage and recycling.
New Hypo feed pump hoses	22-Dec-22		New hypo pump hoses installed east, west, and south hypo pumps
Sample pump A installed	22-Dec-22		Rebuilt sample pump A (west) installed, old pump being rebuyilt
Dan covering 1st shift	23-Dec-22	26-Dec-22	Dan covering 1st shift
Josh covering 3rd shift	23-Dec-22	27-Dec-22	Josh covering 3rd shift operations
Observed Christmas Holiday	23-Dec-22	23-Dec-22	
Christmas holiday	24-Dec-22	25-Dec-22	Christmas holiday
Observed Christmas Holiday	26-Dec-22	26-Dec-22	
Dan off for coverage	27-Dec-22	28-Dec-22	Dan off for coverage
Joshua off for Coverage	28-Dec-22	29-Dec-22	Joshua off for covering 3rd shift.
Dan vacation day	29-Dec-22		Dan on vacation
Observed new years holiday	30-Dec-22	30-Dec-22	Observed new years holiday
New Years Holiday	31-Dec-22	1-Jan-23	New Years holiday



MONTHLY CONSTRUCTION-MAINTENANCE DEPARTMENT REPORT

December 2022

Distribution System Maintenance:

- Repaired water main break on S 17th St north of Washington Avenue.
- Repaired water main break on S 12th St south of Washington Avenue.
- Repaired water main break on South Business Drive north of Ashland Avenue.
- Continued seasonal hydrant checks.
- Installed hydrant flags within system for snowplowing purposes.
- Poured temporary concrete patches and completed water main break site cleanup.
- Hauled in fill to replenish stock.

Building/Grounds Maintenance:

- General shop maintenance and cleaning.
- Clean out and organization of Johnson Shed.
- Aided Operations in repair of underdrain system on #5 Filter.

Water Quality:

- Completed weekly water quality flushing.

Taps:

- 1" tap at 1842 Superior Ave. Lead Service was removed from the system.

Equipment Maintenance:

- Performed routine maintenance and repairs on construction equipment and vehicle fleet.



Distribution System -- December 2022

Street Valves and Hydrant Valves Installed (including water main projects and others)

Location	Date Installed	Size ("), Jt	Installed By	Type
----------	----------------	--------------	--------------	------

Total Valves Installed = 0

Street Valves and Hydrant Valves Removed

Location	Installed	Abandoned	Type
----------	-----------	-----------	------

Total Valves Removed = 0

Street Valves and Hydrant Valves Abandoned

Location	Installed	Abandoned
----------	-----------	-----------

Total Valves Abandoned = 0

Street Valves and Hydrant Valves Maintained

Location	Maintained	Size	By
----------	------------	------	----

Total Valves Maintained = 0

Hydrants Installed (including water main projects and others)

Location	Installed	Tr Size	Valve	By
----------	-----------	---------	-------	----

Total Hydrants Installed = 0

Hydrants Removed (including water main projects and others)

Location	Installed	Removed	Hyd Valve?
----------	-----------	---------	------------

Total Hydrants Removed = 0

Hydrants Abandoned (including water main projects and others)

Location	Installed	Abandoned	Tr Size	Hyd Valve?
----------	-----------	-----------	---------	------------

Total Hydrants Abandoned = 0

Hydrants Maintained/Moved (including water main projects and others)

Location	Installed	Maintained
----------	-----------	------------

Total Hydrants Maintained/Moved = 0

Water Main Breaks

Location	Date	Size
3318 S 17th St.	12/17/2022	8"
3403 S 12th St.	12/19/2022	8"
2223 S. Business Dr.	12/28/2022	8"


Number of Water Main Breaks= 3

SUMMARY


Number of feet of 4 inch water main installed	0.0	water main
Number of feet of 6 inch hydrant lead installed	0.0	
Number of feet of 6 inch water main installed	0.0	
Number of feet of 8 inch water main installed	0.0	
Number of feet of 12 inch water main installed	0.0	
Number of feet of 16 inch water main installed	0.0	
Number of feet of 20 inch water main installed	0.0	
Number of feet of 24 inch water main installed	0.0	
Number of feet of water main abandoned or removed	0	
Number of water main breaks repaired	3	hydrants
Number of hydrants installed	0	
Number of hydrants removed or abandoned	0	
Number of hydrants maintained or moved	0	valves
Number of street valves installed	0	
Number of hydrant valves installed	0	
Number of street valves removed or abandoned	0	
Number of hydrant valves removed or abandoned	0	
Number of valves maintained	0	
Number of water connections installed	1	

CUSTOMER RELATIONS & FISCAL SUMMARY

PAYMENT TRANSACTIONS



6,057
Total # of December
Payments Processed



COLLECTIONS

District 2

\$1,100,732

Total Billed

\$252,636

Outstanding
After Due Date

1254

Past Due Letters Mailed

0

Disconnection
Letters Mailed

0

Properties Disconnected

\$111,500

Outstanding At
Month End

PAYMENTS BY SOURCE

	December 2021	December 2022
Payment Window (Cash/Check)	328	339
Drop Box Payments	158	122
Electronic Payments	4027	4266
Mail Payments	2180	1936
Total Payments	6693	6663

Payments Returned NSF **15**

UTILITY BILLS



Total Paperless
1,291

Total Emailed
Statements
3,162



**DECEMBER
2022**

CUSTOMER RELATIONS & FISCAL SUMMARY

PROPERTY TRANSACTIONS

	December 2021	December 2022
Account Transfers <i>(Finals)</i>	197	177
Property Data Requests	98	59

PSC COMPLAINTS

0 PSC Complaint(s) Filed

ACCOUNTS PAYABLE

175 Invoice Items Paid

CUSTOMER SERVICE



91

Customer Service Email
Requests Completed



406

USS Calls Answered



21:53

USS Hours
On the Phone



60

Lead ST Calls Completed
(Incoming & Outgoing)



4:28

Lead ST Hours
On the Phone


CUSTOMER ASSISTANCE PAYMENTS

Number of Payments Received: **12**

Total Dollars: **\$1,670**

*Payments received from Wisconsin Emergency Rental Assistance Program, LIHWAP, Salvation Army, and St. Vincent DePaul for customer benefit.


LEAD SERVICE LINE REPLACEMENT ACTIVE LOANS



**DECEMBER
2022**

CUSTOMER RELATIONS & FISCAL SUMMARY

SERVICE TECH MILES DRIVEN



CROSS CONNECTION

1150

Inspections by SWU

Inspections by Hydro Corp



3

Facilities with Compliance Issues

LEAD EDUCATION

15

WDNR Lead in Drinking Water brochures distributed at home visits

TROUBLESHOOTING WORK ORDERS COMPLETED

104

Work orders completed for high consumptions, zero/low, and checks.

LEAK ALLOWANCES ISSUED

5

Customer Requests

339

CCF Allowed @ Reduced Rate



SERVICE LEAKS

2

New Reported Leak(s)

2

Leak(s) Fixed or Off

2

Active Leak(s) Month End

METERS

127

Meters

Installed/Replaced

42

Meters Tested



**DECEMBER
2022**

CUSTOMER RELATIONS & FISCAL SUMMARY

FACEBOOK PAGE



6 December New Followers

769 Total Followers

WEBSITE VISITORS

3,125



2021 Visits in December: 3,112
Top Page Viewed: **Pay Your Bill**

ADDITIONAL CR/F ACTIVITIES DECEMBER

- ◆ Service Techs continue their work replacing and testing water meters.
- ◆ USS issued bills to District 1 and Monthly customers.
- ◆ Disconnections for nonpayment were not held in December due to the tax roll process. They will resume in January 2023.
- ◆ USS assisted in entering data for the ETF Transition.
- ◆ Meter inventory was completed.
- ◆ The STs shadowed the USS in the areas of troubleshooting and new account setup.

DECEMBER
2022

Date: January 12, 2023
To: Joe Trueblood, Utility Superintendent
From: Bill Swearingen, Operations Supervisor
Subject: Filter Underdrain Monitoring and Future Planning Report

Background

An IMS cap failure on filter 5 initiated an emergency response that included an onsite visit from Leopold to which they determined that the underdrain was a good candidate for an IMS cap replacement and conversion to their IMS 200 cap. Utility staff completed all necessary underdrain preparations and IMS cap replacement work. The filter was returned to service on December 12, 2022 and is operating within the manufacturer's specifications and WDNR standards. In parallel to this work, operations staff have also participated in filter underdrain replacement alternatives and review workshops organized by utility engineering consulting firm CDM Smith.

Underdrain Pressure Testing

The Operations Department operates and maintains 11 gravity sand filtrations systems installed by Leopold in the mid-1990s. Based on recommendations, additional filter assessments and pressure monitoring have also been completed by staff. Details are below (oldest to newest):

Filters #9, #8, and #7

Installation year: 1996/1997

Age: 26/25 years

Underdrain Type: S Underdrain with I.M.S Cap media retainer

Modifications: None

Pressure testing across existing I.M.S cap (Head loss):

- Filters 9
 - Pressure reading at high-rate backwash = 9.2 psi
 - Pressure reading at static (water level at trough weir) = 2.7 psi
 - Pressure differential = 6.5 psi
- Filters 8
 - Pressure reading at high-rate backwash = 9.2 psi
 - Pressure reading at static (water level at trough weir) = 3.5 psi
 - Pressure differential = 5.7 psi
- Filter 7
 - Pressure reading at high-rate backwash = 10 psi
 - Pressure reading at static (water level at trough weir) = 3.0 psi
 - Pressure differential = 7.0 psi

Both 8 and 9 filters are experiencing elevated headloss pressure differentials of 6.5 psi and 5.7 psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi.

Like filters 8 and 9, filter#7 is experiencing a higher elevated headloss at a pressure differential of 7.0 psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi.

Plan of Action:

Continue with monitoring and operational contingency planning to further reduce risk of over pressurizing the IMS caps. Filters 7, 8, and 9 should be targeted for replacement within 1-2 years. Replacement underdrain systems would be based on filter underdrain alternatives and review workshops conducted by utility staff and CDM Smith. Total underdrain replacement cost for all three filters is estimated to be \$1,275,000 installed with media. This cost would include initial air scour equipment purchase. Recommend scheduling replacement in years 2023/2024.

Filter #6

Installation year: 1997

Age: 25 years

Underdrain Type: S Underdrain with I.M.S Cap media retainer

Modifications: None

Pressure testing across existing I.M.S cap (Head loss):

- Pressure reading at high-rate backwash = 12 psi
- Pressure reading at static (water level at trough weir) = 2.6 psi
- Pressure differential = 9.4 psi

Filter #6 is experiencing extremely high headloss at a pressure differential of 9.4psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi

Plan of Action:

I would recommend that the utility engage Leopold on an IMS cap replacement project as we have done with filter 5. Media would need to be removed to determine that the underdrain is not damaged and make sure it's a good candidate for an IMS cap replacement. Utility staff can complete all necessary underdrain preparations and IMS cap conversion to the IMS 200 cap. Leopold indicates that an IMS cap conversion extends the working life of an underdrain 5-10years. IMS cap replacement project returns the filter to service within 4 months at a total cost of \$120,000 plus utility labor. IMS Cap replacement project can be scheduled in year 2023

The utility would then need to look at an underdrain replacement after 5 years. The replacement underdrain would ideally be the same underdrain system installed in other filtrations systems based on the underdrain evaluation report generated by CDM Smith. Total underdrain replacement cost for filter 6 after 5 years is estimated to be \$425,000 installed with media. Recommend scheduling replacement in year 2028.

Filter #5

Installation year: 1998

Age: 24 years

Underdrain Type: S Underdrain with I.M.S Cap media retainer

Modifications: Original IMS cap fail in 2022. Completed IMS cap replacement in 2022 (IMS cap conversion to the IMS 200)

Pressure testing across existing I.M.S cap (Head loss):

- Pressure reading at high-rate backwash = 4.8 psi
- Pressure reading at static (water level at trough weir) = 2.9 psi
- Pressure differential = 1.9 psi

Filter #5 is not seeing significant increased pressures. The estimated pressure differential on non-clogged system is approximately 2.0 psi

Plan of Action:

After Leopold's onsite inspection, Leopold's recommendation for this filter was removal of the I.M.S Cap and replacing with I.M.S 200 media retainer. Media was removed to determine that the underdrain was not damaged and to make sure it's a good candidate for an IMS cap replacement. Utility staff completed all necessary underdrain preparations and IMS cap conversion to the IMS 200 cap. Leopold indicates that an IMS cap conversion extends the working life of an underdrain 5-10years. The utility would then need to look at an underdrain replacement after 5 years. The replacement underdrain would ideally be the same underdrain system installed in other filtrations systems based on the underdrain evaluation report generated by CDM Smith. Total underdrain replacement cost for filter 5 after 5 years is estimated to be \$425,000 installed with media. Recommend scheduling replacement in year 2028.

Filters #3 and #4

Installation year: 1998

Age: 23/24 years

Underdrain Type: S Underdrain with I.M.S Cap media retainer

Modifications: None

Pressure testing across existing I.M.S cap (Head loss):

- Filter 3
 - Pressure reading at high-rate backwash = 8.4 psi
 - Pressure reading at static (water level at trough weir) = 3.5 psi
 - Pressure differential = 4.9 psi
- Filter 4
 - Pressure reading at high-rate backwash = 9.2 psi
 - Pressure reading at static (water level at trough weir) = 3.4 psi
 - Pressure differential = 5.8 psi

Filters 3 and 4 are experiencing elevated headloss at pressure differentials of 4.9 psi and 5.8 psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi.

Plan of Action:

Continue with monitoring and operational contingency planning to further reduce risk of over pressurizing the IMS caps. Filters 4 and 3 should be targeted for replacement within 2-3 years. Replacement underdrain systems would be based on filter underdrain alternatives and review workshops conducted by utility staff and CDM Smith. Total underdrain replacement cost for both filters is estimated to be \$800,000 installed with media. Recommend scheduling replacement in year 2025.

Filters #1 and #2

Installation year: 1998

Age: 23 years

Underdrain Type: S Underdrain with I.M.S Cap media retainer

Modifications: None

Pressure testing across existing I.M.S cap (Head loss):

- Filter 1
 - Pressure reading at high-rate backwash = 7.8 psi
 - Pressure reading at static (water level at trough weir) = 3.2 psi
 - Pressure differential = 4.6 psi
- Filter 2
 - Pressure reading at high-rate backwash = 7.5 psi
 - Pressure reading at static (water level at trough weir) = 2.5 psi
 - Pressure differential = 5.0 psi

Filters 1 and 2 are experiencing slightly elevated headloss at pressure differentials of 4.6 psi and 5.0 psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi.

Plan of Action:

Continue with monitoring and operational contingency planning to further reduce risk of over pressurizing the IMS caps. Filters 1 and 2 should be targeted for replacement within 3-4 years. Replacement underdrain systems would be based on filter underdrain alternatives and review workshops conducted by utility staff and CDM Smith. Total underdrain replacement cost for both filters is estimated to be \$800,000 installed with media. Recommend scheduling replacement in year 2026.

Filters #10 and #11

Installation year: 2018/2007

Age: 4 years and 15 years

Modifications: Original S Underdrain with I.M.S Cap media retainer replaced due to failures

- 2007 – Filter #11 underdrain failure. Replaced with Type SL underdrain with I.M.S Cap media retainer
- 2018 – Filter #10 underdrain failure. Replaced with Type XA underdrain with I.M.S 200 media retainer

Pressure testing across existing I.M.S cap (Head loss):

- Filter 10
 - Pressure reading at high-rate backwash = 4.8 psi
 - Pressure reading at static (water level at trough weir) = 2.5 psi
 - Pressure differential = 2.3 psi
- Filter 11
 - Pressure reading at high-rate backwash = 8.5 psi
 - Pressure reading at static (water level at trough weir) = 3.3 psi
 - Pressure differential = 5.2 psi


Filters 10 is not seeing significant increased pressures. Filter 11 is experiencing slightly elevated headloss at a pressure differential of 5.2 psi. The estimated pressure differential on non-clogged system is approximately 2.0 psi.

Plan of Action:

Continue with monitoring and operational contingency planning to further reduce risk of over pressurizing the IMS caps. Filter 10 should have a working lifetime of 20-25 years based on previous replacement work and assessments. The replacement underdrain would ideally be the same underdrain system installed in other filtrations systems. Total underdrain replacement cost is estimated to be \$600,000 installed with media. Recommend scheduling replacement in year 2038.

Filter 11 should be targeted sooner because it is still operating under the same style underdrain system (Type SL underdrain with I.M.S Cap media retainer) that failed in 2007. The replacement underdrain would ideally be the same underdrain system installed in other filtrations systems. Total underdrain replacement cost is estimated to be \$550,000 installed with media. Recommend scheduling replacement in year 2027 when the underdrain is at 20-year life expectancy.

Filter Underdrain Pressure Monitoring (High Backwash Rate)




NOTE:
13-15gpm/ft² backwash rate used to minimize over pressurizing
Typical backwash rate is 15-20gpm/ft²

Contingency Planning

The Operations department has implemented the following changes to backwashing operations to further reduce risk of over pressurizing the IMS caps:

- Filter Run Hours: Filters are to be washed every 100hrs or one per shift. This action is to prevent any further clogging of the IMS cap.
- Wash Operations: To help reduce the pressure across the IMS cap, staff will wash at a lower rate. Typically, the wash valve is set to wash at a high wash rate of 15-20gpm/ft². Washing operations have been adjusted to 13-15gpm/ft².
- Operations staff have installed pressure gauges on the filters to monitor pressure across the caps. Monitoring the pressure vs gpm/ft² during wash operations is ongoing. Any change in pressure over time will help determine whether the underdrain IMS cap is clogging at rapid rate.

Individual Filter Underdrain Headloss Curve Example:



Replacement and Cost Schedule

Underdrain Replacement and Cost Schedule			
Year	Filter #	Cost	Total Cost
2024	9	\$ 425,000.00	\$ 1,275,000.00
	8	\$ 425,000.00	
	7	\$ 425,000.00	
2025	4	\$ 400,000.00	\$ 800,000.00
	3	\$ 400,000.00	
2026	2	\$ 400,000.00	\$ 800,000.00
	1	\$ 400,000.00	
2027	11	\$ 550,000.00	\$ 550,000.00
2028	5	\$ 425,000.00	\$ 850,000.00
	6	\$ 425,000.00	
2038	10	\$ 600,000.00	\$ 600,000.00

These are initial cost estimates provided by filter underdrain manufacturers. Updated cost estimates to be included in the underdrain replacement alternatives and review report provided by CDM Smith. Design services and bidding documents would also need to be provided by CDM Smith. WDNR and PSC approvals will be required, with estimated lead times of 4-6 months. I would recommend that no more than 3 filters be out of service for replacement to maintain plant filter capacity for an average day demand. Under this replacement schedule, 54% of the filters will be either new and/or rehabilitated by spring 2024, this includes the filter 10 underdrain replacement in 2018.

REQUISITION

SHEBOYGAN WATER UTILITY

REQUISITION DATE 01/11/2023

Item 6.

VENDOR: BADGER METER INC
4545 W BROWN DEER RD
P. O. BOX 245036
MILWAUKEE WI 53224

SHIP TO 72 Park Ave Sheboygan WI 53081

DATE REQUESTED BY 01/17/2023

REQUISITION NO. 4969

QTY	ITEM #	INVENTORY #	DESCRIPTION	UNIT PRICE	TOTAL PRICE
360			M25 Plastic disc meter 5/8" x 7 1/2"--5/8" bore, bare	57.73	20,782.80
			Total Freight Misc		
NOTE:					
TOTAL					20,782.80

☐ CALL IN PURCHASE ORDER NUMBER PREPARED BY davew
PHONE NO. 800-616-3837

☐ FAX PURCHASE ORDER REQUESTED BY DW
FAX NUMBER: 888-371-5982

☐ SEND ORIGINAL PURCHASE ORDER TO VENDOR APPROVED BY

☐ ALREADY ORDERED